

TIREE, United Kingdom

WMO: 031000

Lat: 56.4999N

Lon: 6.8807W

Elev: 38

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.9	34.0	23.3	17.6	35.7	25.4	19.5	36.7	47.2	43.5	43.6	43.7	9.3	60	0.827

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.3	65.4	60.0	63.0	58.8	61.5	57.8	61.1	63.9	59.9	62.0	58.8	60.6	11.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.8	77.0	62.2	58.8	74.0	61.0	57.8	71.4	59.9	27.2	64.1	26.3	62.0	25.6	60.7	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.3	35.0	31.6	28.2	70.8	2.3	3.6	26.5	73.4	25.1	75.5	23.8	77.6	22.1	80.2		
(5)			26.4	63.9	2.4	2.1	24.7	65.5	23.3	66.7	22.0	67.9	20.2	69.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	42.7	42.4	43.5	46.3	50.0	53.7	56.5	56.9	55.0	51.0	46.7	43.8	
	DBStd	6.37	3.72	3.87	3.66	3.62	3.72	2.95	2.73	2.62	2.82	3.68	4.08	4.51	
	HDD50	1149	226	214	202	118	45	3	0	0	2	32	111	196	
	HDD65	5811	691	634	666	561	466	338	263	250	301	433	549	659	
	CDD50	813	0	0	0	7	44	115	202	215	151	65	12	2	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	16.1	19.9	19.2	17.3	15.6	13.9	13.2	11.9	12.8	15.0	17.5	18.2	19.1	
Precipitation	PrecAvg	47.4	5.1	3.7	3.6	2.6	2.4	2.6	3.2	3.9	4.5	5.5	5.1	5.2	
	PrecMax	59.9	10.2	9.7	7.1	6.1	6.9	5.4	7.6	9.1	8.9	9.8	9.4	10.6	
	PrecMin	33.7	0.7	0.2	0.2	0.3	0.6	0.9	0.8	0.4	1.1	1.5	1.7	1.6	
	PrecStd	6.3	2.0	2.0	1.5	1.3	1.2	0.9	1.4	1.8	1.8	2.1	1.7	2.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	51.8	52.9	59.2	67.0	67.2	69.3	69.4	63.5	59.8	56.5	53.9	
		MCWB	50.3	50.2	49.4	51.4	57.4	60.4	62.9	63.0	58.8	56.6	54.5	52.4	
	2%	DB	50.5	50.5	50.9	54.9	60.9	62.8	64.8	64.7	61.6	58.3	54.8	52.6	
		MCWB	49.3	49.1	48.5	50.0	54.9	58.2	60.3	60.4	58.0	55.8	53.0	51.2	
	5%	DB	49.6	49.4	49.9	52.9	57.5	60.2	62.5	62.6	60.3	57.3	53.8	51.5	
		MCWB	48.4	48.0	47.9	49.0	52.9	56.3	58.8	59.0	57.3	55.0	52.1	50.1	
	10%	DB	48.5	48.3	48.9	51.4	55.5	58.5	61.0	61.1	59.4	56.3	52.6	50.4	
		MCWB	47.1	46.8	47.0	48.4	51.7	55.2	57.7	57.8	56.6	54.1	50.8	48.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	51.0	50.8	52.8	58.5	61.2	63.4	63.4	60.3	57.9	55.5	53.0
			MCDB	51.2	51.3	51.6	56.5	64.6	66.0	67.8	67.8	61.5	58.8	56.1	53.4
2%		WB	49.8	49.5	49.4	51.1	55.8	58.6	61.1	61.3	59.3	56.7	53.7	51.6	
		MCDB	50.3	50.2	50.2	53.5	59.8	61.9	63.9	63.8	60.5	57.6	54.4	52.3	
5%		WB	48.7	48.4	48.5	50.1	53.8	57.0	59.6	60.0	58.3	55.7	52.5	50.5	
		MCDB	49.4	49.3	49.4	52.0	56.5	59.4	61.8	61.9	59.7	56.8	53.5	51.4	
10%		WB	47.3	47.1	47.4	49.0	52.4	55.8	58.4	58.8	57.4	54.7	51.1	49.1	
		MCDB	48.4	48.2	48.6	51.0	54.7	57.8	60.3	60.4	58.8	56.0	52.4	50.3	
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.7	7.5	8.4	9.3	8.2	8.2	8.3	7.9	7.1	6.8	6.8	
		MCDBR	6.7	6.1	7.3	9.7	12.0	10.5	10.1	9.7	8.4	6.7	6.5	6.8	
		MCWBR	7.4	6.3	6.3	6.9	7.9	7.0	6.7	6.6	6.4	6.1	7.2	7.5	
	5% WB	MCDBR	6.6	5.9	6.8	8.1	10.4	9.5	9.1	8.6	7.2	6.4	6.6	6.9	
		MCWBR	7.5	6.4	6.7	6.4	7.7	6.7	6.6	6.6	6.3	6.8	7.7	7.9	
Clear-Sky Solar Irradiance	taub	0.353	0.359	0.375	0.385	0.389	0.378	0.381	0.369	0.370	0.353	0.339	0.335		
	taud	2.154	2.259	2.298	2.327	2.372	2.446	2.447	2.487	2.456	2.386	2.233	2.135		
	Ebn at Noon	157	216	246	263	270	274	271	267	248	218	164	130		
	Edh at Noon	19	25	31	35	35	33	32	29	26	22	17	15		
All-Sky Solar Radiation	RadAvg	132	342	726	1256	1630	1669	1538	1244	823	431	175	90		
	RadStd	14	33	51	83	122	167	105	83	50	44	16	11		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page