

CORSEWALL POINT LH, United Kingdom

WMO: 031180

Lat: 55.007N

Lon: 5.159W

Elev: 49

StdP: 14.67

Time Zone: 0.00 (EUW)

Period: 82-90

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.2	31.8	22.9	17.3	34.2	24.9	19.0	34.9	50.8	41.8	46.2	42.6	14.6	90	0.824

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	67.1	60.6	64.4	59.8	62.3	58.7	61.8	65.4	60.4	63.3	59.2	61.7	12.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.3	78.2	62.8	59.1	74.9	61.7	57.9	71.8	60.5	27.7	65.8	26.7	63.5	25.9	61.9	66.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.6	34.6	31.9	DB	26.5	73.1	3.3	3.0	24.1	75.3	22.1	77.1	20.3	78.8	17.9	80.9	(4)
(5)			WB	24.9	65.1	3.1	1.5	22.7	66.2	20.9	67.0	19.2	67.8	16.9	68.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	41.2	40.5	42.5	45.2	49.9	53.9	57.3	57.2	54.6	51.3	46.1	44.3
	DBStd	6.95	5.21	4.49	3.52	3.52	3.65	3.52	2.87	2.90	2.75	3.27	3.82	4.38
	HDD50	1291	272	266	232	148	43	4	0	0	1	24	123	178
	HDD65	5938	736	686	697	593	467	333	239	244	312	424	566	641
	CDD50	828	1	0	0	5	40	121	227	222	139	65	6	2
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0
	CDH74	7	0	0	0	0	0	0	2	5	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.0	20.7	19.4	18.1	13.7	13.1	11.7	11.7	13.4	15.8	18.0	17.8	18.7
Precipitation	PrecAvg	63.7	7.4	5.4	5.1	3.9	3.5	3.4	4.0	4.3	5.1	7.1	7.3	7.1
	PrecMax	81.3	12.3	10.3	9.8	6.6	7.8	5.7	6.8	10.8	8.8	12.1	12.0	13.1
	PrecMin	47.8	1.5	1.9	2.2	1.7	0.9	1.3	1.1	1.0	1.5	2.1	3.8	2.3
	PrecStd	8.8	2.5	2.6	1.9	1.3	1.7	1.2	1.3	2.2	2.0	2.8	2.2	3.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.9	51.9	51.8	58.2	67.6	69.5	71.2	71.4	64.0	60.1	55.1	53.7
		MCWB	50.1	50.0	49.6	51.1	57.2	61.7	61.7	61.5	59.9	57.6	53.1	51.5
	2%	DB	50.3	49.7	50.2	54.6	61.2	64.9	66.7	66.1	61.7	58.3	53.7	52.2
		MCWB	48.9	48.5	48.6	49.8	53.7	59.4	61.2	60.8	58.6	56.3	52.2	50.7
	5%	DB	49.2	48.3	49.0	52.2	57.7	62.0	64.3	63.1	60.0	57.1	52.6	51.5
		MCWB	47.9	47.0	47.4	48.7	52.4	58.0	60.5	59.5	57.3	55.1	50.9	50.1
	10%	DB	48.0	46.8	47.5	50.4	55.5	59.4	62.2	61.2	58.6	55.9	51.5	50.4
		MCWB	46.7	45.4	45.9	47.5	51.3	55.8	59.1	58.2	56.4	53.8	49.6	49.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	50.3	50.3	52.6	58.0	62.1	64.3	63.5	61.1	58.5	53.9	52.7
		MCDB	51.7	51.2	50.9	55.6	65.6	67.2	67.1	69.1	63.4	59.1	54.4	52.9
	2%	WB	49.5	48.9	49.1	50.8	54.8	59.9	62.1	61.5	59.4	57.3	52.6	51.2
		MCDB	50.1	49.7	49.9	53.3	58.9	64.0	65.6	64.7	60.8	58.1	53.4	51.8
	5%	WB	48.3	47.4	48.0	49.4	53.2	58.3	60.6	60.1	58.1	55.8	51.3	50.4
		MCDB	48.9	48.0	48.9	51.7	56.6	61.5	63.4	62.6	59.4	56.6	52.3	51.2
	10%	WB	47.0	45.6	46.1	48.0	51.8	56.5	59.2	58.7	57.0	54.4	50.0	49.4
		MCDB	47.9	46.6	47.0	50.0	55.1	58.9	61.8	60.7	58.3	55.6	51.1	50.4
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.8	5.8	7.1	7.8	7.1	6.8	6.4	6.1	5.9	5.4	5.3
		MCDBR	5.7	6.3	6.4	9.6	12.5	12.1	11.5	9.9	7.9	6.7	5.8	5.5
		MCWBR	6.3	6.1	5.7	6.8	7.7	8.0	7.5	6.4	6.3	5.9	6.7	5.8
	5% WB	MCDBR	5.6	6.0	6.3	8.7	10.9	11.3	10.1	8.8	7.5	5.9	6.0	5.4
		MCWBR	6.3	6.2	6.0	6.7	7.8	8.0	7.5	6.5	7.0	6.3	6.9	5.7
Clear-Sky Solar Irradiance	taub	0.334	0.346	0.369	0.385	0.388	0.383	0.384	0.369	0.363	0.347	0.327	0.321	
	taud	2.250	2.336	2.318	2.312	2.351	2.401	2.401	2.455	2.469	2.438	2.323	2.218	
	Ebn at Noon	183	231	253	266	272	274	271	269	254	229	186	157	
	Edh at Noon	19	24	31	36	36	35	34	31	27	22	17	16	
All-Sky Solar Radiation	RadAvg	167	384	754	1219	1560	1555	1488	1219	847	461	219	124	
	RadStd	20	41	58	91	137	158	135	89	59	55	23	13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page