

CORSEWALL POINT LH, United Kingdom

WMO: 031180

Lat: 55.007N

Lon: 5.159W

Elev: 15

StdP: 101.14

Time Zone: 0.00 (EUW)

Period: 82-90

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.6	-0.1	-5.1	2.5	1.2	-3.9	2.7	1.6	22.7	5.5	20.6	5.9	6.5	90	0.824

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.8	19.5	15.9	18.0	15.5	16.8	14.8	16.6	18.6	15.8	17.4	15.1	16.5	5.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.7	11.2	17.1	15.0	10.7	16.5	14.4	10.3	15.8	46.5	18.8	44.3	17.5	42.4	16.6	19.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.5	14.3	DB	-3.1	22.9	1.8	1.7	-4.4	24.1	-5.5	25.0	-6.5	26.0	-7.9	27.2	(4)
(5)			WB	-4.0	18.4	1.7	0.8	-5.2	19.0	-6.2	19.5	-7.1	19.9	-8.4	20.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	5.1	4.7	5.8	7.4	10.0	12.2	14.1	14.0	12.5	10.7	7.9	6.8
	DBStd	3.86	2.89	2.49	1.95	1.96	2.03	1.96	1.59	1.61	1.53	1.82	2.12	2.43
	HDD10.0	717	151	148	129	82	24	2	0	0	1	13	68	99
	HDD18.3	3299	409	381	387	329	259	185	133	136	173	236	314	356
	CDD10.0	460	1	0	0	3	22	67	126	123	77	36	3	1
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	4	0	0	0	0	0	0	1	3	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.1	9.3	8.7	8.1	6.1	5.9	5.2	5.2	6.0	7.1	8.0	8.0	8.3
Precipitation	PrecAvg	1618	188	138	130	99	89	87	101	110	130	181	185	181
	PrecMax	2066	312	261	250	168	198	146	172	274	223	307	304	334
	PrecMin	1215	38	48	55	44	24	32	29	25	38	53	97	58
	PrecStd	223	63	65	49	34	44	31	34	56	51	72	55	76
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	11.0	11.0	14.6	19.8	20.8	21.8	21.9	17.8	15.6	12.9	12.0
		MCWB	10.1	10.0	9.8	10.6	14.0	16.5	16.5	16.4	15.5	14.2	11.7	10.8
	2%	DB	10.2	9.8	10.1	12.6	16.2	18.3	19.3	19.0	16.5	14.6	12.0	11.2
		MCWB	9.4	9.1	9.2	9.9	12.1	15.2	16.2	16.0	14.8	13.5	11.2	10.4
	5%	DB	9.5	9.0	9.4	11.2	14.3	16.7	17.9	17.3	15.5	13.9	11.4	10.8
		MCWB	8.8	8.4	8.6	9.3	11.3	14.4	15.8	15.3	14.1	12.8	10.5	10.1
	10%	DB	8.9	8.2	8.6	10.2	13.0	15.2	16.8	16.2	14.8	13.3	10.8	10.2
		MCWB	8.2	7.5	7.7	8.6	10.7	13.2	15.0	14.6	13.6	12.1	9.8	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	10.2	10.2	11.5	14.4	16.7	17.9	17.5	16.2	14.7	12.1	11.5
		MCDB	10.9	10.7	10.5	13.1	18.7	19.6	19.5	20.6	17.4	15.1	12.5	11.6
	2%	WB	9.7	9.4	9.5	10.5	12.7	15.5	16.7	16.4	15.2	14.0	11.5	10.7
		MCDB	10.1	9.8	9.9	11.8	14.9	17.8	18.7	18.2	16.0	14.5	11.9	11.0
	5%	WB	9.1	8.5	8.9	9.7	11.8	14.6	15.9	15.6	14.5	13.2	10.7	10.2
		MCDB	9.4	8.9	9.4	10.9	13.7	16.4	17.5	17.0	15.2	13.7	11.3	10.7
	10%	WB	8.3	7.6	7.9	8.9	11.0	13.6	15.1	14.8	13.9	12.5	10.0	9.7
		MCDB	8.8	8.1	8.4	10.0	12.9	15.0	16.6	15.9	14.6	13.1	10.6	10.2
Mean Daily Temperature Range	5% DB	MDBR	3.0	3.2	3.2	3.9	4.4	3.9	3.8	3.6	3.4	3.3	3.0	3.0
		MCDBR	3.2	3.5	3.5	5.4	7.0	6.7	6.4	5.5	4.4	3.7	3.2	3.1
		MCWBR	3.5	3.4	3.2	3.8	4.3	4.5	4.2	3.5	3.5	3.3	3.7	3.2
	5% WB	MCDBR	3.1	3.3	3.5	4.8	6.1	6.3	5.6	4.9	4.1	3.3	3.3	3.0
		MCWBR	3.5	3.4	3.4	3.7	4.3	4.4	4.2	3.6	3.9	3.5	3.8	3.2
Clear-Sky Solar Irradiance	taub	0.334	0.346	0.369	0.385	0.388	0.383	0.384	0.369	0.363	0.347	0.327	0.321	
	taud	2.250	2.336	2.318	2.312	2.351	2.401	2.401	2.455	2.469	2.438	2.323	2.218	
	Ebn at Noon	576	727	797	837	856	864	855	847	802	721	587	496	
	Edh at Noon	60	77	98	112	114	110	108	97	84	69	55	49	
All-Sky Solar Radiation	RadAvg	0.53	1.21	2.38	3.84	4.92	4.90	4.69	3.84	2.67	1.45	0.69	0.39	
	RadStd	0.06	0.13	0.18	0.29	0.43	0.50	0.42	0.28	0.19	0.17	0.07	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page