

GLASGOW AP, United Kingdom

WMO: 031400

Lat: 55.872N

Lon: 4.433W

Elev: 26

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.2	24.9	19.1	14.4	25.0	21.6	16.2	28.0	37.2	46.2	32.6	47.5	1.6	230	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	73.7	62.9	70.2	61.2	67.9	60.0	64.8	71.4	63.0	68.4	61.4	66.1	9.3	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.4	84.4	67.6	60.8	79.5	66.0	59.1	74.9	64.0	29.8	71.1	28.5	68.1	27.4	65.8	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.9	21.0	16.2	79.8	5.4	3.1	12.3	82.0	9.2	83.8	6.1	85.6	2.2	87.8
			15.6	68.0	5.3	1.9	11.8	69.4	8.7	70.5	5.7	71.6	1.8	73.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.5	39.4	40.0	42.4	46.5	51.4	56.2	59.3	58.6	55.0	49.5	43.7	39.4
	DBStd	8.89	5.91	5.36	4.91	4.65	4.93	4.04	3.89	3.93	4.08	5.20	5.98	7.52
	HDD50	1622	328	280	240	123	41	2	0	0	7	72	200	329
	HDD65	6034	792	699	702	556	421	266	183	204	300	479	640	792
	CDD50	1075	1	1	3	17	85	187	289	266	157	57	10	2
	CDD65	13	0	0	0	0	0	1	7	5	0	0	0	0
	CDH74	101	0	0	0	0	6	18	48	28	1	0	0	0
	CDH80	7	0	0	0	0	0	2	3	2	0	0	0	0
Wind	WSAvg	9.4	10.4	10.6	10.6	9.8	9.5	8.9	8.1	8.1	8.6	9.3	9.0	9.5
Precipitation	PrecAvg	46.1	5.1	3.7	4.0	2.5	2.8	2.6	2.7	3.5	4.6	5.1	4.9	4.9
	PrecMax	60.4	10.9	9.8	8.6	5.1	6.5	4.6	6.5	7.3	11.3	11.0	8.1	10.9
	PrecMin	34.7	0.7	0.4	0.8	0.2	0.3	0.5	0.5	0.4	0.4	1.3	0.7	1.2
	PrecStd	6.1	2.4	2.2	1.9	1.1	1.5	1.1	1.3	1.7	2.2	2.5	1.9	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	53.9	57.6	66.1	73.6	76.6	79.1	77.8	69.9	63.0	58.5	55.6
		MCWB	51.3	51.0	50.4	54.8	60.1	62.9	66.2	66.1	61.5	58.5	55.5	53.2
	2%	DB	51.8	51.9	53.9	60.7	68.0	71.4	73.8	71.8	66.4	60.8	55.8	53.5
		MCWB	49.5	49.3	49.0	52.1	58.1	60.7	63.7	62.9	59.6	57.1	53.1	51.3
	5%	DB	50.1	50.2	52.0	57.2	64.1	67.7	70.2	68.3	64.3	59.0	53.9	51.7
		MCWB	48.2	47.9	47.8	50.4	55.4	59.0	61.8	60.8	58.7	55.7	51.3	49.5
	10%	DB	48.3	48.4	50.2	55.0	60.5	64.4	67.7	66.1	62.4	57.3	52.2	49.8
		MCWB	46.7	46.2	46.9	49.3	53.1	57.0	60.5	60.0	57.7	54.2	49.7	48.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	51.9	52.6	56.2	62.9	64.9	67.6	67.1	63.8	59.7	56.1	53.8
		MCDB	54.1	53.7	56.6	63.2	71.3	73.6	76.2	75.1	68.2	62.3	58.0	55.6
	2%	WB	50.1	49.9	50.5	53.4	58.9	62.0	65.1	64.3	61.4	57.8	54.0	51.7
		MCDB	51.3	51.2	52.9	58.8	66.6	69.0	72.1	69.6	64.8	60.2	56.0	53.5
	5%	WB	48.3	48.2	48.9	51.6	56.3	59.7	63.2	62.6	59.7	56.3	52.2	49.9
		MCDB	49.5	50.0	51.3	56.2	62.3	65.7	68.8	66.9	62.9	58.7	54.2	51.2
	10%	WB	46.5	46.4	47.3	50.0	54.2	57.9	61.3	61.0	58.3	54.8	50.4	47.8
		MCDB	48.2	48.4	49.8	53.7	59.5	63.1	66.2	65.0	61.6	57.3	52.2	49.3
Mean Daily Temperature Range	5% DB	MDBR	9.4	10.9	12.4	14.3	15.3	14.4	14.2	14.5	13.2	11.9	10.7	10.1
		MCDBR	9.5	10.4	13.8	18.0	21.4	20.6	20.1	18.5	16.1	12.1	10.4	9.9
		MCWBR	9.0	9.0	9.9	11.5	12.6	12.0	11.2	10.8	10.4	9.5	9.3	9.6
	5% WB	MCDBR	9.4	9.8	11.8	15.9	18.6	17.7	17.1	15.9	13.1	10.7	10.1	10.2
		MCWBR	9.3	9.2	9.6	10.8	11.7	11.0	10.4	10.1	9.8	9.2	9.5	10.1
Clear-Sky Solar Irradiance	taub	0.333	0.344	0.369	0.387	0.390	0.385	0.386	0.370	0.362	0.345	0.324	0.317	
	taud	2.205	2.307	2.280	2.270	2.308	2.353	2.356	2.411	2.437	2.415	2.297	2.185	
	Ebn at Noon	174	226	250	263	270	272	269	267	252	225	180	148	
	Edh at Noon	19	24	32	37	38	36	36	32	27	22	17	15	
All-Sky Solar Radiation	RadAvg	148	358	705	1151	1487	1455	1394	1121	778	419	197	112	
	RadStd	22	44	57	93	136	158	140	89	61	56	19	14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page