

GLEN OGLE, United Kingdom

WMO: 031480

Lat: 56.4249N

Lon: 4.3232W

Elev: 1850

StdP: 13.74

Time Zone: 0.00 (EUW)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.3	24.7	14.2	12.1	30.2	17.5	14.2	28.4	85.4	37.6	73.3	34.1	15.4	320	0.963

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	65.1	55.6	62.0	54.2	59.4	53.7	58.5	61.5	56.9	59.8	55.4	57.9	13.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	75.3	59.1	55.8	70.9	57.7	54.1	66.7	56.1	26.2	61.7	25.2	60.0	24.1	57.9	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 61.6	48.7	40.2	DB	20.9	71.0	2.4	3.3	19.2	73.4	17.7	75.3	16.4	77.1	14.6	79.5	(4)
(5)			WB	19.5	62.1	2.3	2.8	17.9	64.0	16.5	65.6	15.2	67.2	13.6	69.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.2	33.8	34.0	35.6	39.5	44.6	48.9	52.2	51.7	48.8	43.3	37.9	35.0		
	DBStd	8.25	4.62	5.02	5.23	5.12	5.66	4.58	4.37	3.78	3.99	4.31	4.91	5.26		
	HDD50	3120	502	447	446	316	189	73	22	20	66	211	364	464		
	HDD65	8333	967	867	910	764	631	484	397	412	485	673	814	929		
	CDD50	262	0	0	1	2	22	40	90	74	31	2	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	1	0	0	0	0	0	1	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	18.1	21.7	21.1	19.1	17.0	15.8	14.5	14.4	15.5	16.6	18.8	21.1	21.7		
	PrecAvg	64.4	8.7	6.4	5.7	4.0	3.5	3.8	3.5	3.8	5.2	6.9	6.4	6.5		
(15) Precipitation	PrecMax	77.0	16.1	14.2	13.0	6.1	6.1	7.3	6.3	9.7	8.7	12.0	9.3	12.9		
	PrecMin	47.6	2.5	1.2	2.5	1.4	0.6	0.8	0.9	0.9	1.9	1.1	3.0	1.9		
	PrecStd	9.0	3.4	3.8	2.6	1.1	1.8	1.5	1.3	2.2	2.2	3.1	1.9	3.3		
	PrecStd	9.0	3.4	3.8	2.6	1.1	1.8	1.5	1.3	2.2	2.2	3.1	1.9	3.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.4	48.9	53.3	58.1	66.4	66.9	69.6	68.1	62.2	54.9	51.7	50.0		
		MCWB	46.5	46.3	45.4	47.7	54.0	55.6	58.2	58.6	55.3	53.3	50.0	48.3		
	2%	DB	45.0	46.2	47.5	53.0	61.3	62.6	65.3	62.7	58.7	52.9	49.0	47.2		
		MCWB	44.2	44.5	43.1	45.7	51.5	53.1	56.4	55.8	54.8	51.8	48.0	45.8		
	5%	DB	43.0	43.8	44.8	49.6	56.9	59.0	62.0	59.3	56.5	51.0	46.8	45.0		
		MCWB	42.3	42.7	42.5	44.4	49.0	52.7	54.9	54.9	53.5	49.8	45.9	43.8		
	10%	DB	41.0	41.5	42.7	46.6	53.1	55.8	59.0	57.1	54.4	49.4	44.9	42.7		
		MCWB	40.3	40.5	40.8	43.0	46.8	50.3	54.4	53.8	51.9	48.3	44.1	41.8		
	0.4%	WB	46.8	47.5	47.6	50.4	56.9	58.5	61.1	60.7	58.4	54.0	50.6	48.8		
		MCDB	47.1	47.9	51.0	54.3	62.7	62.9	65.5	64.3	59.7	54.3	51.0	49.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.6	44.9	45.0	47.6	53.1	55.9	58.5	58.2	56.3	52.1	48.4	46.4		
		MCDB	44.9	45.5	46.5	50.9	58.8	60.8	62.0	60.7	57.5	52.6	48.7	46.9		
	5%	WB	42.5	42.7	42.9	45.5	50.2	53.5	56.9	56.4	54.2	50.3	46.1	44.2		
		MCDB	42.9	43.5	44.1	48.3	54.8	56.7	60.1	58.4	55.4	50.7	46.6	44.8		
	10%	WB	40.5	40.6	41.1	43.7	48.1	51.7	55.2	54.7	52.6	48.6	44.2	41.9		
		MCDB	40.9	41.5	42.4	46.1	52.1	54.5	58.0	56.4	53.9	49.1	44.8	42.5		
	5% DB	MDBR	6.1	6.5	7.3	9.0	10.5	9.6	9.0	8.2	7.6	6.4	6.2	6.3		
		MCDBR	9.0	9.0	10.0	13.1	15.4	14.6	13.2	11.0	9.9	8.1	8.9	9.7		
		MCWBR	9.0	8.6	7.6	8.1	8.8	8.9	7.5	6.8	7.0	7.5	9.2	9.8		
		MCWBR	8.9	8.7	9.2	10.9	13.4	11.7	10.7	9.3	8.6	7.9	8.8	9.5		
(35) Mean Daily Temperature Range	5% WB	MCWBR	9.1	8.6	8.2	7.8	8.5	8.3	7.3	7.3	7.6	7.9	9.2	9.8		
		MCWBR	9.1	8.6	8.2	7.8	8.5	8.3	7.3	7.3	7.6	7.9	9.2	9.8		
	taub	taub	0.291	0.308	0.330	0.347	0.350	0.348	0.349	0.335	0.326	0.313	0.288	0.274		
		taud	2.252	2.377	2.368	2.364	2.391	2.418	2.416	2.465	2.503	2.486	2.346	2.201		
(40) Clear-Sky Solar Irradiance	Ebn at Noon	Ebn at Noon	190	241	264	277	282	284	281	278	265	238	193	162		
		Edh at Noon	17	22	29	33	34	34	33	30	25	20	15	13		
	RadAvg	RadAvg	137	338	667	1108	1453	1415	1355	1077	743	397	179	103		
		RadStd	22	44	62	94	128	152	134	93	58	53	17	14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+2.02	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page