

EDINBURGH AP, United Kingdom

WMO: 031600

Lat: 55.950N

Lon: 3.373W

Elev: 41

StdP: 100.83

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.1	-3.2	-7.1	2.1	-3.3	-5.3	2.4	-1.3	15.8	8.1	14.3	8.1	1.3	250	0.659

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	22.2	16.8	20.8	16.2	19.2	15.2	17.8	20.9	16.9	19.6	16.0	18.4	4.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.5	11.8	19.2	15.8	11.3	18.4	15.0	10.7	17.6	50.3	21.1	47.5	19.8	45.1	18.2	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	10.7	9.4	-8.3	25.5	2.6	2.1	-10.1	27.1	-11.7	28.3	-13.1	29.5	-15.0	31.0		
			-8.6	19.8	2.6	1.4	-10.4	20.8	-11.9	21.6	-13.4	22.4	-15.3	23.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	4.0	4.4	5.6	7.7	10.3	13.1	14.9	14.8	12.8	9.7	6.4	4.0
	DBStd	4.88	3.14	2.99	2.88	2.66	2.60	2.12	2.00	2.04	2.32	2.91	3.22	3.90
	HDD10.0	932	186	157	138	77	27	2	0	0	4	41	114	186
	HDD18.3	3410	443	389	394	319	249	158	108	112	167	268	359	443
	CDD10.0	570	1	1	2	8	36	94	153	148	88	32	6	2
	CDD18.3	4	0	0	0	0	0	2	2	1	0	0	0	0
	CDH23.3	27	0	0	0	0	1	2	16	7	1	0	0	0
	CDH26.7	2	0	0	0	0	0	0	1	1	0	0	0	0
Wind	WSAvg	4.3	4.8	4.9	4.9	4.5	4.4	4.1	3.7	3.7	4.1	4.2	4.2	4.5
Precipitation	PrecAvg	661	60	44	49	41	51	51	57	59	63	68	62	59
	PrecMax	848	120	112	91	93	136	133	156	120	150	133	197	129
	PrecMin	438	18	3	16	6	9	6	5	4	7	14	9	9
	PrecStd	101	27	27	23	20	29	30	34	31	38	34	37	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	13.2	14.9	17.9	21.2	23.0	25.6	24.0	22.1	18.0	15.1	13.5
		MCWB	10.6	11.1	10.7	12.8	15.1	16.3	18.1	18.2	16.8	14.6	13.1	11.8
	2%	DB	11.1	11.7	12.9	15.1	18.2	20.3	22.8	21.4	19.8	16.3	13.7	12.1
		MCWB	9.6	9.9	9.8	11.2	13.3	15.2	17.3	16.7	15.7	13.7	11.9	10.5
	5%	DB	10.0	10.4	11.4	13.9	16.3	18.9	20.9	20.0	18.1	15.2	12.2	11.0
		MCWB	8.6	8.7	8.8	10.3	12.4	14.4	16.5	15.9	14.5	13.0	10.5	9.5
	10%	DB	9.0	9.2	10.2	12.6	15.0	17.5	19.1	18.9	17.0	14.2	11.2	9.9
		MCWB	7.8	7.6	8.0	9.3	11.4	13.6	15.3	15.3	14.0	12.1	9.5	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	11.7	11.5	13.3	16.0	17.8	19.4	18.8	17.8	15.2	13.2	12.1
		MCDB	12.4	12.9	14.1	16.4	19.8	21.3	23.8	22.3	21.0	17.0	14.6	13.6
	2%	WB	9.9	10.0	10.3	11.8	14.1	16.0	18.0	17.6	16.4	14.2	12.1	10.8
		MCDB	10.9	11.3	12.2	14.8	17.4	19.3	21.4	20.4	18.8	16.1	13.6	12.2
	5%	WB	8.7	9.0	9.3	10.7	12.9	15.0	17.0	16.7	15.2	13.3	11.0	9.7
		MCDB	9.8	10.5	11.2	13.3	15.8	17.8	19.8	19.1	17.3	15.0	12.3	10.9
	10%	WB	7.6	7.7	8.3	9.8	11.8	14.0	16.0	15.9	14.3	12.5	9.9	8.4
		MCDB	8.8	9.1	10.2	12.1	14.5	16.8	18.5	17.9	16.3	14.2	11.1	9.6
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.1	6.9	7.7	8.0	7.7	8.1	8.0	7.6	6.9	6.2	5.7
		MCDBR	5.7	6.2	8.1	9.7	10.1	10.2	10.9	9.5	9.3	7.4	6.2	6.2
		MCWBR	5.2	5.2	5.8	6.2	6.1	6.0	6.3	5.5	5.9	5.6	5.4	5.7
	5% WB	MCDBR	5.7	6.1	7.1	9.0	9.2	9.0	9.3	8.2	8.2	6.8	6.2	6.1
		MCWBR	5.4	5.5	5.6	6.1	5.9	5.9	6.0	5.4	5.8	5.6	5.6	5.8
Clear-Sky Solar Irradiance	taub	0.325	0.339	0.370	0.390	0.390	0.389	0.389	0.374	0.360	0.343	0.319	0.308	
	taud	2.236	2.331	2.277	2.249	2.298	2.332	2.338	2.388	2.434	2.417	2.317	2.213	
	Ebn at Noon	562	722	786	826	850	855	846	836	796	710	574	481	
	Edh at Noon	57	75	100	118	120	117	114	102	85	68	52	46	
All-Sky Solar Radiation	RadAvg	0.52	1.16	2.18	3.57	4.71	4.60	4.43	3.56	2.53	1.38	0.67	0.38	
	RadStd	0.08	0.11	0.25	0.39	0.33	0.42	0.44	0.26	0.19	0.16	0.07	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page