

FIFE NESS, United Kingdom

WMO: 031740

Lat: 56.279N

Lon: 2.587W

Elev: 39

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.0	32.8	23.7	18.0	34.0	25.7	19.7	35.1	50.5	40.2	46.2	39.4	11.8	290	0.768

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	68.5	61.1	66.2	59.7	64.3	58.6	62.7	66.4	61.2	64.3	60.1	62.9	13.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.9	80.0	64.4	59.7	76.7	63.0	58.6	73.6	61.7	28.2	66.7	27.2	64.4	26.5	63.1	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.8	34.2	30.7	DB	27.1	73.8	3.1	3.7	24.8	76.5	23.0	78.7	21.2	80.8	18.9	83.5	(4)
(5)			WB	25.8	66.0	2.5	1.9	24.0	67.3	22.6	68.4	21.2	69.5	19.4	70.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	41.5	41.4	42.9	45.9	50.1	54.9	58.4	59.0	56.2	51.3	46.1	42.0		
	DBStd	7.48	3.66	3.99	4.17	3.85	3.78	3.41	3.18	2.75	3.14	4.08	4.41	4.89		
	HDD50	1321	264	242	221	135	45	2	0	0	1	35	127	249		
	HDD65	5780	729	661	684	574	463	304	208	188	266	424	566	713		
	CDD50	1020	0	1	2	11	47	148	259	278	186	76	11	1		
	CDD65	3	0	0	0	0	0	0	2	1	0	0	0	0		
	CDH74	8	0	0	0	0	0	0	6	2	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	14.4	17.7	17.6	15.6	14.2	12.3	12.2	10.0	10.7	12.8	16.2	16.8	16.9		
(15) Precipitation	PrecAvg	26.4	2.2	2.0	1.7	1.8	2.1	2.5	2.0	2.2	2.1	3.1	2.5	2.3		
	PrecMax	37.0	4.4	3.9	4.5	3.9	3.8	4.3	4.6	6.7	4.8	5.8	4.3	3.9		
	PrecMin	19.1	0.7	0.3	0.7	0.2	0.7	1.0	0.8	0.5	0.6	0.5	1.4	0.9		
	PrecStd	4.2	0.9	1.1	1.0	1.1	0.9	0.9	1.0	1.6	1.3	1.6	0.8	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	54.3	56.4	60.8	65.0	68.8	73.3	72.0	68.7	62.5	56.6	54.7		
		MCWB	49.7	52.1	51.2	53.1	56.8	60.4	65.1	63.1	61.6	56.8	53.9	53.1		
	2%	DB	50.6	51.5	53.4	56.8	61.1	65.6	68.7	68.2	65.1	59.9	54.9	51.8		
		MCWB	48.1	49.0	49.2	51.1	54.3	58.8	61.2	61.2	59.2	55.5	52.3	49.5		
	5%	DB	48.9	49.6	51.3	54.2	57.9	63.0	65.9	65.7	62.9	58.2	53.4	50.1		
		MCWB	46.4	47.1	48.1	49.4	52.7	56.8	59.6	59.6	57.9	54.8	51.1	48.1		
	10%	DB	47.2	47.5	49.2	51.8	55.5	60.7	63.8	63.7	61.0	56.7	52.1	48.6		
		MCWB	45.0	44.8	46.4	48.1	51.7	55.7	58.7	59.0	56.8	53.8	50.2	46.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	52.5	52.4	54.5	58.5	61.9	65.7	64.7	63.5	58.3	54.7	52.9		
		MCDB	52.0	54.1	55.2	58.9	62.6	66.1	72.8	70.2	67.5	61.0	55.7	54.1		
	2%	WB	48.6	49.4	50.1	51.9	55.5	59.6	62.6	62.6	60.4	56.8	52.9	49.8		
		MCDB	50.4	51.2	52.3	55.8	59.3	64.3	67.0	65.8	63.3	58.9	54.2	51.3		
	5%	WB	46.7	47.4	48.4	50.1	53.7	57.8	60.9	61.3	58.9	55.6	51.7	48.4		
		MCDB	48.4	49.4	50.8	53.5	57.1	61.6	64.4	63.9	61.6	57.4	52.8	49.9		
	10%	WB	45.4	45.2	46.7	48.4	52.1	56.3	59.5	60.3	57.6	54.4	50.6	47.0		
		MCDB	47.0	47.1	49.0	51.3	54.7	59.7	62.4	62.6	60.0	56.3	51.9	48.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	7.1	7.7	7.9	8.1	8.9	9.1	8.5	7.9	7.2	6.9	6.3		
		MCDBR	8.5	9.0	11.1	12.6	12.7	13.4	13.8	12.3	11.0	9.0	7.8	7.2		
	5% WB	MCWBR	8.0	8.2	8.5	8.2	8.2	8.3	8.4	7.3	7.4	6.8	7.4	7.0		
		MCWBR	8.2	9.0	10.6	11.7	11.2	12.0	11.8	9.7	9.3	7.6	7.0	7.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.317	0.334	0.365	0.386	0.382	0.384	0.385	0.373	0.358	0.342	0.315	0.298		
		taud	2.285	2.379	2.327	2.296	2.359	2.381	2.384	2.427	2.476	2.454	2.347	2.246		
	Ebn at Noon	Ebn at Noon	182	231	251	263	272	272	269	266	253	226	183	156		
		Edh at Noon	17	23	30	36	36	35	35	31	26	21	16	14		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	158	364	687	1129	1504	1478	1424	1137	800	431	206	116		
	RadStd	RadStd	23	34	84	120	96	127	128	79	54	50	21	14		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page