

DISHFORTH, United Kingdom

WMO: 032610

Lat: 54.137N

Lon: 1.420W

Elev: 36

StdP: 100.90

Time Zone: 0.00 (EUW)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.1	-2.6	-6.1	2.3	-1.4	-4.8	2.5	-0.4	15.3	8.5	13.4	8.5	1.7	340	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	25.1	18.0	23.2	17.2	21.5	16.2	18.7	23.1	17.8	22.0	16.9	20.4	4.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	12.2	20.6	16.2	11.5	19.4	15.4	11.0	18.5	53.1	23.0	50.3	22.2	47.6	20.6	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.5	9.2	-6.8	28.4	2.3	1.5	-8.5	29.5	-9.9	30.4	-11.2	31.3	-12.9	32.4		
(5)			-7.1	20.9	2.3	1.5	-8.8	22.0	-10.1	22.9	-11.4	23.8	-13.1	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	4.2	4.5	6.0	8.2	11.0	13.8	16.1	15.8	13.4	10.3	6.8	4.1	(6)
(7)		DBStd	5.19	3.07	3.12	2.84	2.86	2.80	2.61	2.41	2.41	2.29	2.84	3.15	3.71	(7)
(8)		HDD10.0	877	180	156	128	69	22	2	0	0	2	30	103	186	(8)
(9)		HDD18.3	3232	438	388	383	305	229	139	78	86	148	248	347	442	(9)
(10)		CDD10.0	706	1	1	3	14	52	114	189	180	104	41	6	2	(10)
(11)		CDD18.3	19	0	0	0	0	0	2	8	8	1	0	0	0	(11)
(12)		CDH23.3	149	0	0	0	0	2	18	71	52	6	1	0	0	(12)
(13)		CDH26.7	17	0	0	0	0	0	2	7	9	0	0	0	0	(13)
(14)	Wind	WSAvg	4.1	4.7	4.8	4.5	4.1	3.6	3.4	3.5	3.6	4.0	4.2	4.3	(14)	
(15)	Precipitation	PrecAvg	685	60	47	41	51	48	60	56	56	63	68	65	(15)	
(16)		PrecMax	959	127	88	90	140	97	162	128	155	115	147	137	129	(16)
(17)		PrecMin	518	8	10	9	5	11	8	18	14	15	21	22	20	(17)
(18)		PrecStd	109	28	22	22	35	21	37	25	32	30	28	29	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	13.4	15.7	19.5	22.9	25.7	27.5	28.0	24.1	19.0	15.3	13.7	(19)
(20)			MCWB	10.9	11.0	10.8	13.5	16.5	18.7	18.3	18.5	17.5	15.3	13.3	11.8	(20)
(21)		2%	DB	11.3	11.8	13.7	16.7	20.4	22.7	25.3	24.6	21.1	17.1	13.8	12.1	(21)
(22)			MCWB	9.6	9.6	10.1	11.8	14.6	16.6	18.1	18.1	15.9	14.3	11.9	10.6	(22)
(23)		5%	DB	10.1	10.6	12.1	15.1	18.1	20.9	23.5	22.2	19.3	15.9	12.7	10.9	(23)
(24)			MCWB	8.4	8.4	9.3	10.7	13.3	15.5	17.4	16.9	15.0	13.6	11.0	9.6	(24)
(25)		10%	DB	9.0	9.5	10.9	13.5	16.3	19.1	21.4	20.6	17.8	14.8	11.5	9.6	(25)
(26)			MCWB	7.5	7.4	8.2	10.0	12.1	14.5	16.3	16.0	14.0	12.7	10.0	8.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	11.2	11.8	14.1	17.0	19.7	19.9	19.9	18.5	16.1	13.7	12.0	(27)
(28)			MCD B	12.5	12.9	14.4	17.9	22.0	24.7	24.9	24.5	22.7	17.9	15.0	13.1	(28)
(29)		2%	WB	9.8	9.9	10.7	12.5	15.1	17.3	18.7	18.6	17.0	15.0	12.3	10.9	(29)
(30)			MCD B	11.1	11.6	13.0	15.7	19.5	21.3	23.4	22.7	20.1	16.6	13.6	12.0	(30)
(31)		5%	WB	8.6	8.7	9.6	11.3	13.8	16.1	17.8	17.7	15.7	14.0	11.2	9.7	(31)
(32)			MCD B	9.9	10.4	11.9	14.3	17.3	19.7	22.3	21.6	18.1	15.5	12.3	10.8	(32)
(33)		10%	WB	7.6	7.6	8.5	10.2	12.7	15.1	16.9	16.8	14.7	13.0	10.2	8.3	(33)
(34)			MCD B	8.8	9.2	10.7	13.0	15.7	18.4	20.7	19.8	17.0	14.5	11.3	9.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.0	6.0	7.3	8.4	8.7	8.8	9.1	8.6	8.2	6.8	5.8	5.3	(35)
(36)			MCDBR	6.2	6.7	9.2	10.7	11.7	12.0	12.6	11.2	10.6	7.6	6.5	6.1	(36)
(37)			MCWBR	5.6	5.4	6.2	6.5	6.8	6.7	6.2	5.6	6.0	5.4	5.5	5.5	(37)
(38)		5% WB	MCDBR	6.1	6.4	8.6	9.6	10.9	10.7	11.2	9.7	9.3	7.1	6.3	5.9	(38)
(39)			MCWBR	5.7	5.6	6.3	6.3	6.8	6.4	6.1	5.4	6.0	5.6	5.5	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.337	0.368	0.395	0.394	0.398	0.398	0.386	0.365	0.347	0.321	0.307	(40)	
(41)		taud	2.317	2.367	2.287	2.230	2.275	2.292	2.296	2.348	2.410	2.431	2.379	2.295	(41)	
(42)		Ebn at Noon	625	752	803	829	851	851	842	831	802	731	625	558	(42)	
(43)		Edh at Noon	58	77	102	123	124	123	121	108	90	71	54	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.62	1.27	2.35	3.70	4.71	4.81	4.65	3.84	2.79	1.56	0.77	0.48	(44)	
(45)		RadStd	0.07	0.15	0.30	0.41	0.28	0.43	0.43	0.25	0.25	0.13	0.08	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (58 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page