

LINTON ON OUSE, United Kingdom

WMO: 032660

Lat: 54.0453N

Lon: 1.2511W

Elev: 53

StdP: 14.67

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.6	27.3	20.8	15.6	30.3	23.1	17.5	31.6	32.6	47.7	29.0	47.1	3.8	310	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	78.1	64.4	74.4	62.8	71.4	61.2	66.0	74.2	64.3	71.9	62.7	69.4	9.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	85.8	69.4	61.2	80.9	67.4	59.7	76.7	65.7	30.7	74.1	29.4	71.9	28.2	69.4	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	22.0	19.4	18.9	84.2	4.8	2.7	15.5	86.2	12.7	87.8	10.0	89.3	6.5	91.3		
(5)			18.2	69.9	4.7	3.2	14.8	72.2	12.0	74.1	9.4	75.9	5.9	78.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	39.8	40.4	43.2	47.3	52.7	57.9	61.8	61.2	56.8	51.0	44.4	39.9
	DBStd	9.57	5.69	5.84	5.28	5.25	5.25	4.57	4.33	4.28	4.21	5.25	5.78	6.88
	HDD50	1505	318	272	218	112	32	1	0	0	2	51	182	317
	HDD65	5610	782	689	675	531	383	218	120	134	249	433	619	777
	CDD50	1416	1	3	7	31	115	239	366	349	205	83	13	4
	CDD65	45	0	0	0	0	0	5	21	17	2	0	0	0
	CDH74	345	0	0	0	1	9	51	158	108	16	2	0	0
	CDH80	44	0	0	0	0	0	6	17	20	1	0	0	0
(14) Wind	WSAvg	8.6	9.8	9.9	9.6	8.7	8.6	7.7	7.4	7.5	7.7	8.6	8.7	9.0
(15) Precipitation	PrecAvg	27.0	2.4	1.9	1.6	2.0	1.9	2.4	2.2	2.7	2.2	2.5	2.7	2.6
	PrecMax	37.8	5.0	3.5	3.5	5.5	3.8	6.4	5.0	6.1	4.5	5.8	5.4	5.1
	PrecMin	20.4	0.3	0.4	0.4	0.2	0.4	0.3	0.7	0.6	0.6	0.8	0.9	0.8
	PrecStd	4.3	1.1	0.9	0.9	1.4	0.8	1.5	1.0	1.3	1.2	1.1	1.1	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	57.1	60.6	69.5	74.7	80.2	82.3	83.0	76.2	67.5	60.1	57.6
		MCWB	51.7	52.2	51.0	56.3	62.2	66.0	65.2	66.0	63.6	60.9	55.6	53.7
	2%	DB	52.9	53.8	57.2	63.2	70.2	74.1	78.5	76.6	70.6	63.6	57.3	54.8
		MCWB	49.4	49.4	50.5	53.3	58.8	62.2	64.8	64.3	60.9	57.8	53.3	51.4
	5%	DB	50.4	51.5	54.5	59.7	65.9	70.5	74.8	72.6	67.4	61.1	55.1	52.3
		MCWB	47.0	47.3	48.9	51.5	56.5	60.0	63.0	62.5	59.0	56.4	51.7	49.3
	10%	DB	48.5	49.5	52.2	56.9	62.4	67.3	71.3	69.6	64.7	59.1	52.9	49.8
		MCWB	45.5	45.7	47.1	50.0	54.2	58.4	61.5	60.5	57.4	54.8	49.9	47.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	52.4	53.6	57.7	63.7	68.4	68.3	67.8	65.4	61.7	56.4	54.0
		MCDB	55.2	55.9	57.8	65.2	73.0	76.0	78.3	77.1	73.7	66.0	59.2	56.4
	2%	WB	49.8	50.1	51.5	54.9	59.9	63.7	66.1	65.5	62.6	59.2	54.1	51.8
		MCDB	52.6	53.4	56.0	61.6	67.7	70.5	74.6	73.4	68.3	62.6	56.7	54.3
	5%	WB	47.6	48.0	49.5	52.6	57.5	61.4	64.2	63.9	60.4	57.2	52.1	49.6
		MCDB	50.1	51.1	53.7	58.4	64.3	68.3	72.4	70.9	65.0	60.3	54.5	51.9
	10%	WB	45.7	46.0	47.6	50.5	55.3	59.4	62.5	62.2	58.7	55.4	50.2	47.4
		MCDB	48.1	49.0	51.7	56.0	61.3	65.8	69.8	67.9	63.2	58.4	52.5	49.7
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	11.0	13.0	15.3	15.7	15.4	16.0	15.3	14.5	12.4	10.4	9.6
		MCDBR	11.0	12.2	16.4	20.0	21.5	21.8	22.4	20.0	18.9	13.8	11.3	10.7
	5% WB	MCWBR	9.9	9.8	10.9	11.6	12.0	11.8	10.6	9.6	10.5	9.4	9.5	9.6
		MCWBR	11.1	11.7	14.8	18.3	20.2	19.2	20.1	17.6	15.9	12.8	10.8	10.5
(40) Clear-Sky Solar Irradiance	taub		0.320	0.337	0.368	0.395	0.394	0.399	0.399	0.387	0.366	0.348	0.322	0.307
		taud	2.331	2.378	2.296	2.233	2.276	2.289	2.293	2.347	2.411	2.437	2.390	2.307
	Ebn at Noon		200	239	255	263	270	270	267	263	254	232	199	179
		Edh at Noon	18	24	32	39	39	39	38	34	29	23	17	16
(44) All-Sky Solar Radiation	RadAvg		199	405	748	1175	1492	1526	1478	1220	888	498	246	155
	RadStd		23	47	95	133	89	137	140	80	81	43	25	16

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (60 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page