

BRIDLINGTON MRSC, United Kingdom

WMO: 032920

Lat: 54.0939N

Lon: 0.1758W

Elev: 15

StdP: 101.14

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.5	-0.5	-5.1	2.5	0.9	-3.8	2.7	1.4	17.7	5.6	15.6	5.0	3.9	300	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	22.4	16.8	21.0	16.1	19.8	15.7	18.0	20.8	17.2	19.5	16.6	18.7	5.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	12.1	19.0	16.2	11.6	18.3	15.6	11.1	17.6	50.9	21.1	48.5	19.7	46.5	18.7	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.3	12.4	10.7	DB	-4.1	26.2	2.3	1.7	-5.7	27.4	-7.0	28.4	-8.3	29.4	-10.0	30.6	(4)
			WB	-4.6	20.6	2.2	2.1	-6.2	22.1	-7.5	23.3	-8.7	24.5	-10.2	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	4.8	5.2	6.4	8.2	10.9	13.6	15.8	16.0	14.0	11.2	7.6	5.2
	DBStd	4.71	2.40	2.66	2.59	2.41	2.35	2.25	2.04	1.95	2.04	2.46	2.65	2.92
	HDD10.0	741	161	137	116	63	17	1	0	0	1	16	79	151
	HDD18.3	3075	419	369	371	303	232	144	82	77	129	221	322	407
	CDD10.0	714	0	1	3	10	44	107	181	185	121	53	7	2
	CDD18.3	9	0	0	0	0	0	1	4	4	1	0	0	0
	CDH23.3	23	0	0	0	0	0	4	11	6	2	0	0	0
	CDH26.7	2	0	0	0	0	0	1	1	1	0	0	0	0
Wind	WSAvg	5.0	5.9	5.8	5.4	4.9	4.8	4.3	4.0	4.1	4.7	5.5	5.5	5.5
Precipitation	PrecAvg	658	58	47	40	50	51	59	51	64	47	58	71	62
	PrecMax	837	109	77	103	141	100	187	96	125	93	109	138	109
	PrecMin	457	9	4	3	3	13	5	9	5	12	13	17	22
	PrecStd	102	29	18	26	41	22	44	23	31	27	25	29	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	14.0	15.6	18.0	20.1	23.2	24.7	24.0	22.6	19.5	15.3	13.4
		MCWB	10.7	11.3	11.5	12.6	15.9	16.8	18.0	18.2	17.3	15.6	13.2	11.6
	2%	DB	11.1	11.8	13.4	15.4	17.8	20.5	22.2	22.3	20.3	17.1	13.6	11.9
		MCWB	9.3	9.6	10.1	11.3	13.3	15.4	16.8	16.7	15.9	14.1	11.9	10.4
	5%	DB	9.7	10.5	11.9	13.6	16.1	18.9	20.7	20.7	18.7	15.7	12.3	10.6
		MCWB	8.0	8.3	9.0	10.2	12.3	14.5	16.2	16.1	15.1	13.2	11.0	9.3
	10%	DB	8.5	9.2	10.5	12.1	14.7	17.4	19.5	19.5	17.5	14.7	11.4	9.4
		MCWB	7.1	7.2	8.0	9.3	11.6	13.9	15.8	15.8	14.6	12.8	10.1	8.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	11.4	12.1	13.9	16.3	18.0	19.0	19.2	18.2	16.2	13.8	11.9
		MCDB	12.3	13.5	14.6	16.6	19.3	21.5	23.2	22.0	20.9	19.0	14.9	13.0
	2%	WB	9.6	10.0	10.7	11.9	14.2	16.4	17.9	18.1	16.8	14.7	12.3	10.7
		MCDB	10.9	11.6	13.0	14.6	16.8	19.4	20.7	20.6	19.1	16.1	13.3	11.8
	5%	WB	8.3	8.6	9.3	10.5	13.0	15.3	17.1	17.3	16.0	14.0	11.2	9.5
		MCDB	9.4	10.1	11.3	13.0	15.4	17.8	19.4	19.3	17.6	15.0	12.1	10.4
	10%	WB	7.3	7.5	8.2	9.6	12.0	14.5	16.3	16.6	15.2	13.2	10.4	8.4
		MCDB	8.3	8.9	10.0	11.6	14.1	16.7	18.6	18.4	16.8	14.4	11.2	9.3
Mean Daily Temperature Range	5% DB	MDBR	4.4	5.1	5.8	6.1	6.3	6.3	6.5	6.5	6.3	5.5	4.9	4.5
		MCDBR	6.0	6.5	8.0	8.6	8.5	8.8	8.6	8.4	8.1	6.6	5.4	5.6
		MCWBR	5.5	5.0	5.4	5.4	5.1	5.1	4.6	4.4	4.9	4.6	4.5	5.0
	5% WB	MCDBR	5.8	6.3	7.6	7.8	7.6	7.7	7.3	6.6	7.0	5.8	5.0	5.4
		MCWBR	5.5	5.2	5.6	5.3	5.3	5.2	4.6	4.2	4.8	4.5	4.5	5.1
Clear-Sky Solar Irradiance	taub	0.324	0.342	0.372	0.397	0.394	0.401	0.403	0.393	0.373	0.353	0.326	0.311	
	taud	2.336	2.385	2.309	2.262	2.330	2.331	2.335	2.381	2.434	2.451	2.391	2.313	
	Ebn at Noon	625	748	800	828	853	848	838	826	795	727	621	557	
	Edh at Noon	58	76	100	119	117	119	116	105	88	70	54	48	
All-Sky Solar Radiation	RadAvg	0.62	1.28	2.43	3.85	4.91	5.03	4.86	4.04	2.90	1.61	0.77	0.48	
	RadStd	0.07	0.16	0.28	0.39	0.32	0.41	0.44	0.27	0.26	0.12	0.07	0.05	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+43	N/A
	Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page