

CAPEL CURIG, United Kingdom

WMO: 033050

Lat: 53.0942N

Lon: 3.9414W

Elev: 709

StdP: 14.32

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 23.5	(c) 27.0	(d) 20.9	(e) 16.1	(f) 28.8	(g) 23.5	(h) 18.2	(i) 31.0	(j) 50.9	(k) 47.2	(l) 46.6	(m) 46.7	(n) 2.6	(o) 50	(p) 0.784

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.3	(c) 73.9	(d) 63.4	(e) 70.0	(f) 61.3	(g) 66.9	(h) 59.6	(i) 64.8	(j) 71.5	(k) 62.8	(l) 67.5	(m) 61.1	(n) 64.8	(o) 10.0	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	86.1	66.6	60.8	81.8	64.6	59.5	77.8	63.0	30.1	72.1	28.7	67.8	27.5	64.7	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 44.4	(b) 38.9	(c) 33.7	(e) 18.2	(f) 79.4	(g) 4.6	(h) 3.8	(i) 14.9	(j) 82.1	(k) 12.3	(l) 84.3	(m) 9.7	(n) 86.4	(o) 6.4	(p) 89.2		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			18.9	68.4	5.1	2.3	15.3	70.1	12.3	71.4	9.4	72.7	5.7	74.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	39.9	40.0	41.8	45.6	50.5	55.1	58.2	58.0	54.7	50.1	45.0	41.2
	DBStd	8.30	5.94	5.16	4.94	4.78	4.95	4.17	3.84	3.74	3.82	4.88	5.45	6.35
	HDD50	1556	314	280	257	146	53	5	0	0	6	59	161	275
	HDD65	6074	778	700	720	582	451	300	214	220	309	463	599	738
	CDD50	967	0	1	2	13	67	157	255	249	147	62	12	2
	CDD65	10	0	0	0	0	0	2	4	4	0	0	0	0
	CDH74	98	0	0	0	0	3	19	49	26	1	0	0	0
	CDH80	7	0	0	0	0	0	1	5	1	0	0	0	0
Wind	WSAvg	14.5	16.9	17.2	15.1	12.6	13.4	12.8	12.5	12.4	12.7	15.1	15.7	17.3
Precipitation	PrecAvg	54.4	6.1	4.6	3.7	3.3	3.3	3.2	3.5	4.0	4.2	5.7	6.2	6.7
	PrecMax	70.3	11.2	10.9	8.3	5.7	6.6	8.5	7.5	7.8	8.0	12.4	14.4	20.3
	PrecMin	38.2	0.1	0.0	1.0	0.9	0.8	1.0	0.9	0.3	0.2	1.2	3.0	1.1
	PrecStd	8.3	2.9	2.8	1.9	1.5	1.7	1.8	1.7	1.5	1.9	2.8	3.0	4.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	54.6	58.4	67.9	72.6	76.7	79.2	77.9	71.5	64.0	58.2	54.6
		MCWB	49.5	46.9	49.5	55.5	60.8	62.9	66.0	66.2	63.4	57.9	54.6	51.8
	2%	DB	50.3	50.5	53.9	60.9	68.0	70.8	74.2	71.3	66.7	60.9	55.6	52.8
		MCWB	48.4	47.9	48.9	51.7	57.6	61.4	63.8	63.0	59.7	56.9	53.6	50.9
	5%	DB	49.0	48.9	50.9	56.2	63.3	66.6	69.8	67.4	63.5	59.0	54.0	51.2
		MCWB	47.2	46.7	47.4	49.5	55.5	58.7	61.7	61.4	58.4	56.1	52.0	49.5
	10%	DB	47.6	47.4	48.8	53.1	59.6	63.2	65.8	64.2	61.3	57.3	52.4	49.4
		MCWB	45.9	45.3	46.1	48.2	53.2	56.7	59.8	59.8	57.5	54.8	50.3	47.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.6	50.4	51.9	55.8	62.6	66.1	67.3	67.4	64.2	59.8	55.8	52.9
		MCDB	51.3	52.0	55.1	65.2	70.8	73.6	76.0	74.6	69.6	62.1	57.0	53.7
	2%	WB	49.0	48.6	49.5	52.9	59.1	61.9	64.8	64.5	61.4	58.2	54.2	51.5
		MCDB	49.9	49.9	52.3	58.8	66.0	69.0	72.5	69.7	64.1	60.0	55.4	52.5
	5%	WB	47.6	47.1	48.0	50.7	56.5	59.4	62.6	62.5	59.8	56.6	52.4	49.8
		MCDB	48.7	48.4	50.2	54.7	61.9	64.7	67.5	65.8	62.2	58.4	53.8	50.9
	10%	WB	46.4	45.6	46.6	49.0	54.2	57.7	60.8	60.9	58.3	55.0	50.6	48.1
		MCDB	47.6	47.2	48.7	52.4	58.3	61.8	64.6	63.3	60.8	56.9	52.2	49.4
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.6	10.1	11.9	12.7	12.0	11.3	11.0	11.3	9.4	8.1	8.0
		MCDBR	7.8	10.8	14.2	19.3	20.9	20.8	20.9	17.5	16.7	11.2	8.6	8.7
		MCWBR	8.1	9.3	10.2	12.0	12.5	12.7	11.9	10.6	11.0	8.8	8.4	9.1
	5% WB	MCDBR	7.8	9.3	12.0	15.6	18.3	17.6	17.5	13.6	12.4	9.6	8.3	8.6
		MCWBR	8.4	8.7	9.4	10.3	11.5	11.4	10.7	9.2	9.7	8.5	8.6	9.3
Clear-Sky Solar Irradiance	taub	0.325	0.337	0.364	0.384	0.389	0.381	0.382	0.367	0.359	0.345	0.322	0.314	
	taud	2.306	2.370	2.315	2.288	2.323	2.371	2.372	2.428	2.447	2.438	2.372	2.278	
	Ebn at Noon	203	243	259	268	273	276	273	272	259	237	205	182	
	Edh at Noon	20	25	32	37	38	36	36	32	28	23	18	17	
All-Sky Solar Radiation	RadAvg	211	430	806	1258	1590	1686	1562	1293	935	520	257	158	
	RadStd	20	43	68	107	108	154	148	88	65	46	26	16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page