

CAPEL CURIG, United Kingdom

WMO: 033050

Lat: 53.0942N

Lon: 3.9414W

Elev: 216

StdP: 98.76

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.7	-2.8	-6.2	2.3	-1.8	-4.7	2.6	-0.6	22.8	8.4	20.9	8.2	1.2	50	0.784

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	23.3	17.4	21.1	16.3	19.4	15.3	18.2	21.9	17.1	19.7	16.2	18.2	4.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.3	19.2	16.0	11.7	18.1	15.3	11.1	17.2	52.1	22.3	48.8	19.9	46.1	18.1	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	17.4	15.1	DB	-7.6	26.3	2.5	2.1	-9.5	27.8	-11.0	29.1	-12.4	30.2	-14.2	31.8	(4)
(5)			WB	-7.3	20.2	2.8	1.3	-9.3	21.2	-11.0	21.9	-12.6	22.6	-14.6	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	4.4	4.5	5.4	7.6	10.3	12.8	14.6	14.5	12.6	10.0	7.2	5.1	
	DBStd	4.61	3.30	2.87	2.74	2.66	2.75	2.31	2.13	2.08	2.12	2.71	3.03	3.53	
	HDD10.0	864	174	156	143	81	29	3	0	0	3	33	89	153	
	HDD18.3	3374	432	389	400	323	251	167	119	122	172	257	333	410	
	CDD10.0	537	0	1	1	7	37	87	142	138	82	34	7	1	
	CDD18.3	6	0	0	0	0	0	1	2	2	0	0	0	0	
	CDH23.3	54	0	0	0	0	2	11	27	14	1	0	0	0	
	CDH26.7	4	0	0	0	0	0	1	3	1	0	0	0	0	
Wind	WSAvg	6.5	7.5	7.7	6.7	5.6	6.0	5.7	5.6	5.6	5.7	6.7	7.0	7.7	
Precipitation	PrecAvg	1383	155	116	94	84	83	82	88	101	107	146	157	171	
	PrecMax	1785	285	277	212	146	167	217	191	198	202	315	367	516	
	PrecMin	971	2	1	26	22	21	26	24	7	6	30	76	29	
	PrecStd	210	74	72	49	37	42	45	42	39	47	70	76	102	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	12.6	14.7	20.0	22.6	24.8	26.2	25.5	22.0	17.8	14.6	12.6	
		MCWB	9.7	8.3	9.7	13.0	16.0	17.2	18.9	19.0	17.4	14.4	12.5	11.0	
	2%	DB	10.2	10.3	12.2	16.0	20.0	21.6	23.4	21.8	19.3	16.0	13.1	11.5	
		MCWB	9.1	8.8	9.4	11.0	14.2	16.4	17.7	17.2	15.4	13.9	12.0	10.5	
	5%	DB	9.4	9.4	10.5	13.4	17.4	19.2	21.0	19.6	17.5	15.0	12.2	10.7	
		MCWB	8.5	8.2	8.6	9.7	13.0	14.8	16.5	16.3	14.7	13.4	11.1	9.7	
	10%	DB	8.7	8.5	9.3	11.7	15.3	17.3	18.8	17.9	16.3	14.0	11.3	9.7	
		MCWB	7.7	7.4	7.8	9.0	11.8	13.7	15.4	15.4	14.1	12.6	10.1	8.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	10.2	11.1	13.2	17.0	19.0	19.6	19.7	17.9	15.5	13.2	11.6
			MCDB	10.7	11.1	12.9	18.5	21.6	23.1	24.5	23.6	20.9	16.7	13.9	12.0
2%		WB	9.5	9.2	9.7	11.6	15.0	16.6	18.2	18.1	16.4	14.6	12.3	10.9	
		MCDB	10.0	10.0	11.3	14.9	18.9	20.6	22.5	21.0	17.8	15.5	13.0	11.4	
5%		WB	8.7	8.4	8.9	10.4	13.6	15.2	17.0	17.0	15.5	13.7	11.4	9.9	
		MCDB	9.3	9.1	10.1	12.6	16.6	18.1	19.7	18.8	16.8	14.6	12.1	10.5	
10%		WB	8.0	7.5	8.1	9.5	12.4	14.3	16.0	16.0	14.6	12.8	10.4	8.9	
		MCDB	8.7	8.5	9.3	11.3	14.6	16.6	18.1	17.4	16.0	13.9	11.2	9.7	
Mean Daily Temperature Range		5% DB	MDBR	4.4	4.8	5.6	6.6	7.1	6.7	6.3	6.1	6.3	5.2	4.5	4.5
			MCDBR	4.4	6.0	7.9	10.7	11.6	11.6	9.7	9.3	6.2	4.8	4.8	
	MCWBR		4.5	5.1	5.7	6.7	6.9	7.0	6.6	5.9	6.1	4.9	4.7	5.1	
	5% WB	MCDBR	4.3	5.2	6.7	8.7	10.2	9.8	9.7	7.5	6.9	5.3	4.6	4.8	
		MCWBR	4.7	4.9	5.2	5.7	6.4	6.3	5.9	5.1	5.4	4.7	4.8	5.2	
Clear-Sky Solar Irradiance	taub	0.325	0.337	0.364	0.384	0.389	0.381	0.382	0.367	0.359	0.345	0.322	0.314		
	taud	2.306	2.370	2.315	2.288	2.323	2.371	2.372	2.428	2.447	2.438	2.372	2.278		
	Ebn at Noon	641	765	816	846	860	870	861	856	818	747	645	574		
	Edh at Noon	62	78	101	117	119	115	113	101	88	72	57	53		
All-Sky Solar Radiation	RadAvg	0.66	1.36	2.54	3.97	5.01	5.32	4.92	4.08	2.95	1.64	0.81	0.50		
	RadStd	0.06	0.13	0.21	0.34	0.34	0.34	0.48	0.47	0.28	0.20	0.14	0.08	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page