

CONINGSBY, United Kingdom

WMO: 033910

Lat: 53.0939N

Lon: 0.1728W

Elev: 25

StdP: 14.68

Time Zone: 0.00 (EUW)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.2	28.7	21.6	16.3	31.8	23.9	18.1	32.3	32.0	48.7	28.9	48.5	5.4	320	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	79.4	65.3	75.8	63.8	72.9	62.2	66.9	75.8	65.3	73.1	63.7	70.9	10.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	88.5	70.3	62.1	83.6	68.7	60.7	79.5	66.9	31.4	75.6	30.1	73.2	29.0	71.1	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.2	23.1	20.7	DB	20.6	86.3	4.6	3.0	17.3	88.5	14.6	90.3	12.0	92.0	8.7	94.2	(4)
(5)			WB	20.0	71.0	4.6	2.2	16.7	72.6	14.0	73.9	11.4	75.1	8.1	76.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.4	39.7	40.7	43.6	48.0	53.4	58.5	62.7	62.6	58.0	52.0	44.5	40.2	(6)	
	DBStd	9.81	5.39	5.53	5.27	5.11	5.19	4.67	4.52	4.39	4.28	5.13	5.45	6.22	(7)	
	HDD50	1436	321	263	208	96	25	1	0	0	1	36	177	308	(8)	
	HDD65	5404	785	680	664	510	360	201	101	101	214	404	614	770	(9)	
	CDD50	1578	1	3	9	36	130	257	395	392	241	99	12	3	(10)	
	CDD65	70	0	0	0	0	0	7	30	28	4	1	0	0	(11)	
	CDH74	507	0	0	0	1	8	71	213	180	29	5	0	0	(12)	
	CDH80	82	0	0	0	0	0	13	31	35	2	1	0	0	(13)	
(14) Wind	WSAvg	9.9	11.0	11.3	10.9	10.2	10.0	9.0	8.6	8.7	9.0	9.8	9.9	10.3	(14)	
(15) Precipitation	PrecAvg	25.4	2.2	1.7	1.5	1.9	2.0	2.3	2.3	2.4	2.0	2.5	2.5	2.2	(15)	
	PrecMax	33.6	4.0	2.8	2.9	5.5	4.7	6.8	5.5	4.5	4.4	4.4	4.5	4.3	(16)	
	PrecMin	17.6	0.6	0.4	0.2	0.2	0.7	0.5	0.6	0.4	0.4	0.9	0.9	0.9	(17)	
	PrecStd	4.3	0.9	0.6	0.7	1.3	1.0	1.5	1.3	1.1	1.1	0.9	0.9	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.6	57.5	61.6	69.8	74.8	81.7	83.6	84.5	78.0	69.5	60.3	56.4	(19)	
		MCWB	52.1	52.3	52.5	56.8	62.2	67.1	67.4	67.0	64.0	61.8	56.3	52.9	(20)	
	2%	DB	52.6	54.0	58.0	64.2	70.3	75.1	79.2	79.0	72.8	64.7	57.3	54.1	(21)	
		MCWB	49.5	50.0	50.8	53.9	59.7	63.6	65.1	65.5	62.5	58.7	54.1	51.4	(22)	
	5%	DB	50.4	51.7	55.2	60.6	66.8	71.2	75.9	74.7	69.1	62.2	55.0	51.9	(23)	
		MCWB	47.7	47.9	49.4	52.1	57.3	61.2	63.8	63.2	60.2	57.4	52.2	49.5	(24)	
	10%	DB	48.2	49.5	52.7	57.6	63.5	68.1	72.7	71.7	66.2	60.0	52.9	49.6	(25)	
		MCWB	45.7	46.3	47.6	50.4	55.2	59.4	62.2	61.4	58.4	55.8	50.3	47.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.6	53.3	54.5	58.4	64.2	68.8	69.6	69.4	66.0	62.7	57.4	53.6	(27)	
		MCDB	55.3	56.7	59.1	67.6	73.3	79.2	81.1	79.3	73.9	67.8	59.6	55.4	(28)	
	2%	WB	50.1	50.4	52.2	55.4	60.7	65.1	66.7	66.6	63.7	60.3	54.7	51.9	(29)	
		MCDB	52.1	53.6	56.5	62.3	68.4	72.7	75.7	75.0	70.7	63.9	56.8	53.9	(30)	
	5%	WB	48.0	48.5	50.1	53.2	58.4	62.7	65.1	65.0	61.8	58.4	52.6	49.7	(31)	
		MCDB	50.0	51.2	54.3	59.1	65.2	69.4	73.0	72.6	67.2	61.3	54.6	51.7	(32)	
	10%	WB	45.9	46.7	48.2	51.1	56.4	60.6	63.5	63.4	60.1	56.6	50.7	47.6	(33)	
		MCDB	47.8	49.2	52.1	56.7	62.3	66.4	70.9	69.9	64.6	59.4	52.5	49.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	11.1	13.3	15.3	15.7	15.5	16.4	16.4	15.3	12.8	10.8	9.3	(35)	
		MCDBR	12.0	12.8	16.9	20.3	20.9	21.0	21.7	21.0	19.6	14.5	11.9	11.0	(36)	
	5% WB	MCWBR	10.7	9.9	11.0	11.7	11.9	11.3	10.1	9.5	10.5	9.7	9.9	9.8	(37)	
		MCWBR	11.8	12.6	15.6	18.8	19.2	19.2	19.7	18.7	17.5	14.0	11.3	11.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.326	0.342	0.375	0.401	0.402	0.408	0.409	0.397	0.375	0.355	0.329	0.315	(40)	
		taud	2.354	2.382	2.288	2.226	2.272	2.278	2.285	2.343	2.404	2.438	2.404	2.333	(41)	
	Ebn at Noon		205	241	255	262	269	268	265	262	253	233	203	185	(42)	
		Edh at Noon	19	25	33	39	40	40	39	35	29	23	18	16	(43)	
(44) All-Sky Solar Radiation	RadAvg		220	437	790	1229	1531	1602	1549	1289	951	544	272	176	(44)	
	RadStd		21	56	88	136	106	140	156	87	83	45	29	19	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (77 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page