

CONINGSBY, United Kingdom

WMO: 033910

Lat: 53.0939N

Lon: 0.1728W

Elev: 8

StdP: 101.23

Time Zone: 0.00 (EUW)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.2	-1.8	-5.8	2.3	-0.1	-4.5	2.6	0.1	14.3	9.3	12.9	9.2	2.4	320	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	26.4	18.5	24.3	17.7	22.7	16.8	19.4	24.3	18.5	22.8	17.6	21.6	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.6	21.3	16.7	11.9	20.4	16.0	11.4	19.4	55.1	24.2	52.2	22.9	49.6	21.7	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.3	9.2	DB	-6.3	30.2	2.6	1.7	-8.2	31.4	-9.7	32.4	-11.1	33.3	-13.0	34.6	(4)
(5)			WB	-6.7	21.7	2.5	1.2	-8.5	22.5	-10.0	23.3	-11.4	23.9	-13.3	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	4.3	4.8	6.4	8.9	11.9	14.7	17.1	17.0	14.4	11.1	7.0	4.5	(6)	
	DBStd	5.45	2.99	3.07	2.93	2.84	2.88	2.60	2.51	2.44	2.38	2.85	3.03	3.46	(7)	
	HDD10.0	798	178	146	116	53	14	1	0	0	1	20	98	171	(8)	
	HDD18.3	3002	436	378	369	283	200	112	56	56	119	224	341	428	(9)	
	CDD10.0	877	1	2	5	20	72	143	219	218	134	55	7	2	(10)	
	CDD18.3	39	0	0	0	0	0	4	17	16	2	1	0	0	(11)	
	CDH23.3	282	0	0	0	1	4	39	118	100	16	3	0	0	(12)	
	CDH26.7	46	0	0	0	0	0	7	17	19	1	1	0	0	(13)	
(14) Wind	WSAvg	4.4	4.9	5.1	4.9	4.6	4.5	4.0	3.9	3.9	4.0	4.4	4.4	4.6	(14)	
(15) Precipitation	PrecAvg	644	55	42	38	47	51	58	59	61	52	63	63	55	(15)	
	PrecMax	853	101	70	73	139	119	173	140	115	111	111	115	110	(16)	
	PrecMin	446	16	11	5	6	17	12	16	9	11	22	23	22	(17)	
	PrecStd	108	24	16	18	34	25	39	33	28	29	23	23	22	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	14.1	16.5	21.0	23.8	27.6	28.7	29.2	25.6	20.8	15.7	13.5	(19)	
		MCWB	11.2	11.3	11.4	13.8	16.8	19.5	19.7	19.4	17.8	16.6	13.5	11.6	(20)	
	2%	DB	11.5	12.2	14.4	17.9	21.3	23.9	26.2	26.1	22.7	18.2	14.1	12.3	(21)	
		MCWB	9.7	10.0	10.4	12.2	15.4	17.5	18.4	18.6	16.9	14.9	12.3	10.8	(22)	
	5%	DB	10.2	10.9	12.9	15.9	19.3	21.8	24.4	23.7	20.6	16.8	12.8	11.1	(23)	
		MCWB	8.7	8.8	9.7	11.2	14.1	16.2	17.7	17.3	15.6	14.1	11.2	9.7	(24)	
	10%	DB	9.0	9.7	11.5	14.2	17.5	20.0	22.6	22.0	19.0	15.6	11.6	9.8	(25)	
		MCWB	7.6	7.9	8.7	10.2	12.9	15.2	16.8	16.4	14.7	13.2	10.2	8.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.8	12.5	14.7	17.9	20.5	20.9	20.8	18.9	17.0	14.1	12.0	(27)	
		MCDB	12.9	13.7	15.1	19.8	22.9	26.2	27.3	26.3	23.3	19.9	15.3	13.0	(28)	
	2%	WB	10.0	10.2	11.2	13.0	15.9	18.4	19.3	19.2	17.6	15.7	12.6	11.0	(29)	
		MCDB	11.2	12.0	13.6	16.9	20.2	22.6	24.3	23.9	21.5	17.7	13.8	12.2	(30)	
	5%	WB	8.9	9.2	10.1	11.8	14.7	17.1	18.4	18.4	16.6	14.7	11.4	9.9	(31)	
		MCDB	10.0	10.7	12.4	15.1	18.4	20.8	22.8	22.5	19.6	16.3	12.5	11.0	(32)	
	10%	WB	7.7	8.1	9.0	10.6	13.5	15.9	17.5	17.4	15.6	13.7	10.4	8.7	(33)	
		MCDB	8.8	9.6	11.2	13.7	16.8	19.1	21.6	21.0	18.1	15.2	11.4	9.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.2	7.4	8.5	8.7	8.6	9.1	9.1	8.5	7.1	6.0	5.2	(35)	
		MCDBR	6.7	7.1	9.4	11.3	11.6	11.7	12.1	11.6	10.9	8.1	6.6	6.1	(36)	
	5% WB	MCWBR	6.0	5.5	6.1	6.5	6.6	6.3	5.6	5.3	5.8	5.4	5.5	5.5	(37)	
		MCWBR	6.6	7.0	8.7	10.5	10.7	10.7	11.0	10.4	9.7	7.8	6.3	6.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.326	0.342	0.375	0.401	0.402	0.408	0.409	0.397	0.375	0.355	0.329	0.315	(40)	
		taud	2.354	2.382	2.288	2.226	2.272	2.278	2.285	2.343	2.404	2.438	2.404	2.333	(41)	
	Ebn at Noon		647	759	803	827	847	844	835	825	799	734	641	583	(42)	
		Edh at Noon	60	78	104	124	125	126	123	110	92	73	56	51	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.69	1.38	2.49	3.87	4.83	5.05	4.88	4.06	3.00	1.71	0.86	0.55	(44)	
	RadStd		0.07	0.17	0.28	0.43	0.33	0.44	0.49	0.28	0.26	0.14	0.09	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (77 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page