

WITTERING, United Kingdom

WMO: 034620

Lat: 52.6114N

Lon: 0.4611W

Elev: 273

StdP: 14.55

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.7	28.2	21.1	16.0	30.2	23.4	17.9	31.8	34.1	48.5	31.0	48.5	7.3	270	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	80.1	64.5	76.1	63.1	72.9	61.8	66.6	75.7	64.8	72.9	63.2	70.5	10.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.3	87.9	69.4	61.7	83.0	67.7	60.2	78.7	66.2	31.3	76.2	29.9	73.0	28.8	70.8	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.7	24.7	22.0	DB	20.7	87.1	4.2	3.3	17.7	89.5	15.2	91.4	12.9	93.3	9.8	95.6	(4)
(5)			WB	20.0	70.5	4.1	3.3	17.1	72.9	14.7	74.8	12.4	76.6	9.4	79.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.2	39.7	40.3	43.4	47.7	52.9	58.3	62.6	62.3	57.7	51.7	44.7	40.4
	DBStd	9.79	5.68	5.86	5.36	5.32	5.22	4.76	4.68	4.51	4.26	5.09	5.45	6.48
	HDD50	1450	319	273	211	104	29	1	0	0	1	39	172	301
	HDD65	5464	783	690	668	519	376	208	104	110	223	413	609	761
	CDD50	1532	1	3	8	36	118	250	392	382	232	92	13	5
	CDD65	70	0	0	0	0	0	7	31	27	4	1	0	0
	CDH74	577	0	0	0	2	8	78	260	198	27	4	0	0
	CDH80	112	0	0	0	0	0	13	53	43	3	0	0	0
Wind	WSAvg	10.9	12.5	12.4	11.9	10.8	10.5	9.8	9.6	9.6	10.0	10.8	11.0	11.9
Precipitation	PrecAvg	22.8	1.8	1.4	1.9	1.9	2.1	2.0	1.9	2.2	1.7	1.8	2.1	2.0
	PrecMax	29.4	3.4	4.6	3.8	3.3	5.2	6.1	5.0	4.5	4.2	5.1	5.1	5.1
	PrecMin	16.8	0.6	0.5	0.4	0.4	0.6	0.1	0.2	0.1	0.3	0.2	0.8	0.3
	PrecStd	2.9	0.8	0.9	1.0	0.8	1.3	1.4	1.2	1.1	1.1	1.3	0.9	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	57.2	61.6	70.2	74.8	82.0	85.8	84.9	78.0	68.8	59.9	56.8
		MCWB	52.0	52.5	51.8	58.1	62.4	66.5	66.6	65.5	62.9	60.8	56.5	53.5
	2%	DB	52.8	53.7	57.5	63.9	70.5	75.5	80.3	79.5	72.3	64.2	57.3	54.6
		MCWB	50.0	49.6	50.6	53.7	59.7	62.3	64.3	65.0	61.6	58.2	54.4	52.1
	5%	DB	50.6	51.3	54.8	60.4	66.6	71.5	76.5	74.7	68.5	61.6	55.1	52.5
		MCWB	47.9	47.6	49.1	51.8	57.2	60.9	63.3	63.0	59.7	57.1	52.3	50.2
	10%	DB	48.4	49.3	52.5	57.2	62.9	68.0	72.8	71.4	65.8	59.4	53.0	50.2
		MCWB	46.1	46.2	47.6	50.2	54.9	58.8	61.9	61.4	58.1	55.6	50.5	48.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.7	52.9	54.1	58.8	64.4	68.5	69.1	68.5	65.7	61.9	57.2	54.0
		MCDB	54.8	56.1	58.4	68.4	72.4	79.0	81.1	79.4	73.1	67.0	59.0	55.6
	2%	WB	50.3	50.2	51.9	55.4	60.6	64.4	66.5	66.2	63.2	59.9	54.9	52.6
		MCDB	52.5	53.1	56.1	62.5	68.6	71.6	76.1	75.0	69.3	63.3	56.8	54.3
	5%	WB	48.3	48.2	50.0	53.0	58.3	62.1	64.7	64.5	61.3	58.0	52.8	50.4
		MCDB	50.2	50.9	54.0	58.5	64.7	69.0	73.2	72.3	66.3	60.8	54.7	52.3
	10%	WB	46.3	46.5	48.1	50.9	56.1	60.2	63.0	62.9	59.7	56.2	50.9	48.2
		MCDB	48.2	48.9	51.8	56.2	61.7	66.7	70.8	69.5	64.1	59.0	52.7	50.1
Mean Daily Temperature Range	5% DB	MDBR	9.0	10.6	12.7	14.9	15.4	15.6	16.6	16.0	14.5	12.1	10.0	8.8
		MCDBR	11.6	12.1	16.2	19.6	21.4	21.6	23.0	21.2	18.7	13.6	10.9	10.5
		MCWBR	10.5	9.5	10.6	11.3	12.2	11.0	9.8	9.2	9.6	9.0	9.4	9.7
	5% WB	MCDBR	11.5	11.7	14.6	17.9	19.4	19.0	19.9	18.8	16.2	12.7	10.7	10.2
		MCWBR	10.7	9.7	10.5	11.1	11.9	11.1	9.8	9.1	9.9	9.5	9.6	9.6
Clear-Sky Solar Irradiance	taub	0.322	0.338	0.370	0.396	0.400	0.403	0.402	0.390	0.370	0.351	0.325	0.311	
	taud	2.365	2.388	2.291	2.229	2.259	2.273	2.283	2.341	2.402	2.438	2.415	2.344	
	Ebn at Noon	211	245	257	265	270	270	267	264	256	236	208	191	
	Edh at Noon	19	25	33	40	40	40	39	35	30	23	18	16	
All-Sky Solar Radiation	RadAvg	236	457	796	1223	1512	1610	1551	1281	958	556	292	193	
	RadStd	21	55	95	134	98	156	167	90	86	48	32	20	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (91 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page