

WEYBOURNE, United Kingdom

WMO: 034880

Lat: 52.9494N

Lon: 1.1225E

Elev: 66

StdP: 14.66

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	31.3	23.4	17.7	33.9	25.6	19.7	34.7	38.8	44.1	35.2	42.4	11.7	210	0.730

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.2	76.2	64.6	72.9	63.4	70.3	62.3	66.9	73.0	65.2	70.4	63.7	68.5	13.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	91.5	69.5	63.0	86.3	67.8	61.7	82.3	66.3	31.5	73.5	30.1	70.4	29.1	68.7	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.4	29.2	26.3	DB	24.3	85.4	3.9	2.2	21.4	87.0	19.1	88.3	16.9	89.6	14.1	91.2	(4)
(5)			WB	23.9	72.5	3.7	4.4	21.2	75.7	19.0	78.2	16.9	80.7	14.2	83.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.9	40.9	41.3	43.8	48.0	52.8	57.9	62.0	62.6	58.5	53.6	46.6	42.2	(6)	
	DBStd	9.14	4.96	5.47	5.18	5.13	4.87	4.80	4.24	4.16	4.20	4.88	4.75	5.34	(7)	
	HDD50	1243	282	247	202	97	25	1	0	0	0	20	122	247	(8)	
	HDD65	5204	746	663	657	510	380	220	113	100	201	356	551	707	(9)	
	CDD50	1574	2	4	10	37	110	239	373	389	255	130	20	5	(10)	
	CDD65	60	0	0	0	0	1	8	21	24	5	1	0	0	(11)	
	CDH74	221	0	0	0	0	2	42	72	83	17	5	0	0	(12)	
	CDH80	32	0	0	0	0	0	9	10	12	1	0	0	0	(13)	
	WSAvg	14.0	16.3	16.0	14.8	13.2	12.9	12.1	11.5	12.4	13.5	14.4	14.9	15.8	(14)	
	PrecAvg	25.6	2.2	1.7	1.6	1.6	1.8	2.1	2.3	2.4	2.2	2.6	2.9	2.3	(15)	
(16) Precipitation	PrecMax	32.8	3.7	3.2	3.4	5.0	5.2	6.1	4.5	5.9	4.6	5.2	4.9	3.7	(16)	
	PrecMin	16.8	0.4	0.5	0.4	0.1	0.4	0.4	0.6	0.2	0.5	0.5	0.9	1.0	(17)	
	PrecStd	4.1	1.0	0.7	0.9	1.2	1.0	1.4	1.0	1.3	1.0	1.0	0.9	0.8	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	58.2	60.9	69.1	72.7	79.8	81.0	81.4	76.2	70.3	60.8	57.3	(19)	
		MCWB	52.1	52.3	52.7	57.9	61.2	65.4	66.1	67.8	64.9	61.5	57.3	53.5	(20)	
	2%	DB	53.3	54.2	57.0	62.8	67.2	72.7	75.4	75.7	71.4	65.4	58.0	54.8	(21)	
		MCWB	50.2	50.0	51.2	54.2	58.0	63.3	64.4	64.7	62.2	59.9	54.9	52.0	(22)	
	5%	DB	50.8	51.6	54.2	59.0	63.5	69.0	72.0	72.2	67.9	62.5	55.8	52.4	(23)	
		MCWB	48.0	48.0	49.6	51.7	56.1	60.7	63.7	63.3	60.9	58.0	53.1	49.9	(24)	
	10%	DB	48.5	49.3	51.8	56.0	60.4	65.8	69.2	69.5	65.2	60.4	53.8	50.3	(25)	
		MCWB	46.0	46.2	47.7	50.3	54.2	59.0	62.5	62.6	59.4	56.7	51.4	47.9	(26)	
	0.4%	WB	52.9	53.4	54.7	58.5	63.4	68.1	71.3	69.4	66.8	63.1	58.0	54.0	(27)	
		MCDB	55.2	57.0	58.3	66.5	69.5	76.6	75.0	75.9	72.5	69.0	60.1	56.2	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	50.5	50.5	52.3	55.1	59.4	64.1	66.7	66.6	64.0	60.6	55.5	52.4	(29)	
		MCDB	52.9	53.5	55.9	61.5	65.1	70.1	72.0	72.7	69.2	64.5	57.4	54.5	(30)	
	5%	WB	48.4	48.5	50.1	52.7	57.1	61.9	64.8	65.1	62.2	58.8	53.5	50.2	(31)	
		MCDB	50.6	51.3	53.5	57.5	62.1	67.4	69.9	70.1	66.2	61.5	55.5	52.2	(32)	
	10%	WB	46.3	46.5	48.1	50.8	55.2	60.1	63.4	63.7	60.6	57.3	51.7	48.1	(33)	
		MCDB	48.2	49.1	51.4	55.2	59.5	64.7	68.0	68.0	64.0	59.9	53.6	50.2	(34)	
	5% DB	MDBR	7.6	8.2	9.9	11.3	11.2	11.8	12.3	12.2	11.4	9.9	8.4	7.6	(35)	
		MCDBR	10.4	11.0	13.4	16.7	16.5	17.1	17.2	16.8	15.6	11.9	9.5	9.6	(36)	
		MCWBR	9.8	8.5	9.3	10.0	9.7	9.9	9.1	8.6	8.6	8.1	8.3	8.7	(37)	
		MCWBR	10.3	10.6	12.6	15.6	14.9	15.7	15.0	14.2	13.4	11.3	9.3	9.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.328	0.345	0.378	0.402	0.402	0.408	0.409	0.398	0.379	0.358	0.332	0.316	(40)	
		taud	2.350	2.379	2.294	2.253	2.314	2.315	2.322	2.369	2.417	2.440	2.401	2.335	(41)	
	Ebn at Noon		205	240	254	263	269	268	265	262	252	233	203	186	(42)	
		Edh at Noon	19	25	33	38	38	38	38	34	29	23	18	16	(43)	
(44) All-Sky Solar Radiation	RadAvg		217	436	808	1277	1578	1651	1587	1344	986	562	272	171	(44)	
	RadStd		21	64	79	128	120	120	148	92	82	45	27	19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+121	N/A
(47) Regional (61 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page