

COLTISHALL, United Kingdom

WMO: 034950

Lat: 52.755N

Lon: 1.358E

Elev: 66

StdP: 14.66

Time Zone: 0.00 (EUW)

Period: 94-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.1	29.3	21.7	16.4	31.1	24.1	18.3	33.0	33.4	48.7	30.1	48.2	4.8	90	0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.5	78.8	65.7	75.3	64.3	72.4	62.7	67.1	75.4	65.5	72.9	64.0	70.4	10.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.0	89.5	70.2	62.7	85.4	68.3	61.3	81.3	66.9	31.6	75.9	30.4	73.2	29.2	70.7	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.9	23.6	21.0	DB	21.1	86.5	3.3	2.3	18.7	88.2	16.8	89.6	15.0	90.9	12.6	92.6	(4)
(5)			WB	20.5	70.7	3.1	1.4	18.3	71.7	16.4	72.6	14.7	73.4	12.4	74.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	40.4	41.1	43.7	47.5	52.8	58.0	62.1	62.8	58.0	52.2	45.5	40.8
	DBStd	9.50	5.12	5.76	5.54	5.18	5.21	4.95	4.36	4.64	4.04	4.90	5.20	5.69
	HDD50	1374	300	254	208	109	30	1	0	0	0	32	150	290
	HDD65	5374	764	670	661	526	377	217	113	101	212	398	584	751
	CDD50	1543	1	4	11	33	118	242	374	398	242	99	17	4
	CDD65	68	0	0	0	0	1	8	22	34	3	0	0	0
	CDH74	425	0	0	0	0	5	74	141	188	17	0	0	0
	CDH80	61	0	0	0	0	0	16	17	27	1	0	0	0
Wind	WSAvg	9.7	11.7	12.0	10.8	9.7	9.2	8.7	8.0	7.5	8.6	10.1	9.7	10.5
Precipitation	PrecAvg	24.8	2.1	1.5	1.9	1.9	1.7	2.1	2.2	2.1	2.1	2.3	2.6	2.4
	PrecMax	32.2	4.3	3.7	3.4	5.4	3.7	5.5	6.6	4.9	5.8	5.7	5.9	4.7
	PrecMin	19.0	0.4	0.1	0.5	0.2	0.3	0.3	0.2	0.2	0.3	0.4	0.8	0.9
	PrecStd	3.3	1.0	0.8	0.9	1.1	0.9	1.3	1.3	1.2	1.4	1.5	1.0	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	58.1	61.1	67.9	74.3	81.8	82.3	83.4	76.3	68.3	60.8	56.9
		MCWB	50.8	52.8	53.3	56.5	62.2	65.1	66.6	67.1	63.5	60.9	57.4	53.6
	2%	DB	52.8	54.8	57.9	62.8	69.6	74.8	78.2	79.0	72.2	64.3	58.0	54.5
		MCWB	49.5	50.2	51.4	53.9	59.3	64.0	65.2	66.7	61.7	58.7	54.9	51.7
	5%	DB	50.4	52.2	55.3	59.5	65.9	70.8	74.4	75.4	68.3	62.0	55.7	51.8
		MCWB	47.5	48.1	50.2	51.6	57.8	61.4	63.6	64.9	59.9	57.4	52.5	49.2
	10%	DB	48.2	49.9	52.9	56.9	62.6	67.5	71.3	72.0	65.5	60.1	53.5	49.3
		MCWB	45.6	46.6	48.6	50.3	55.4	59.1	62.4	63.2	58.7	56.3	50.7	47.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.9	53.4	55.3	57.7	65.4	68.0	68.7	69.6	65.6	62.5	57.8	54.0
		MCDB	54.0	56.9	59.5	65.9	71.4	77.4	77.4	79.1	73.2	67.2	60.0	56.1
	2%	WB	49.8	50.7	52.7	55.0	60.8	64.5	66.5	67.5	63.3	60.1	55.3	52.2
		MCDB	52.0	54.2	56.5	60.9	67.5	72.9	75.1	75.7	68.9	63.0	57.5	54.3
	5%	WB	47.9	48.6	50.9	52.8	58.1	62.4	64.7	66.0	61.7	58.5	53.1	49.7
		MCDB	50.0	51.5	54.5	58.1	65.0	69.0	72.1	73.2	66.1	61.0	55.1	51.6
	10%	WB	46.0	46.7	48.9	50.8	56.0	60.6	63.3	64.5	60.2	57.1	51.2	47.2
		MCDB	48.0	49.6	52.3	55.8	61.9	66.2	69.6	70.5	63.9	59.6	53.0	49.1
Mean Daily Temperature Range	5% DB	MDBR	8.6	10.1	11.6	13.7	14.0	14.7	14.7	15.5	13.6	12.3	10.5	8.7
		MCDBR	11.0	11.5	15.0	18.3	20.1	20.4	21.0	20.8	18.7	14.0	11.1	9.9
		MCWBR	10.1	9.0	10.1	10.5	11.9	11.3	9.7	9.6	10.1	9.7	9.2	8.9
	5% WB	MCDBR	10.8	11.3	13.5	17.2	19.6	18.5	18.8	19.0	16.3	13.1	10.3	10.1
		MCWBR	10.3	9.4	10.0	10.5	12.2	11.2	9.7	9.2	9.7	10.1	9.1	9.4
Clear-Sky Solar Irradiance	taub	0.327	0.344	0.378	0.401	0.403	0.408	0.409	0.398	0.378	0.358	0.331	0.316	
	taud	2.349	2.375	2.285	2.245	2.297	2.300	2.309	2.355	2.407	2.431	2.398	2.336	
	Ebn at Noon	207	241	254	263	269	268	265	262	253	233	204	187	
	Edh at Noon	19	25	33	39	39	39	38	35	29	23	18	16	
All-Sky Solar Radiation	RadAvg	223	440	804	1266	1553	1634	1567	1324	981	565	279	177	
	RadStd	21	65	83	130	118	122	154	92	81	47	29	20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page