

HEMSBY, United Kingdom

WMO: 034960

Lat: 52.683N

Lon: 1.683E

Elev: 14

StdP: 101.16

Time Zone: 0.00 (EUW)

Period: 90-01

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	-0.9	-5.2	2.4	0.1	-3.9	2.7	1.0	16.1	7.4	14.8	6.8	4.9	80	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	24.0	18.2	22.4	17.6	21.1	16.8	19.0	22.5	18.2	21.3	17.5	20.2	5.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.7	20.6	17.0	12.1	19.7	16.2	11.6	19.0	54.0	22.3	51.4	21.5	49.2	20.3	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.3	11.8	10.5	DB	-4.7	28.0	1.7	1.8	-5.9	29.2	-6.9	30.3	-7.9	31.2	-9.1	32.5	
			WB	-5.1	20.9	1.6	1.1	-6.2	21.7	-7.1	22.4	-8.0	23.0	-9.2	23.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	4.9	5.0	6.8	8.4	11.3	13.9	16.3	16.9	14.4	11.0	7.4	5.1
	DBStd	5.03	2.65	3.13	2.70	2.70	2.68	2.51	2.28	2.32	2.12	2.73	2.89	2.98
	HDD10.0	748	160	142	105	63	17	1	0	0	0	20	86	154
	HDD18.3	3014	418	373	358	298	218	136	71	57	119	227	327	411
	CDD10.0	799	1	2	5	15	57	117	195	214	132	52	9	2
	CDD18.3	24	0	0	0	0	0	2	8	13	1	0	0	0
	CDH23.3	81	0	0	0	0	1	12	33	34	2	0	0	0
	CDH26.7	6	0	0	0	0	0	2	2	2	0	0	0	0
Wind	WSAvg	5.2	6.1	6.1	5.8	5.3	4.9	4.5	4.3	4.3	4.7	5.4	5.4	6.0
Precipitation	PrecAvg	589	47	35	38	43	45	42	52	55	56	60	63	56
	PrecMax	806	98	71	79	101	97	98	109	123	127	162	129	104
	PrecMin	418	11	13	8	4	5	5	7	6	7	7	22	26
	PrecStd	83	18	17	20	23	24	27	27	30	36	42	24	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	14.2	15.7	18.8	22.0	24.8	26.3	26.3	22.7	19.5	15.6	13.9
		MCWB	10.3	11.3	11.7	13.3	16.0	18.1	18.7	18.8	17.6	15.8	13.6	11.9
	2%	DB	11.3	12.1	13.8	15.6	19.2	21.8	24.0	24.0	20.6	17.5	14.1	12.4
		MCWB	9.5	9.7	10.6	11.6	14.2	17.2	18.3	18.4	16.3	14.8	12.6	10.9
	5%	DB	10.2	10.8	12.5	14.1	17.4	19.9	22.0	22.6	19.0	16.2	12.7	11.2
		MCWB	8.7	8.8	9.8	10.7	13.5	15.6	17.4	17.8	15.5	13.9	11.3	9.9
	10%	DB	9.0	9.6	11.2	12.8	15.7	18.3	20.6	21.2	17.9	15.2	11.7	9.7
		MCWB	7.6	7.9	9.0	9.9	12.6	14.6	16.8	17.0	15.0	13.1	10.5	8.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	11.6	12.5	13.7	16.5	19.1	20.2	20.2	18.4	16.5	14.1	12.2
		MCDB	12.0	13.7	15.4	17.2	20.6	23.5	24.2	24.0	21.1	19.0	15.3	13.4
	2%	WB	9.9	10.3	11.2	12.2	14.9	17.6	18.9	19.1	17.3	15.3	12.7	11.2
		MCDB	11.1	11.9	13.3	14.8	18.4	20.8	22.2	22.5	19.4	16.9	13.6	12.3
	5%	WB	8.8	9.1	10.2	11.1	13.9	16.2	18.0	18.4	16.5	14.4	11.7	10.0
		MCDB	10.1	10.5	12.0	13.4	16.9	19.3	21.1	21.5	18.2	15.8	12.5	11.2
	10%	WB	7.7	8.0	9.2	10.2	12.8	15.1	17.1	17.7	15.7	13.6	10.7	8.5
		MCDB	8.9	9.5	11.0	12.3	15.2	17.7	20.0	20.4	17.3	14.9	11.6	9.5
Mean Daily Temperature Range	5% DB	MDBR	4.5	5.2	5.7	6.3	6.4	7.0	7.2	7.5	6.4	5.8	4.9	4.2
		MCDBR	5.9	6.2	7.5	8.3	9.5	9.5	9.8	9.3	7.7	6.9	4.9	5.6
		MCWBR	5.4	5.1	5.2	5.1	5.6	5.5	5.1	4.6	4.6	4.8	4.1	5.2
	5% WB	MCDBR	5.9	6.2	7.0	7.3	9.0	9.0	8.8	8.3	6.6	6.4	4.8	5.7
		MCWBR	5.6	5.3	5.3	4.9	5.6	5.7	5.0	4.5	4.4	4.9	4.3	5.4
Clear-Sky Solar Irradiance	taub	0.329	0.345	0.379	0.402	0.404	0.409	0.410	0.400	0.381	0.360	0.333	0.318	
	taud	2.350	2.378	2.291	2.259	2.313	2.317	2.326	2.368	2.416	2.432	2.397	2.340	
	Ebn at Noon	651	760	801	829	847	845	836	824	796	733	642	590	
	Edh at Noon	61	79	104	121	121	121	118	108	92	74	58	52	
All-Sky Solar Radiation	RadAvg	0.70	1.39	2.56	4.08	4.99	5.26	5.04	4.25	3.13	1.78	0.87	0.55	
	RadStd	0.07	0.21	0.27	0.41	0.36	0.37	0.51	0.30	0.25	0.15	0.09	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (66 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page