

HEREFORD CREDENHILL, United Kingdom

WMO: 035220

Lat: 52.0800N

Lon: 2.8025W

Elev: 76

StdP: 100.42

Time Zone: 0.00 (EUW)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.6	-2.9	-6.1	2.3	-2.3	-4.7	2.6	-1.1	17.0	9.1	13.6	8.6	1.3	50	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	26.0	18.8	24.0	17.9	22.3	17.0	19.7	24.2	18.6	22.5	17.7	21.3	2.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.0	13.1	21.4	17.0	12.3	20.4	16.2	11.6	19.4	56.4	24.4	52.8	22.4	50.1	21.3	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	7.5	6.4	-8.1	29.2	2.4	2.2	-9.8	30.8	-11.1	32.1	-12.5	33.3	-14.2	35.0		
			-8.3	22.1	2.3	1.9	-10.0	23.5	-11.4	24.7	-12.7	25.8	-14.4	27.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	4.8	4.9	6.5	9.0	11.9	14.9	16.7	16.1	13.9	10.9	7.3	5.1
	DBStd	5.23	3.54	3.26	2.98	2.68	2.75	2.45	2.45	2.21	2.36	3.01	3.35	3.88
	HDD10.0	757	164	144	113	49	12	0	0	0	2	25	92	157
	HDD18.3	2996	421	375	367	281	201	105	63	76	134	231	332	411
	CDD10.0	827	2	2	4	19	69	149	208	189	118	53	10	4
	CDD18.3	23	0	0	0	0	0	3	13	6	1	0	0	0
	CDH23.3	236	0	0	0	1	8	45	131	42	7	2	0	0
	CDH26.7	34	0	0	0	0	0	6	23	6	0	0	0	0
Wind	WSAvg	2.6	3.1	3.1	3.1	2.8	2.7	2.4	2.2	2.1	1.9	2.4	2.6	2.8
Precipitation	PrecAvg	808	89	66	52	56	60	54	55	59	60	88	82	86
	PrecMax	1049	183	174	97	158	107	148	165	149	148	174	158	167
	PrecMin	528	8	4	10	6	6	9	7	9	11	14	39	24
	PrecStd	126	38	41	26	38	24	35	36	36	35	41	31	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	13.8	17.0	21.7	24.5	27.4	29.2	27.1	24.4	19.9	15.9	14.0
		MCWB	11.8	11.7	11.4	15.0	17.8	19.3	19.9	20.8	18.7	16.3	13.9	12.0
	2%	DB	12.4	12.4	14.4	18.3	21.8	24.3	26.7	24.2	21.7	17.8	14.5	13.0
		MCWB	10.8	10.5	10.8	13.1	16.0	17.9	18.7	18.5	17.5	15.1	12.8	11.5
	5%	DB	11.2	11.3	12.8	16.1	19.4	22.4	24.5	22.3	20.2	16.6	13.5	12.0
		MCWB	9.7	9.5	9.9	11.8	14.6	16.9	17.9	17.5	16.3	14.3	12.0	10.6
	10%	DB	10.1	10.1	11.6	14.3	17.3	20.5	22.4	20.9	18.9	15.5	12.4	10.9
		MCWB	8.8	8.5	9.2	10.7	13.2	15.9	16.8	16.8	15.4	13.5	11.0	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	12.3	12.2	15.7	18.4	21.1	20.7	21.6	19.6	17.0	14.4	12.7
		MCDB	13.2	13.5	14.7	19.8	23.0	26.4	27.4	25.4	22.0	19.1	15.3	13.4
	2%	WB	11.1	10.8	11.4	13.7	16.6	18.6	19.3	19.6	18.1	15.8	13.2	11.7
		MCDB	12.3	12.1	13.6	17.3	20.9	22.8	25.0	23.2	20.9	17.2	14.1	12.7
	5%	WB	10.0	9.8	10.5	12.4	15.1	17.3	18.3	18.3	17.1	14.8	12.3	10.8
		MCDB	11.0	11.1	12.6	15.2	18.3	21.3	23.2	21.1	19.5	16.1	13.3	11.9
	10%	WB	8.9	8.7	9.5	11.2	14.0	16.3	17.4	17.3	16.0	13.9	11.2	9.6
		MCDB	10.0	9.9	11.4	13.8	16.7	19.8	21.5	20.0	18.1	15.2	12.3	10.7
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.4	8.1	9.4	9.4	9.5	9.6	9.3	9.5	7.5	6.6	5.9
		MCDBR	6.7	7.2	9.9	12.6	12.7	12.9	13.5	11.4	11.6	8.0	6.8	6.0
		MCWBR	6.1	5.6	6.9	8.0	7.5	7.4	6.5	6.6	7.4	5.6	5.8	5.5
	5% WB	MCDBR	6.4	7.0	9.5	11.4	11.3	11.6	11.8	10.3	10.7	7.5	6.9	6.1
		MCWBR	6.1	5.8	7.0	7.7	7.1	7.1	6.4	6.7	7.6	5.8	6.1	5.8
Clear-Sky Solar Irradiance	taub	0.321	0.337	0.369	0.393	0.399	0.392	0.389	0.375	0.364	0.348	0.322	0.311	
	taud	2.345	2.374	2.283	2.232	2.252	2.302	2.313	2.372	2.402	2.419	2.397	2.321	
	Ebn at Noon	672	776	815	839	853	862	857	851	817	752	668	612	
	Edh at Noon	62	80	105	125	128	123	120	107	93	76	59	54	
All-Sky Solar Radiation	RadAvg	0.75	1.41	2.54	3.90	4.82	5.19	4.84	3.98	3.01	1.70	0.89	0.58	
	RadStd	0.07	0.16	0.31	0.45	0.27	0.56	0.50	0.33	0.23	0.15	0.09	0.07	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (81 neighbors)		(m)								
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page