

COLESHILL, United Kingdom

WMO: 035350

Lat: 52.4800N

Lon: 1.6908W

Elev: 315

StdP: 14.53

Time Zone: 0.00 (EUW)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.0	27.6	21.8	16.5	28.6	24.0	18.4	30.4	34.9	47.8	29.3	49.0	4.4	350	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	79.6	65.7	75.7	63.9	72.4	62.3	67.3	76.4	65.3	72.9	63.6	70.3	7.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	90.0	71.0	62.3	84.9	68.5	60.9	80.7	66.7	31.9	76.4	30.3	72.9	29.1	70.5	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	20.5	17.4	DB	20.7	85.9	3.3	4.4	18.4	89.1	16.4	91.7	14.6	94.2	12.2	97.4	(4)
(5)			WB	20.3	71.6	3.3	2.8	17.9	73.7	16.0	75.3	14.2	76.9	11.8	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	40.2	40.6	43.6	48.0	53.0	58.8	62.3	61.5	57.4	51.7	44.9	41.0
	DBStd	9.57	5.91	5.99	5.50	5.23	4.99	4.57	4.68	4.13	4.47	5.34	5.65	6.50
	HDD50	1394	306	268	206	95	25	1	0	0	2	43	166	282
	HDD65	5416	769	684	663	509	373	194	113	124	230	412	602	743
	CDD50	1509	1	4	8	37	117	264	381	357	225	96	14	5
	CDD65	56	0	0	0	0	0	7	29	16	3	1	0	0
	CDH74	505	0	0	0	2	13	85	277	102	21	5	0	0
	CDH80	88	0	0	0	0	0	10	57	18	2	1	0	0
Wind	WSAvg	8.1	9.5	9.5	9.2	8.5	8.2	7.1	6.8	6.8	6.8	8.1	8.3	8.8
Precipitation	PrecAvg	26.5	2.5	1.9	1.9	1.9	2.1	2.2	2.0	2.6	2.3	2.1	2.4	2.6
	PrecMax	35.9	5.2	5.5	3.5	4.1	6.7	5.7	4.3	4.7	5.4	4.9	5.2	5.4
	PrecMin	19.4	0.6	0.3	0.2	0.1	0.5	0.4	0.2	0.4	0.4	0.2	1.0	0.5
	PrecStd	3.6	1.1	1.1	0.9	1.0	1.3	1.3	1.1	1.1	1.4	1.2	1.0	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	57.5	62.1	71.2	75.8	81.6	85.9	81.9	77.1	68.3	59.7	56.6
		MCWB	52.4	52.9	52.2	58.2	63.1	67.0	67.7	67.0	63.8	61.4	56.6	53.6
	2%	DB	53.0	53.8	57.6	65.0	71.1	76.3	80.7	76.3	71.9	63.9	57.2	54.4
		MCWB	50.6	50.4	50.7	55.2	60.4	64.4	65.8	64.8	62.7	59.0	54.4	52.1
	5%	DB	50.8	51.6	55.0	60.9	66.6	72.4	76.8	72.7	68.8	61.5	55.4	52.5
		MCWB	48.5	48.6	49.6	52.8	57.8	62.1	64.2	62.9	60.7	57.5	52.9	50.5
	10%	DB	48.8	49.5	52.7	57.6	62.6	68.8	72.5	70.0	65.9	59.5	53.4	50.6
		MCWB	46.7	46.8	48.2	51.0	55.1	60.4	62.2	61.4	59.2	56.1	51.2	48.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.1	53.3	53.9	59.7	64.6	70.3	70.1	68.9	67.2	62.2	57.6	54.3
		MCDB	54.9	55.5	58.2	69.4	72.3	79.3	81.9	78.6	73.6	66.7	59.1	55.7
	2%	WB	51.0	50.9	51.9	56.2	61.3	65.9	67.3	66.4	64.1	60.3	55.0	52.5
		MCDB	52.6	53.4	55.8	63.1	69.7	73.5	77.8	73.7	69.7	63.1	56.6	54.0
	5%	WB	48.9	49.1	50.3	53.9	58.7	63.1	65.1	64.5	62.1	58.4	53.3	50.8
		MCDB	50.5	51.3	54.3	59.6	65.0	70.1	73.7	70.9	66.4	60.7	55.0	52.4
	10%	WB	47.0	47.2	48.6	51.8	56.5	61.2	63.4	62.8	60.3	56.7	51.3	48.6
		MCDB	48.7	49.3	52.3	57.2	61.3	67.3	70.9	68.0	64.4	59.0	53.1	50.2
Mean Daily Temperature Range	5% DB	MDBR	9.4	10.3	13.1	15.7	15.8	16.3	16.8	15.7	15.4	12.2	10.1	9.1
		MCDBR	11.0	11.9	16.7	21.5	22.0	23.1	24.0	19.9	19.3	13.4	11.1	10.1
		MCWBR	10.2	9.2	11.1	13.0	12.8	12.8	11.1	10.1	10.9	9.2	9.6	9.4
	5% WB	MCDBR	11.0	11.3	15.5	19.4	19.3	19.9	20.7	17.6	16.6	12.5	10.8	10.0
		MCWBR	10.4	9.4	11.0	12.4	12.0	12.4	11.0	10.0	10.8	9.5	9.9	9.7
Clear-Sky Solar Irradiance	taub	0.321	0.337	0.369	0.394	0.399	0.397	0.396	0.382	0.366	0.349	0.324	0.311	
	taud	2.360	2.390	2.297	2.235	2.260	2.292	2.299	2.361	2.407	2.435	2.411	2.337	
	Ebn at Noon	211	245	258	266	270	272	269	267	258	238	210	192	
	Edh at Noon	19	25	33	39	40	39	39	34	29	23	18	16	
All-Sky Solar Radiation	RadAvg	239	456	798	1224	1512	1617	1547	1274	957	554	292	193	
	RadStd	21	54	96	134	96	162	168	92	84	48	32	20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (93 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page