

WYTON, United Kingdom

WMO: 035660

Lat: 52.357N

Lon: 0.108W

Elev: 41

StdP: 100.83

Time Zone: 0.00 (EUW)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.8	-2.9	-7.0	2.1	-3.3	-5.2	2.4	-1.3	15.0	8.0	13.5	7.0	3.4	50	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	26.4	17.9	24.6	17.0	22.9	16.3	18.9	24.6	17.9	22.6	17.1	21.4	4.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	12.1	20.4	16.1	11.5	19.7	15.3	10.9	18.9	53.7	24.8	50.5	22.6	48.1	21.3	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.6	9.5	DB	-7.3	29.6	3.6	2.7	-9.8	31.6	-11.9	33.2	-13.9	34.7	-16.5	36.7	(4)
(5)			WB	-7.6	20.7	3.5	1.2	-10.1	21.5	-12.2	22.2	-14.1	22.8	-16.7	23.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	4.5	4.1	6.7	8.1	11.7	14.3	17.0	16.6	13.8	10.4	6.8	5.3	(6)	
	DBStd	5.43	3.41	3.92	3.02	3.10	2.81	3.04	2.56	2.70	2.52	2.94	3.23	3.47	(7)	
	HDD10.0	823	172	167	109	74	13	2	0	0	2	32	104	148	(8)	
	HDD18.3	3089	430	399	361	307	206	126	58	68	138	246	346	403	(9)	
	CDD10.0	813	1	2	6	17	66	131	217	204	114	44	8	4	(10)	
	CDD18.3	36	0	0	0	0	1	4	16	14	1	0	0	0	(11)	
	CDH23.3	308	0	0	0	0	13	46	138	101	11	0	0	0	(12)	
	CDH26.7	49	0	0	0	0	1	2	24	21	1	0	0	0	(13)	
(14) Wind	WSAvg	4.7	5.4	5.4	5.6	4.9	4.4	4.0	4.2	4.2	4.3	4.4	4.4	5.1	(14)	
(15) Precipitation	PrecAvg	537	44	30	41	43	46	49	45	51	50	45	49	46	(15)	
	PrecMax	729	88	74	82	94	106	123	121	106	122	132	100	99	(16)	
	PrecMin	280	8	9	3	7	5	2	7	9	4	2	22	11	(17)	
	PrecStd	88	18	16	22	22	25	28	26	25	32	32	20	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	13.8	16.8	20.5	24.9	26.8	29.4	29.7	24.9	20.1	15.1	13.9	(19)	
		MCWB	10.7	11.1	11.6	13.7	16.4	18.6	18.7	18.9	16.5	15.4	13.4	11.9	(20)	
	2%	DB	11.4	12.0	14.1	17.9	22.1	24.7	26.6	25.7	21.7	17.7	14.0	13.1	(21)	
		MCWB	9.7	9.8	10.3	12.5	15.8	17.1	18.1	17.5	16.2	13.9	12.4	11.2	(22)	
	5%	DB	10.5	10.7	12.6	15.2	19.7	22.6	24.7	23.9	19.9	16.1	12.9	12.0	(23)	
		MCWB	8.9	8.8	9.5	11.1	14.1	16.3	17.4	16.7	14.6	13.1	11.5	10.3	(24)	
	10%	DB	9.3	9.5	11.3	13.5	17.6	20.4	22.6	22.0	18.4	14.9	11.8	10.7	(25)	
		MCWB	7.8	7.7	8.7	10.0	12.9	15.3	16.4	16.0	14.0	12.5	10.5	9.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	11.4	12.1	15.1	17.6	20.3	20.1	19.6	17.9	15.9	13.6	12.3	(27)	
		MCDB	12.3	13.0	15.9	19.9	23.3	23.7	26.3	26.2	21.1	19.2	14.7	13.6	(28)	
	2%	WB	10.1	10.1	11.0	13.1	16.1	18.0	19.0	18.6	16.7	14.6	12.6	11.4	(29)	
		MCDB	11.3	11.6	13.3	16.6	21.2	23.4	24.9	24.3	20.2	16.6	13.7	12.9	(30)	
	5%	WB	9.0	9.1	10.1	11.6	14.8	16.9	18.0	17.5	15.9	13.8	11.6	10.4	(31)	
		MCDB	10.2	10.6	11.9	14.5	19.1	21.4	22.6	22.1	19.0	15.4	12.7	11.8	(32)	
	10%	WB	8.0	8.0	9.2	10.3	13.3	15.7	17.1	16.7	14.9	12.9	10.7	9.2	(33)	
		MCDB	9.2	9.3	11.0	13.2	17.1	20.0	21.3	20.9	17.3	14.6	11.6	10.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.5	6.9	7.8	9.0	8.7	9.1	9.1	7.8	6.6	5.4	4.7	(35)	
		MCDBR	6.1	6.3	8.0	10.3	13.3	12.3	12.8	11.9	10.2	8.1	5.6	5.6	(36)	
	5% WB	MCWBR	5.7	4.9	5.3	6.0	7.3	6.2	5.7	5.1	5.4	5.0	4.6	5.0	(37)	
		MCWBR	6.2	6.3	7.2	9.7	12.7	11.1	10.9	10.4	8.8	7.1	5.7	5.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.324	0.340	0.374	0.399	0.403	0.406	0.405	0.393	0.373	0.354	0.328	0.313	(40)	
		taud	2.369	2.385	2.282	2.225	2.253	2.267	2.281	2.335	2.396	2.434	2.415	2.351	(41)	
	Ebn at Noon		666	770	808	833	848	847	841	831	805	743	658	607	(42)	
		Edh at Noon	61	79	105	125	128	128	124	111	94	74	58	52	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.75	1.44	2.52	3.91	4.79	5.13	4.91	4.09	3.07	1.78	0.93	0.61	(44)	
	RadStd		0.07	0.19	0.30	0.42	0.33	0.46	0.52	0.29	0.27	0.16	0.10	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (89 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page