

MILDENHALL, United KingdomWMO: **035770**Lat: **52.367N**Lon: **0.483E**Elev: **10**StdP: **101.20**Time Zone: **0.00 (EUW)**Period: **94-19**WBAN: **35046****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.2	-5.9	2.3	-1.3	-4.2	2.7	-0.5	14.3	9.7	12.9	9.5	2.3	240	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	28.2	19.2	26.1	18.4	24.1	17.6	20.6	25.3	19.6	24.0	18.6	22.5	4.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	13.9	21.3	18.1	13.0	20.5	17.2	12.3	19.7	59.1	25.8	55.6	23.9	52.9	22.8	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	10.2	9.1	-6.6	32.0	2.2	2.1	-8.2	33.5	-9.5	34.8	-10.8	36.0	-12.4	37.5		
			-6.8	22.5	2.3	1.0	-8.4	23.2	-9.8	23.8	-11.0	24.4	-12.7	25.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	4.7	5.2	7.0	9.6	12.6	15.5	18.1	17.8	15.0	11.7	7.7	5.2
	DBStd	5.70	3.37	3.40	3.11	3.27	3.15	2.77	2.79	2.68	2.67	3.12	3.34	3.79
	HDD10.0	716	166	137	100	47	11	0	0	0	1	18	83	153
	HDD18.3	2797	423	367	351	263	179	92	39	43	106	208	320	407
	CDD10.0	1035	2	3	8	34	92	167	251	241	150	69	14	5
	CDD18.3	72	0	0	0	0	1	8	32	26	5	1	0	0
	CDH23.3	607	0	0	0	3	17	81	276	189	37	4	0	0
	CDH26.7	143	0	0	0	0	1	15	69	51	7	1	0	0
(14) Wind	WSAvg	4.4	5.1	5.1	4.9	4.5	4.4	4.1	3.9	3.9	3.9	4.3	4.4	4.8
(15) Precipitation	PrecAvg	587	51	39	33	39	45	51	53	59	49	58	58	49
	PrecMax	766	96	74	79	115	121	147	105	128	109	112	110	95
	PrecMin	389	12	6	3	1	11	15	21	5	8	13	26	17
	PrecStd	101	21	20	19	29	25	33	23	29	28	26	23	21
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	15.1	17.5	23.0	25.2	28.7	31.2	30.9	27.2	21.8	16.8	14.3
		MCWB	12.0	12.4	11.9	15.0	17.2	19.4	19.8	19.9	18.5	17.1	15.2	12.6
	2%	DB	12.2	13.0	15.4	19.2	23.1	25.8	28.4	27.9	23.8	19.1	15.1	13.2
		MCWB	10.6	10.9	11.5	13.3	16.4	18.1	19.3	19.3	17.5	16.0	13.3	11.9
	5%	DB	11.1	11.8	13.9	17.2	21.0	23.2	26.2	25.1	21.8	17.7	13.9	12.1
		MCWB	9.6	9.8	10.7	12.3	15.4	17.1	18.5	18.2	16.6	15.1	12.5	10.9
	10%	DB	9.9	10.2	12.2	15.2	18.9	21.2	24.2	23.1	20.0	16.2	12.8	10.9
		MCWB	8.7	8.8	9.7	11.4	14.2	16.1	17.8	17.2	15.7	14.2	11.5	9.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.4	12.7	13.8	16.0	19.7	21.2	21.7	21.6	20.3	18.4	15.3	13.3
		MCDB	13.2	14.1	15.6	20.4	22.6	26.1	26.3	26.8	24.5	20.5	16.1	13.9
	2%	WB	11.2	11.3	12.5	14.4	17.5	19.6	20.5	20.2	18.6	16.8	13.8	12.3
		MCDB	12.3	12.7	14.4	17.8	20.9	23.0	25.7	25.0	22.0	18.5	14.7	13.2
	5%	WB	9.9	10.1	11.3	13.2	16.0	18.1	19.5	19.2	17.7	15.7	12.7	11.2
		MCDB	10.9	11.2	13.2	16.3	20.1	21.6	24.5	23.6	20.5	17.0	13.8	12.1
	10%	WB	8.8	9.1	10.2	11.9	14.7	17.0	18.5	18.3	16.6	14.8	11.6	10.0
		MCDB	9.7	10.2	12.0	15.0	18.1	20.3	22.9	22.0	19.0	16.1	12.6	10.7
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	6.4	7.9	9.2	9.4	9.5	10.0	9.7	9.1	7.7	6.2	5.3
		MCDBR	6.4	7.3	10.1	11.7	12.7	12.8	13.6	12.6	11.3	8.3	6.2	5.6
	5% WB	MCWBR	5.9	5.7	6.8	6.8	7.1	6.6	5.6	5.4	6.0	5.7	5.4	5.2
		MCDBR	6.2	6.8	8.7	10.6	11.3	11.1	11.7	10.7	9.7	7.7	6.3	5.6
		MCWBR	6.0	5.8	6.5	6.9	7.2	6.6	5.7	5.4	6.2	6.0	5.7	5.4
(40) Clear-Sky Solar Irradiance	taub	0.327	0.344	0.378	0.403	0.407	0.411	0.410	0.399	0.377	0.358	0.331	0.316	
	taud	2.357	2.372	2.267	2.215	2.247	2.258	2.273	2.325	2.384	2.420	2.404	2.345	
	Ebn at Noon	661	765	803	829	844	843	836	826	800	738	652	601	
	Edh at Noon	61	80	107	127	129	129	125	113	95	75	58	53	
(44) All-Sky Solar Radiation	RadAvg	0.73	1.41	2.52	3.97	4.81	5.13	4.90	4.12	3.09	1.80	0.91	0.58	
	RadStd	0.07	0.21	0.28	0.41	0.36	0.40	0.51	0.30	0.26	0.16	0.10	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (80 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.62	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A