

LITTLE RISSINGTON, United Kingdom

WMO: 036470

Lat: 51.8606N

Lon: 1.6931W

Elev: 210

StdP: 98.83

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.8	-5.9	2.4	-1.7	-4.6	2.6	-1.0	15.4	8.4	14.2	8.3	4.6	70	0.687

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	25.4	17.8	23.3	16.9	21.6	16.1	18.7	23.3	17.8	21.6	16.9	20.3	4.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.6	20.1	16.3	11.9	19.0	15.5	11.3	18.2	53.8	23.4	50.8	21.6	48.2	20.2	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	11.4	10.2	DB	-6.0	29.0	1.9	2.1	-7.4	30.5	-8.5	31.8	-9.5	33.0	-10.9	34.5	(4)
(5)			WB	-6.3	20.8	1.8	1.3	-7.6	21.7	-8.6	22.4	-9.6	23.2	-10.9	24.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	3.7	4.1	5.8	8.1	11.0	13.9	16.2	15.8	13.6	10.4	6.5	4.2	(6)
(7)		DBStd	5.31	3.21	3.16	2.96	2.91	2.92	2.58	2.57	2.33	2.33	2.75	2.92	3.51	(7)
(8)		HDD10.0	906	197	164	131	71	22	1	0	0	1	28	108	182	(8)
(9)		HDD18.3	3256	455	398	387	308	228	135	78	85	142	246	354	439	(9)
(10)		CDD10.0	714	0	1	2	13	52	119	191	181	110	41	4	1	(10)
(11)		CDD18.3	22	0	0	0	0	0	3	11	7	1	0	0	0	(11)
(12)		CDH23.3	173	0	0	0	1	2	29	93	42	6	1	0	0	(12)
(13)		CDH26.7	24	0	0	0	0	0	3	16	6	0	0	0	0	(13)
(14)	Wind	WSAvg	5.3	5.9	6.0	5.7	5.3	5.1	4.7	4.5	4.6	4.8	5.6	5.6	5.8	(14)
(15)	Precipitation	PrecAvg	725	71	51	47	53	61	52	56	61	57	70	74	73	(15)
(16)		PrecMax	982	182	119	93	151	137	142	178	147	116	128	124	132	(16)
(17)		PrecMin	471	7	10	8	2	9	9	10	8	8	15	33	22	(17)
(18)		PrecStd	130	35	29	22	36	28	32	35	34	31	31	27	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	12.6	15.7	20.5	23.1	26.5	28.7	27.2	24.2	19.1	14.2	12.3	(19)
(20)			MCWB	10.4	10.3	10.6	13.7	16.5	18.6	18.9	19.2	17.4	15.7	13.2	11.5	(20)
(21)		2%	DB	10.6	10.7	13.2	17.0	20.6	23.5	25.9	24.3	21.2	16.6	13.0	11.5	(21)
(22)			MCWB	9.6	9.3	9.7	12.0	15.3	17.0	17.6	17.9	16.2	14.2	12.2	10.8	(22)
(23)		5%	DB	9.5	9.7	11.6	14.8	18.4	21.3	23.6	22.0	19.3	15.5	12.0	10.5	(23)
(24)			MCWB	8.6	8.4	9.1	10.8	14.0	15.9	16.9	16.5	15.2	13.7	11.1	9.8	(24)
(25)		10%	DB	8.5	8.8	10.4	13.0	16.2	19.2	21.6	20.3	17.9	14.5	11.0	9.4	(25)
(26)			MCWB	7.7	7.7	8.4	9.7	12.7	14.8	16.1	15.8	14.6	13.1	10.1	8.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	11.1	11.7	14.5	17.6	19.8	20.0	20.1	18.6	16.4	13.6	11.7	(27)
(28)			MCDWB	11.3	12.0	13.6	18.7	21.6	25.2	26.0	25.2	21.9	18.5	13.9	11.9	(28)
(29)		2%	WB	9.9	9.7	10.6	12.7	15.9	17.6	18.5	18.6	17.1	15.1	12.4	11.0	(29)
(30)			MCDWB	10.4	10.4	12.3	16.1	19.6	21.8	23.5	22.6	19.8	16.0	12.8	11.4	(30)
(31)		5%	WB	8.7	8.8	9.7	11.4	14.5	16.5	17.6	17.6	16.1	14.2	11.3	10.0	(31)
(32)			MCDWB	9.3	9.5	11.1	13.9	17.5	20.1	22.2	20.6	18.3	15.0	11.9	10.4	(32)
(33)		10%	WB	7.8	7.9	8.8	10.2	13.3	15.4	16.7	16.6	15.2	13.3	10.3	8.8	(33)
(34)			MCDWB	8.4	8.7	10.2	12.5	15.7	18.5	20.6	19.2	17.2	14.3	10.9	9.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	5.4	6.8	8.1	8.3	8.6	8.9	8.1	7.8	6.3	5.2	4.6	(35)
(36)			MCDBR	5.8	6.0	8.2	10.5	11.0	11.9	12.1	10.4	9.6	6.7	5.7	5.3	(36)
(37)			MCWBR	5.8	5.0	5.6	6.5	6.6	6.5	5.5	5.1	5.5	4.8	5.2	5.3	(37)
(38)		5% WB	MCDWR	5.7	5.8	7.2	9.4	9.6	10.4	10.4	8.9	8.4	6.3	5.6	5.4	(38)
(39)			MCWBR	5.8	5.2	5.5	6.3	6.3	6.3	5.6	5.1	5.5	5.2	5.4	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.317	0.332	0.364	0.387	0.392	0.388	0.385	0.374	0.359	0.344	0.319	0.307	(40)	
(41)		taud	2.373	2.393	2.299	2.249	2.269	2.304	2.318	2.372	2.413	2.439	2.420	2.349	(41)	
(42)		Ebn at Noon	686	787	823	847	861	866	861	853	824	761	680	628	(42)	
(43)		Edh at Noon	61	79	104	123	126	123	120	108	92	74	58	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.79	1.46	2.54	3.91	4.78	5.21	4.95	4.10	3.08	1.78	0.95	0.62	(44)	
(45)		RadStd	0.07	0.18	0.33	0.45	0.29	0.53	0.51	0.33	0.26	0.16	0.10	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (94 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page