

LUNDY ISLAND LH, United Kingdom

WMO: 037020

Lat: 51.162N

Lon: 4.656W

Elev: 141

StdP: 14.62

Time Zone: 0.00 (EUW)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.4	35.2	24.6	18.8	34.9	27.8	21.9	37.3	56.8	46.5	52.7	46.6	20.3	70	0.785

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	68.5	61.9	66.4	61.3	64.8	60.3	63.4	66.5	62.2	64.9	61.3	63.7	8.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.2	84.1	64.6	61.1	81.0	63.4	60.2	78.4	62.6	28.8	66.6	28.1	65.2	27.4	63.7	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.5	43.1	36.4	DB	30.2	73.2	5.2	5.0	26.4	76.8	23.4	79.7	20.4	82.5	16.7	86.1	(4)
(5)			WB	28.1	65.6	4.9	2.4	24.5	67.3	21.7	68.7	19.0	70.0	15.4	71.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	45.5	43.4	46.1	47.5	53.0	56.4	60.5	60.7	58.5	54.5	50.2	47.0		
	DBStd	6.81	4.17	5.07	3.04	3.20	3.37	3.27	2.86	2.65	2.69	3.25	3.52	3.73		
	HDD50	689	142	185	123	87	5	0	0	0	0	5	40	102		
	HDD65	4755	605	604	586	526	372	257	144	137	195	327	445	557		
	CDD50	1417	2	2	2	11	98	193	325	331	255	143	45	10		
	CDD65	8	0	0	0	0	0	1	4	3	0	0	0	0		
	CDH74	12	0	0	0	0	0	0	0	12	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	0	2	0	0	0	0		
	WSAvg	17.0	20.8	20.1	18.9	16.4	14.1	13.2	12.9	14.5	15.2	18.4	19.3	20.3		
	PrecAvg	48.1	5.4	3.8	3.1	2.8	2.9	3.0	3.2	3.8	3.5	5.3	5.7	5.4		
(15) Precipitation	PrecMax	59.9	8.9	8.3	6.0	5.7	6.3	6.6	8.9	8.6	6.3	9.6	9.7	9.1		
	PrecMin	38.1	0.5	1.1	0.9	0.9	0.4	0.8	0.6	0.4	0.9	1.7	2.7	1.4		
	PrecStd	5.6	2.0	1.9	1.4	1.4	1.3	1.6	1.7	1.9	1.3	2.0	1.9	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	53.1	54.7	59.0	66.3	69.2	72.2	72.0	67.4	62.6	57.5	54.6		
		MCWB	50.9	51.0	50.9	53.3	59.3	59.9	63.2	63.7	61.6	58.7	55.2	52.7		
	2%	DB	51.8	51.7	51.4	55.7	63.2	65.9	69.2	67.5	64.8	60.5	56.5	53.6		
		MCWB	50.5	50.3	49.5	51.4	56.9	59.4	61.9	62.7	60.1	57.6	54.6	51.8		
	5%	DB	51.1	50.6	50.3	53.1	60.5	63.2	66.7	65.7	63.5	59.4	55.7	52.8		
		MCWB	49.7	49.0	48.8	49.8	55.5	58.3	61.2	61.7	59.6	56.7	54.1	51.2		
	10%	DB	50.4	49.4	49.6	51.5	58.2	61.1	64.7	64.2	62.4	58.6	54.9	52.1		
		MCWB	48.8	47.7	48.2	49.0	54.1	57.0	60.3	60.6	59.2	56.0	53.2	50.7		
	0.4%	WB	51.9	51.6	51.6	54.0	59.9	61.9	64.8	65.7	62.7	59.4	56.5	53.2		
		MCDB	52.0	52.0	53.4	58.2	65.0	67.1	69.8	70.2	64.9	61.0	57.1	53.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	51.1	50.6	50.2	51.7	57.6	60.3	63.0	63.8	61.8	58.6	55.6	52.6		
		MCDB	51.4	51.4	50.9	54.5	62.0	63.8	67.0	66.1	63.6	60.0	56.2	53.2		
	5%	WB	50.3	49.4	49.5	50.5	56.0	59.1	61.9	62.7	60.9	57.6	54.7	51.8		
		MCDB	50.8	50.3	50.1	52.0	59.9	62.1	65.2	65.0	62.7	58.9	55.4	52.4		
	10%	WB	49.5	48.2	48.8	49.8	54.4	57.9	60.9	61.7	59.9	56.8	53.7	51.0		
		MCDB	50.3	49.0	49.5	51.0	57.5	60.4	63.6	63.7	61.9	58.2	54.7	51.8		
	5% DB	MDBR	4.1	4.4	4.3	5.1	5.9	5.5	5.5	5.0	4.9	4.3	4.0	4.0		
		MCDBR	4.2	4.7	4.6	7.5	9.6	9.4	9.3	7.2	6.4	5.0	4.2	4.2		
		MCWBR	5.9	5.4	5.1	5.2	5.8	6.0	5.3	4.7	5.1	5.2	5.2	5.4		
		MCWBR	4.1	4.7	4.4	6.1	9.2	7.9	7.5	6.4	5.8	4.8	4.0	4.1		
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.1	5.7	5.1	4.8	6.1	5.7	5.1	4.7	6.0	5.8	5.4	5.7		
	taub		0.335	0.346	0.373	0.385	0.393	0.381	0.385	0.370	0.364	0.355	0.333	0.325		
		taud	2.348	2.388	2.333	2.330	2.350	2.417	2.410	2.470	2.470	2.453	2.399	2.320		
(40) Clear-Sky Solar Irradiance	Ebn at Noon		213	246	260	271	273	278	274	273	262	240	213	195		
		Edh at Noon	21	26	32	36	37	35	35	31	28	24	19	18		
	RadAvg		243	493	876	1405	1713	1873	1711	1438	1071	598	306	188		
(44) All-Sky Solar Radiation	RadStd		24	45	84	97	109	160	133	95	78	45	25	23		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page