

LUNDY ISLAND LH, United Kingdom

WMO: 037020

Lat: 51.162N

Lon: 4.656W

Elev: 43

StdP: 100.81

Time Zone: 0.00 (EUW)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.2	1.8	-4.1	2.7	1.6	-2.3	3.1	2.9	25.4	8.0	23.6	8.1	9.1	70	0.785

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.8	20.3	16.6	19.1	16.3	18.2	15.7	17.4	19.2	16.8	18.3	16.3	17.6	4.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.0	18.1	16.2	11.6	17.5	15.7	11.2	17.0	49.2	19.2	47.4	18.5	45.8	17.6	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.2	19.3	16.3	DB	-1.0	22.9	2.9	2.8	-3.1	24.9	-4.8	26.5	-6.4	28.1	-8.5	30.1	(4)
(5)			WB	-2.2	18.7	2.7	1.3	-4.1	19.6	-5.7	20.4	-7.2	21.1	-9.2	22.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	7.5	6.4	7.8	8.6	11.7	13.6	15.8	15.9	14.7	12.5	10.1	8.4	(6)	
	DBStd	3.78	2.31	2.82	1.69	1.78	1.87	1.82	1.59	1.47	1.50	1.81	1.96	2.07	(7)	
	HDD10.0	383	79	103	68	48	3	0	0	0	0	3	22	57	(8)	
	HDD18.3	2642	336	336	326	292	207	143	80	76	108	182	247	309	(9)	
	CDD10.0	787	1	1	1	6	54	107	181	184	142	79	25	6	(10)	
	CDD18.3	4	0	0	0	0	0	1	2	2	0	0	0	0	(11)	
	CDH23.3	7	0	0	0	0	0	0	0	7	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0	(13)	
(14) Wind	WSAvg	7.6	9.3	9.0	8.4	7.3	6.3	5.9	5.8	6.5	6.8	8.2	8.6	9.1	(14)	
(15) Precipitation	PrecAvg	1222	138	97	80	72	74	75	81	97	90	135	146	136	(15)	
	PrecMax	1521	225	210	153	144	161	168	226	219	159	244	247	232	(16)	
	PrecMin	967	13	28	23	22	11	20	16	11	23	42	69	35	(17)	
	PrecStd	141	52	47	35	35	33	40	44	48	34	50	48	57	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	11.7	12.6	15.0	19.1	20.7	22.3	22.2	19.7	17.0	14.2	12.5	(19)	
		MCWB	10.5	10.6	10.5	11.8	15.2	15.5	17.3	17.6	16.5	14.8	12.9	11.5	(20)	
	2%	DB	11.0	11.0	10.8	13.1	17.3	18.8	20.7	19.7	18.2	15.9	13.6	12.0	(21)	
		MCWB	10.3	10.2	9.7	10.8	13.9	15.2	16.6	17.1	15.6	14.2	12.5	11.0	(22)	
	5%	DB	10.6	10.3	10.2	11.7	15.8	17.3	19.3	18.7	17.5	15.2	13.2	11.6	(23)	
		MCWB	9.8	9.4	9.3	9.9	13.1	14.6	16.2	16.5	15.3	13.7	12.3	10.7	(24)	
	10%	DB	10.2	9.7	9.8	10.8	14.6	16.2	18.2	17.9	16.9	14.8	12.7	11.1	(25)	
		MCWB	9.3	8.7	9.0	9.5	12.3	13.9	15.7	15.9	15.1	13.3	11.8	10.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	10.9	10.9	12.2	15.5	16.6	18.2	18.7	17.1	15.2	13.6	11.8	(27)	
		MCDB	11.1	11.1	11.9	14.5	18.3	19.5	21.0	21.2	18.3	16.1	13.9	12.1	(28)	
	2%	WB	10.6	10.3	10.1	11.0	14.2	15.7	17.2	17.7	16.5	14.8	13.1	11.4	(29)	
		MCDB	10.8	10.8	10.5	12.5	16.7	17.7	19.4	19.0	17.6	15.5	13.4	11.8	(30)	
	5%	WB	10.2	9.6	9.7	10.3	13.3	15.1	16.6	17.1	16.1	14.2	12.6	11.0	(31)	
		MCDB	10.5	10.2	10.1	11.1	15.5	16.7	18.4	18.3	17.1	15.0	13.0	11.3	(32)	
	10%	WB	9.7	9.0	9.3	9.9	12.4	14.4	16.1	16.5	15.5	13.8	12.1	10.6	(33)	
		MCDB	10.2	9.5	9.7	10.6	14.2	15.8	17.6	17.6	16.6	14.6	12.6	11.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.3	2.4	2.4	2.9	3.3	3.1	3.0	2.8	2.7	2.4	2.2	2.2	(35)	
		MCDBR	2.3	2.6	2.6	4.1	5.3	5.2	5.1	4.0	3.6	2.8	2.3	2.4	(36)	
	5% WB	MCWBR	3.3	3.0	2.8	2.9	3.2	3.3	3.0	2.6	2.8	2.9	2.9	3.0	(37)	
		MCWBR	2.3	2.6	2.4	3.4	5.1	4.4	4.2	3.6	3.2	2.6	2.2	2.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.335	0.346	0.373	0.385	0.393	0.381	0.385	0.370	0.364	0.355	0.333	0.325	(40)	
		taud	2.348	2.388	2.333	2.330	2.350	2.417	2.410	2.470	2.470	2.453	2.399	2.320	(41)	
	Ebn at Noon		671	777	820	854	862	876	865	862	826	758	671	614	(42)	
		Edh at Noon	65	81	102	114	117	111	110	98	88	75	61	57	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.77	1.55	2.76	4.43	5.40	5.90	5.39	4.53	3.38	1.88	0.96	0.59	(44)	
	RadStd		0.07	0.14	0.27	0.31	0.34	0.50	0.42	0.30	0.24	0.14	0.08	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page