

LARKHILL, United Kingdom

WMO: 037430

Lat: 51.2017N

Lon: 1.8058W

Elev: 133

StdP: 99.74

Time Zone: 0.00 (EUW)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.6	(c) -2.3	(d) -6.2	(e) 2.3	(f) -1.3	(g) -4.8	(h) 2.6	(i) -0.5	(j) 13.2	(k) 9.0	(l) 11.7	(m) 8.7	(n) 3.0	(o) 40	(p) 0.576

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.1	(c) 26.3	(d) 18.3	(e) 24.2	(f) 17.3	(g) 22.4	(h) 16.5	(i) 19.1	(j) 24.3	(k) 18.1	(l) 22.6	(m) 17.2	(n) 21.0	(o) 3.5	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.6	20.6	16.5	11.9	19.5	15.8	11.4	18.6	54.8	24.4	51.6	22.6	48.9	21.1	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.3	(b) 9.0	(c) 7.9	(e) -6.6	(f) 29.0	(g) 1.8	(h) 1.7	(i) -7.9	(j) 30.3	(k) -9.0	(l) 31.3	(m) -10.0	(n) 32.2	(o) -11.3	(p) 33.5		
(a) 10.3	(b) 9.0	(c) 7.9	(e) -6.9	(f) 21.4	(g) 1.8	(h) 2.2	(i) -8.2	(j) 23.0	(k) -9.3	(l) 24.2	(m) -10.3	(n) 25.5	(o) -11.7	(p) 27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	4.6	4.9	6.5	8.8	11.7	14.6	16.7	16.6	14.2	11.2	7.3	5.0	(6)
(7)		DBStd	5.25	3.34	3.14	2.90	2.91	2.88	2.46	2.45	2.32	2.28	2.79	3.07	3.64	(7)
(8)		HDD10.0	759	168	143	112	55	14	1	0	0	1	19	90	157	(8)
(9)		HDD18.3	2995	425	376	367	287	204	114	63	66	127	223	331	413	(9)
(10)		CDD10.0	836	1	1	4	18	68	139	208	204	126	56	9	3	(10)
(11)		CDD18.3	29	0	0	0	0	0	3	14	11	1	0	0	0	(11)
(12)		CDH23.3	259	0	0	0	1	4	37	124	85	7	1	0	0	(12)
(13)		CDH26.7	39	0	0	0	0	0	4	20	15	0	0	0	0	(13)
(14)	Wind	WSAvg	3.8	4.3	4.4	4.2	3.9	3.7	3.5	3.2	3.2	3.3	3.8	3.7	4.0	(14)
(15)	Precipitation	PrecAvg	768	84	56	66	44	52	52	46	57	67	75	77	91	(15)
(16)		PrecMax	1058	153	162	137	91	110	126	92	138	177	243	194	169	(16)
(17)		PrecMin	566	8	4	13	1	10	4	16	12	20	3	30	19	(17)
(18)		PrecStd	122	41	40	31	24	30	31	24	35	41	52	43	46	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	12.7	16.7	21.6	23.9	27.0	28.8	28.6	24.2	19.6	15.2	13.4	(19)
(20)			MCWB	11.0	10.4	11.1	13.9	16.6	18.3	19.1	19.1	17.3	16.1	13.8	12.0	(20)
(21)		2%	DB	11.5	11.3	13.9	17.9	21.7	24.0	26.7	25.7	21.9	17.3	13.9	12.3	(21)
(22)			MCWB	10.3	9.8	9.8	12.3	15.5	17.1	18.5	18.2	16.5	14.6	12.6	11.3	(22)
(23)		5%	DB	10.6	10.4	12.3	15.5	19.5	22.0	24.5	23.2	20.0	16.2	13.0	11.5	(23)
(24)			MCWB	9.5	9.0	9.3	10.9	14.5	16.1	17.4	17.1	15.4	14.1	11.6	10.5	(24)
(25)		10%	DB	9.6	9.5	11.0	13.7	17.2	20.0	22.4	21.3	18.5	15.3	12.1	10.5	(25)
(26)			MCWB	8.5	8.2	8.8	9.8	13.1	15.1	16.5	16.3	14.7	13.5	10.9	9.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	11.3	11.8	14.8	18.4	19.5	20.4	20.6	18.7	16.6	14.2	12.5	(27)
(28)			MCDWB	12.0	12.3	14.4	20.1	22.1	25.3	26.6	26.2	22.2	19.0	14.8	12.9	(28)
(29)		2%	WB	10.7	10.2	10.8	12.7	16.3	17.9	19.1	19.0	17.3	15.5	12.9	11.6	(29)
(30)			MCDWB	11.3	11.1	12.8	17.1	20.1	22.6	25.1	23.4	20.3	16.7	13.6	12.2	(30)
(31)		5%	WB	9.6	9.3	10.1	11.5	14.9	16.7	18.0	17.9	16.4	14.7	12.0	10.7	(31)
(32)			MCDWB	10.4	10.1	11.8	14.6	18.7	20.7	23.0	21.8	18.8	15.8	12.8	11.4	(32)
(33)		10%	WB	8.7	8.4	9.2	10.5	13.7	15.7	17.0	17.0	15.5	13.9	11.0	9.6	(33)
(34)			MCDWB	9.5	9.4	10.7	13.1	16.7	19.3	21.3	20.2	17.7	15.0	12.0	10.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.2	5.7	7.1	8.4	8.7	8.9	9.1	8.6	8.3	6.6	5.7	5.1	(35)
(36)			MCDBR	5.6	6.0	9.0	11.1	11.8	12.2	13.0	11.8	10.2	6.9	5.5	5.0	(36)
(37)			MCWBR	5.4	4.9	5.8	6.5	6.9	6.5	6.0	5.5	5.5	4.8	4.8	5.0	(37)
(38)		5% WB	MCDBR	5.7	5.8	7.7	9.8	10.6	10.7	11.2	9.9	8.8	6.0	5.4	5.2	(38)
(39)			MCWBR	5.6	5.3	5.5	6.1	6.6	6.2	5.9	5.3	5.6	4.7	5.2	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.338	0.374	0.395	0.399	0.393	0.388	0.379	0.366	0.351	0.325	0.313	(40)	
(41)		taud	2.360	2.374	2.273	2.228	2.254	2.298	2.321	2.367	2.395	2.418	2.406	2.341	(41)	
(42)		Ebn at Noon	687	784	816	841	856	862	860	850	820	759	682	633	(42)	
(43)		Edh at Noon	64	82	108	126	129	124	120	109	95	77	60	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.81	1.50	2.64	4.12	4.99	5.49	5.19	4.33	3.25	1.85	0.98	0.64	(44)	
(45)		RadStd	0.07	0.19	0.35	0.44	0.29	0.55	0.46	0.35	0.25	0.16	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (76 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page