

BOSCOMBE DOWN, United KingdomWMO: **037460**Lat: **51.162N**Lon: **1.755W**Elev: **124**StdP: **99.84**Time Zone: **0.00 (EUW)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.6	-2.3	-6.5	2.2	-0.9	-5.1	2.5	-0.2	15.9	9.9	14.1	9.3	3.0	300	0.633

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	26.4	18.2	24.4	17.2	22.6	16.4	19.1	24.3	18.1	22.6	17.2	21.0	4.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.5	20.6	16.5	11.9	19.4	15.7	11.3	18.5	54.4	24.2	51.3	22.5	48.7	21.1	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	10.9	9.6	-6.2	29.3	1.8	2.0	-7.5	30.7	-8.6	31.9	-9.6	33.0	-10.9	34.4
			-6.6	20.8	1.8	1.1	-7.8	21.6	-8.9	22.3	-9.9	22.9	-11.2	23.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	4.6	4.9	6.6	8.9	11.9	14.7	16.9	16.6	14.3	11.2	7.4	5.0
	DBStd	5.27	3.25	3.06	2.85	2.88	2.87	2.49	2.51	2.38	2.25	2.74	3.04	3.61
	HDD10.0	750	168	143	110	53	12	0	0	0	1	19	87	157
	HDD18.3	2973	426	375	364	284	200	112	60	64	124	223	328	412
	CDD10.0	852	1	1	4	19	71	142	214	206	128	55	9	3
	CDD18.3	33	0	0	0	0	1	4	16	12	1	0	0	0
	CDH23.3	286	0	0	0	1	7	41	140	90	8	1	0	0
	CDH26.7	48	0	0	0	0	0	5	25	18	0	0	0	0
Wind	WSAvg	4.6	5.4	5.2	4.9	4.6	4.5	4.1	4.0	4.1	4.2	4.7	4.6	5.0
Precipitation	PrecAvg	713	75	50	57	47	53	53	41	56	65	67	72	78
	PrecMax	935	154	144	136	100	112	132	96	174	165	162	188	178
	PrecMin	495	7	3	2	2	9	4	8	6	8	4	26	16
	PrecStd	101	39	37	31	25	30	30	23	36	38	42	40	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	12.7	16.9	21.8	24.3	27.2	29.1	29.0	24.5	19.6	15.2	13.3
		MCWB	10.9	10.4	11.1	13.8	16.5	18.5	18.9	18.8	17.5	15.9	13.7	12.0
	2%	DB	11.5	11.3	14.2	18.0	21.9	24.2	26.9	25.9	22.0	17.4	14.0	12.4
		MCWB	10.3	9.6	9.8	12.0	15.2	16.9	18.4	18.2	16.7	14.4	12.7	11.3
	5%	DB	10.5	10.4	12.4	15.7	19.6	22.1	24.7	23.4	20.1	16.2	13.1	11.6
		MCWB	9.4	8.9	9.2	10.9	14.3	16.0	17.3	17.0	15.2	14.0	11.8	10.6
	10%	DB	9.5	9.5	11.1	13.9	17.3	20.2	22.6	21.4	18.6	15.3	12.2	10.6
		MCWB	8.5	8.1	8.8	9.9	12.9	15.0	16.5	16.1	14.6	13.5	10.9	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.1	11.8	14.7	17.7	19.6	20.4	20.5	18.7	16.6	14.2	12.4
		MCDB	11.9	12.3	14.5	19.9	22.0	25.2	26.7	26.6	22.2	18.7	14.8	12.8
	2%	WB	10.6	10.1	10.8	12.7	16.1	17.8	19.1	18.9	17.4	15.5	13.0	11.6
		MCDB	11.3	11.0	12.8	17.2	20.2	22.6	25.0	23.3	20.4	16.6	13.7	12.2
	5%	WB	9.6	9.2	10.1	11.5	14.8	16.7	18.0	17.9	16.4	14.7	12.1	10.7
		MCDB	10.3	10.1	11.8	14.6	18.6	20.8	23.0	21.7	18.7	15.7	12.9	11.5
	10%	WB	8.6	8.4	9.2	10.5	13.6	15.7	17.1	17.0	15.6	13.9	11.1	9.6
		MCDB	9.5	9.3	10.7	13.2	16.7	19.4	21.5	20.2	17.7	14.9	12.0	10.4
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.0	7.3	8.6	8.8	9.1	9.4	8.9	8.4	6.9	5.9	5.3
		MCDBR	5.8	6.3	9.1	11.3	11.9	12.3	13.1	11.8	10.4	7.2	5.8	5.1
		MCWBR	5.5	5.1	5.8	6.5	6.6	6.5	5.9	5.3	5.5	4.9	5.0	4.9
	5% WB	MCDBR	5.8	6.0	7.7	9.8	10.6	10.8	11.3	9.8	8.8	6.3	5.6	5.2
		MCWBR	5.7	5.4	5.5	6.1	6.3	6.2	5.7	5.1	5.6	4.9	5.2	5.2
Clear-Sky Solar Irradiance	taub	0.324	0.339	0.375	0.396	0.399	0.394	0.389	0.380	0.367	0.351	0.325	0.313	
	taud	2.360	2.373	2.272	2.228	2.254	2.297	2.321	2.367	2.394	2.418	2.406	2.342	
	Ebn at Noon	687	783	815	841	855	861	860	850	819	758	682	633	
	Edh at Noon	64	82	108	126	129	125	120	109	95	77	61	56	
All-Sky Solar Radiation	RadAvg	0.81	1.50	2.65	4.14	5.01	5.52	5.22	4.35	3.26	1.86	0.98	0.64	
	RadStd	0.07	0.19	0.35	0.44	0.30	0.55	0.46	0.35	0.25	0.16	0.11	0.08	