

MIDDLE WALLOP, United Kingdom

WMO: 037490

Lat: 51.1497N

Lon: 1.5700W

Elev: 299

StdP: 14.54

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.9	28.3	20.4	15.5	30.8	23.0	17.5	32.7	30.4	49.8	27.8	49.2	5.2	320	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	80.2	64.6	76.5	63.0	73.4	61.6	66.5	76.2	64.7	72.9	63.2	70.3	9.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.1	87.3	69.0	61.7	83.2	67.4	60.4	79.2	65.9	31.3	76.5	29.9	72.8	28.8	70.6	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.6	21.6	19.2	DB	20.7	85.4	3.1	3.7	18.5	88.1	16.7	90.2	15.0	92.3	12.7	95.0	(4)
(5)			WB	20.1	70.4	3.0	2.8	18.0	72.4	16.2	74.0	14.5	75.6	12.4	77.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	40.7	41.3	44.4	48.6	53.9	59.0	62.8	62.4	58.0	52.5	45.8	41.5	(6)
(7)		DBStd	9.50	5.87	5.50	5.14	5.23	5.23	4.47	4.48	4.24	4.15	5.00	5.57	6.56	(7)
(8)		HDD50	1276	291	246	184	85	19	0	0	0	1	32	147	271	(8)
(9)		HDD65	5193	754	664	640	493	344	187	99	105	213	388	577	729	(9)
(10)		CDD50	1625	2	2	9	42	141	271	396	385	241	109	20	7	(10)
(11)		CDD65	65	0	0	0	0	1	7	30	24	3	0	0	0	(11)
(12)		CDH74	605	0	0	0	2	19	89	287	187	19	2	0	0	(12)
(13)		CDH80	103	0	0	0	0	0	12	54	37	0	0	0	0	(13)
(14)	Wind	WSAvg	8.9	10.5	10.3	9.8	9.0	8.8	8.0	7.7	7.7	7.9	8.9	8.9	9.8	(14)
(15)	Precipitation	PrecAvg	29.5	3.0	2.0	2.6	1.8	2.4	2.2	1.7	2.4	2.5	2.8	3.0	3.3	(15)
(16)		PrecMax	37.0	6.1	5.1	6.5	4.2	4.6	5.1	3.2	5.6	7.1	7.2	7.1	7.6	(16)
(17)		PrecMin	20.1	0.3	0.1	0.1	0.0	0.9	0.1	0.4	0.6	0.4	0.1	0.9	0.9	(17)
(18)		PrecStd	4.0	1.6	1.3	1.5	1.0	1.2	1.3	0.7	1.2	1.7	2.0	1.6	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.5	55.4	63.2	72.0	76.5	81.7	85.0	84.4	76.8	68.0	59.9	56.5	(19)
(20)			MCWB	51.9	51.1	51.7	57.6	61.1	64.7	66.7	66.8	63.9	60.6	57.2	53.9	(20)
(21)		2%	DB	53.0	52.8	58.2	65.5	72.5	76.3	81.0	79.2	72.3	63.8	57.5	54.8	(21)
(22)			MCWB	50.8	49.6	49.9	54.2	59.7	62.7	65.1	64.9	62.1	58.1	55.0	52.8	(22)
(23)		5%	DB	51.4	51.1	54.8	61.1	68.3	72.4	77.0	74.6	68.8	61.8	56.0	53.4	(23)
(24)			MCWB	49.3	48.2	48.8	51.9	58.0	60.8	63.2	62.8	59.7	57.4	53.6	51.4	(24)
(25)		10%	DB	49.7	49.6	52.4	57.7	64.0	69.0	73.2	71.3	66.1	60.1	54.5	51.6	(25)
(26)			MCWB	47.8	47.0	47.9	49.9	55.4	59.0	61.9	61.2	58.5	56.5	52.0	49.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.9	52.4	53.5	58.9	64.3	67.4	68.7	68.9	66.2	62.1	57.9	54.7	(27)
(28)			MCD B	53.8	54.4	57.6	68.3	72.4	78.2	81.2	80.5	73.4	65.9	59.0	55.6	(28)
(29)		2%	WB	51.3	50.4	51.6	55.4	61.1	64.2	66.4	66.3	63.8	60.1	55.7	53.3	(29)
(30)			MCD B	52.7	52.1	55.4	63.5	69.0	72.8	77.4	74.5	69.2	62.5	57.0	54.5	(30)
(31)		5%	WB	49.6	48.9	50.3	53.0	58.8	62.1	64.6	64.3	61.9	58.7	54.1	51.6	(31)
(32)			MCD B	51.1	50.6	53.7	59.1	66.1	69.6	74.0	71.2	66.2	60.8	55.7	53.1	(32)
(33)		10%	WB	48.0	47.4	48.8	51.2	56.7	60.3	63.0	62.8	60.4	57.2	52.3	49.8	(33)
(34)			MCD B	49.6	49.3	51.9	56.2	63.0	67.1	70.7	69.0	64.4	59.3	54.1	51.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.7	10.6	12.9	15.3	16.0	16.4	16.9	15.9	15.2	12.3	10.6	9.5	(35)
(36)			MCDBR	10.3	11.6	16.7	21.0	22.6	23.0	23.8	21.6	19.1	13.2	10.0	9.0	(36)
(37)			MCWBR	9.8	9.4	10.4	11.7	12.0	11.6	10.7	9.6	10.2	9.0	8.6	8.8	(37)
(38)		5% WB	MCDBR	10.3	11.1	14.2	18.1	19.6	19.6	20.8	18.0	16.1	11.3	10.0	9.4	(38)
(39)			MCWBR	10.1	9.8	9.8	11.0	11.3	10.8	10.6	9.4	10.3	9.1	9.1	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.341	0.377	0.399	0.402	0.398	0.392	0.384	0.370	0.354	0.327	0.316	(40)	
(41)		taud	2.360	2.371	2.267	2.223	2.251	2.293	2.318	2.362	2.391	2.416	2.406	2.342	(41)	
(42)		Ebn at Noon	217	248	258	266	270	272	272	268	259	239	215	200	(42)	
(43)		Edh at Noon	20	26	35	40	41	40	38	35	30	25	19	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	260	478	840	1314	1589	1756	1664	1388	1038	594	314	204	(44)	
(45)		RadStd	21	60	111	139	97	173	148	109	82	51	35	24	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page