

MIDDLE WALLOP, United Kingdom

WMO: 037490

Lat: 51.1497N

Lon: 1.5700W

Elev: 91

StdP: 100.24

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.4	-2.0	-6.4	2.2	-0.6	-5.0	2.5	0.4	13.6	9.9	12.4	9.6	2.3	320	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	26.8	18.1	24.7	17.2	23.0	16.4	19.2	24.5	18.2	22.7	17.3	21.3	4.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.5	20.6	16.5	11.9	19.7	15.8	11.3	18.9	54.8	24.7	51.6	22.7	49.0	21.5	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.7	8.6	-6.3	29.7	1.7	2.1	-7.5	31.1	-8.5	32.3	-9.5	33.5	-10.7	35.0		
(5)			-6.6	21.3	1.7	1.5	-7.8	22.4	-8.8	23.3	-9.7	24.2	-10.9	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	4.8	5.2	6.9	9.2	12.2	15.0	17.1	16.9	14.5	11.4	7.6	5.3	(6)
(7)		DBStd	5.28	3.26	3.06	2.86	2.90	2.90	2.49	2.49	2.36	2.31	2.78	3.10	3.65	(7)
(8)		HDD10.0	709	162	137	102	47	11	0	0	0	1	18	82	151	(8)
(9)		HDD18.3	2885	419	369	356	274	191	104	55	58	118	216	321	405	(9)
(10)		CDD10.0	903	1	1	5	23	78	151	220	214	134	61	11	4	(10)
(11)		CDD18.3	36	0	0	0	0	1	4	17	13	2	0	0	0	(11)
(12)		CDH23.3	336	0	0	0	1	11	49	159	104	11	1	0	0	(12)
(13)		CDH26.7	57	0	0	0	0	0	7	30	21	0	0	0	0	(13)
(14)	Wind	WSAvg	4.0	4.7	4.6	4.4	4.0	3.9	3.6	3.4	3.4	3.5	4.0	4.0	4.4	(14)
(15)	Precipitation	PrecAvg	749	77	50	66	46	60	55	42	60	64	70	75	84	(15)
(16)		PrecMax	941	155	130	164	106	117	129	82	142	181	182	180	192	(16)
(17)		PrecMin	511	8	3	2	1	23	2	11	15	11	3	24	23	(17)
(18)		PrecStd	101	41	34	37	26	30	33	18	30	44	52	41	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	13.0	17.3	22.2	24.7	27.6	29.4	29.1	24.9	20.0	15.5	13.6	(19)
(20)			MCWB	11.1	10.6	10.9	14.2	16.2	18.2	19.3	19.3	17.7	15.9	14.0	12.2	(20)
(21)		2%	DB	11.7	11.6	14.6	18.6	22.5	24.6	27.2	26.2	22.4	17.7	14.2	12.7	(21)
(22)			MCWB	10.5	9.8	9.9	12.3	15.4	17.1	18.4	18.3	16.7	14.5	12.8	11.5	(22)
(23)		5%	DB	10.8	10.6	12.7	16.2	20.2	22.5	25.0	23.7	20.4	16.6	13.3	11.9	(23)
(24)			MCWB	9.6	9.0	9.3	11.1	14.4	16.0	17.3	17.1	15.4	14.1	12.0	10.8	(24)
(25)		10%	DB	9.9	9.8	11.3	14.3	17.8	20.6	22.9	21.8	18.9	15.6	12.5	10.9	(25)
(26)			MCWB	8.8	8.3	8.8	10.0	13.0	15.0	16.6	16.2	14.7	13.6	11.1	9.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	11.4	11.9	15.0	18.0	19.7	20.4	20.5	19.0	16.7	14.4	12.6	(27)
(28)			MCDWB	12.1	12.5	14.2	20.2	22.5	25.7	27.3	26.9	23.0	18.8	15.0	13.1	(28)
(29)		2%	WB	10.7	10.2	10.9	13.0	16.2	17.9	19.1	19.1	17.6	15.6	13.2	11.8	(29)
(30)			MCDWB	11.5	11.2	13.0	17.5	20.6	22.7	25.2	23.6	20.7	16.9	13.9	12.5	(30)
(31)		5%	WB	9.8	9.4	10.2	11.7	14.9	16.7	18.1	18.0	16.6	14.8	12.3	10.9	(31)
(32)			MCDWB	10.6	10.4	12.1	15.0	18.9	20.9	23.3	21.8	19.0	16.0	13.2	11.7	(32)
(33)		10%	WB	8.9	8.5	9.4	10.6	13.7	15.7	17.2	17.1	15.8	14.0	11.3	9.9	(33)
(34)			MCDWB	9.8	9.6	11.1	13.5	17.2	19.5	21.5	20.5	18.0	15.2	12.3	10.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.9	7.2	8.5	8.9	9.1	9.4	8.8	8.4	6.9	5.9	5.3	(35)
(36)			MCDBR	5.7	6.4	9.3	11.7	12.5	12.8	13.2	12.0	10.6	7.4	5.6	5.0	(36)
(37)			MCWBR	5.5	5.2	5.8	6.5	6.7	6.4	6.0	5.3	5.7	5.0	4.8	4.9	(37)
(38)		5% WB	MCDWB	5.7	6.2	7.9	10.1	10.9	10.9	11.5	10.0	8.9	6.3	5.6	5.2	(38)
(39)			MCWBR	5.6	5.4	5.4	6.1	6.3	6.0	5.9	5.2	5.7	5.1	5.1	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.341	0.377	0.399	0.402	0.398	0.392	0.384	0.370	0.354	0.327	0.316	(40)	
(41)		taud	2.360	2.371	2.267	2.223	2.251	2.293	2.318	2.362	2.391	2.416	2.406	2.342	(41)	
(42)		Ebn at Noon	684	781	812	838	852	858	857	846	816	755	679	630	(42)	
(43)		Edh at Noon	64	82	109	127	129	125	120	109	95	78	61	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.82	1.51	2.65	4.14	5.01	5.54	5.25	4.38	3.27	1.87	0.99	0.64	(44)	
(45)		RadStd	0.07	0.19	0.35	0.44	0.30	0.54	0.47	0.34	0.26	0.16	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page