

LONDON ST JAMES PARK, United Kingdom

WMO: 037700

Lat: 51.5049N

Lon: 0.1310W

Elev: 5

StdP: 101.26

Time Zone: 0.00 (EUW)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.5	(c) -0.3	(d) -5.5	(e) 2.4	(f) 1.6	(g) -4.4	(h) 2.6	(i) 1.7	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.6	(c) 28.5	(d) 18.7	(e) 26.3	(f) 18.0	(g) 24.5	(h) 17.2	(i) 19.9	(j) 26.0	(k) 19.0	(l) 24.3	(m) 18.1	(n) 22.9	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	12.7	22.1	16.9	12.1	21.2	16.2	11.5	20.4	57.1	25.8	53.7	24.5	51.2	22.9	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) -3.1	(f) 32.8	(g) 1.1	(h) 1.7	(i) -3.9	(j) 34.1	(k) -4.6	(l) 35.1	(m) -5.2	(n) 36.0	(o) -6.0	(p) 37.3		
(4) N/A	(5) N/A	(6) N/A	DB	WB	-3.5	22.2	1.3	1.2	-4.4	23.0	-5.2	23.7	-5.9	24.3	-6.8	25.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	5.7	6.2	8.3	11.1	13.8	16.8	19.4	18.4	15.9	12.9	8.7	7.0	(6)
(7)		DBStd	5.52	3.02	3.08	3.04	3.16	3.04	2.68	2.68	2.41	2.48	2.74	3.14	3.38	(7)
(8)		HDD10.0	512	137	111	67	23	3	0	0	0	0	7	61	103	(8)
(9)		HDD18.3	2401	393	340	309	218	143	61	18	28	79	169	289	352	(9)
(10)		CDD10.0	1263	2	4	16	55	123	205	292	259	178	97	22	9	(10)
(11)		CDD18.3	110	0	0	0	1	4	16	52	29	7	1	0	0	(11)
(12)		CDH23.3	687	0	0	0	11	29	113	333	156	39	7	0	0	(12)
(13)		CDH26.7	163	0	0	0	1	1	25	88	40	7	1	0	0	(13)
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15)	Precipitation	PrecAvg	586	51	34	46	44	48	47	44	49	55	60	56	53	(15)
(16)		PrecMax	801	126	89	98	106	88	107	92	118	146	137	139	113	(16)
(17)		PrecMin	437	9	7	4	9	1	6	9	7	4	3	17	12	(17)
(18)		PrecStd	86	27	19	22	24	25	30	24	28	39	42	31	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	15.8	19.1	24.9	26.1	29.6	32.1	30.8	27.5	23.0	16.8	15.0	(19)
(20)			MCWB	11.6	11.3	11.7	15.0	17.7	19.6	21.0	20.5	18.3	17.2	14.7	12.4	(20)
(21)		2%	DB	12.3	13.0	16.4	21.2	23.7	26.3	29.0	27.2	23.7	19.5	15.6	13.7	(21)
(22)			MCWB	10.6	10.4	11.0	13.7	16.4	18.0	18.8	18.8	17.0	15.6	13.6	11.8	(22)
(23)		5%	DB	11.3	11.7	14.3	18.2	21.3	24.0	26.8	24.6	21.6	18.0	14.6	13.0	(23)
(24)			MCWB	9.7	9.4	10.3	12.5	15.1	16.8	18.3	17.6	16.2	14.6	12.7	11.2	(24)
(25)		10%	DB	10.4	10.6	12.7	16.1	19.2	22.1	24.8	22.8	20.2	16.8	13.4	12.1	(25)
(26)			MCWB	8.7	8.6	9.4	11.0	13.6	16.0	17.5	16.6	15.5	14.0	11.7	10.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.8	12.6	16.1	18.9	20.7	21.5	21.0	20.1	17.5	15.2	13.0	(27)
(28)			MCDWB	13.0	14.7	16.9	24.0	24.2	28.4	30.7	29.0	24.1	22.6	16.5	14.2	(28)
(29)		2%	WB	11.2	10.7	11.6	14.3	17.1	19.1	20.0	19.4	18.4	16.1	14.0	12.2	(29)
(30)			MCDWB	12.2	12.6	15.0	20.3	22.1	23.8	26.4	25.1	22.5	18.7	15.4	13.5	(30)
(31)		5%	WB	9.9	9.9	10.9	12.9	15.8	17.7	19.0	18.5	17.2	15.4	12.9	11.5	(31)
(32)			MCDWB	11.1	11.5	13.9	17.5	20.2	22.3	24.9	23.0	20.2	17.4	14.2	12.9	(32)
(33)		10%	WB	9.0	9.0	10.0	11.8	14.7	16.7	18.1	17.7	16.3	14.6	11.8	10.5	(33)
(34)			MCDWB	10.3	10.7	12.9	15.4	18.4	21.3	23.6	21.5	19.2	16.4	13.3	12.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	5.0	6.5	7.9	8.2	8.4	8.6	8.1	7.8	6.1	4.9	4.8	(35)
(36)			MCDBR	5.3	6.5	9.2	11.5	11.4	11.6	11.8	10.7	9.8	7.2	5.0	4.6	(36)
(37)			MCWBR	5.1	4.4	5.1	5.7	5.6	5.5	4.6	4.3	4.6	4.2	4.2	4.2	(37)
(38)		5% WB	MCDBR	5.2	6.0	8.4	10.5	10.1	10.4	10.5	9.1	7.9	6.4	4.9	4.6	(38)
(39)			MCWBR	5.3	4.4	5.1	5.4	5.4	5.6	4.8	4.3	4.7	4.4	4.5	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.348	0.385	0.406	0.411	0.412	0.408	0.398	0.380	0.363	0.336	0.322	(40)	
(41)		taud	2.367	2.370	2.260	2.221	2.249	2.273	2.292	2.338	2.387	2.416	2.412	2.353	(41)	
(42)		Ebn at Noon	671	769	801	829	843	844	840	829	803	741	663	616	(42)	
(43)		Edh at Noon	63	82	109	127	129	127	123	112	96	77	60	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.80	1.46	2.56	4.00	4.81	5.33	5.05	4.20	3.17	1.83	0.96	0.63	(44)	
(45)		RadStd	0.07	0.20	0.34	0.43	0.32	0.50	0.48	0.34	0.26	0.17	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	(47) Regional (81 neighbors)	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A

Nomenclature: See separate page