

LONDON WC CLERKENWELL, United Kingdom

WMO: 037790

Lat: 51.522N

Lon: 0.112W

Elev: 39

StdP: 100.86

Time Zone: 0.00 (EUW)

Period: 94-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	0.4	-6.9	2.1	3.5	-5.4	2.4	3.5	11.0	7.8	10.2	8.3	4.4	50	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.4	28.4	18.5	26.5	17.7	24.7	17.0	19.5	25.8	18.7	24.4	17.9	23.0	4.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.4	21.7	16.5	11.8	21.1	15.7	11.2	20.4	55.6	25.6	53.0	24.5	50.6	23.2	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	8.2	7.4	DB	-2.1	31.7	1.2	1.8	-2.9	33.0	-3.6	34.0	-4.3	35.0	-5.2	36.3	(4)
			WB	-3.3	21.8	1.2	1.6	-4.1	22.9	-4.8	23.9	-5.4	24.8	-6.3	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	6.5	7.0	8.6	10.9	14.0	17.1	19.1	19.2	16.4	13.1	9.6	6.7
	DBStd	5.46	3.12	3.06	2.93	3.13	3.18	2.86	2.75	2.73	2.45	2.68	2.76	3.26
	HDD10.0	451	113	90	61	27	4	0	0	0	0	6	40	110
	HDD18.3	2297	367	318	301	222	138	56	23	19	68	163	262	360
	CDD10.0	1326	4	6	18	55	129	213	283	287	192	102	28	8
	CDD18.3	131	0	0	0	0	5	19	48	48	11	1	0	0
	CDH23.3	693	0	0	0	1	30	123	253	249	37	1	0	0
	CDH26.7	153	0	0	0	0	3	27	55	64	3	0	0	0
Wind	WSAvg	4.0	4.6	4.5	4.3	4.0	4.1	3.9	3.7	3.6	3.7	4.0	3.8	4.2
Precipitation	PrecAvg	586	51	34	46	44	48	47	44	49	55	60	56	53
	PrecMax	801	126	89	98	106	88	107	92	118	146	137	139	113
	PrecMin	437	9	7	4	9	1	6	9	7	4	3	17	12
	PrecStd	86	27	19	22	24	25	30	24	28	39	42	31	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	14.9	17.7	22.0	26.2	29.8	30.5	31.0	26.9	21.8	16.5	14.5
		MCWB	11.7	10.8	11.6	13.9	16.0	19.1	19.2	19.6	17.9	16.9	13.8	12.2
	2%	DB	12.8	13.1	15.5	19.6	23.8	26.5	28.2	28.4	24.0	19.1	15.2	13.5
		MCWB	10.6	10.2	10.2	11.9	15.5	17.5	18.2	18.4	17.1	14.9	12.8	11.4
	5%	DB	11.8	12.0	14.1	17.6	21.7	24.2	26.2	26.1	21.8	17.8	14.4	12.6
		MCWB	9.8	9.3	9.7	11.3	14.3	16.4	17.6	18.0	16.0	14.5	12.0	10.6
	10%	DB	10.9	11.1	12.8	15.8	19.5	22.3	24.3	23.9	20.3	16.8	13.6	11.6
		MCWB	8.9	8.7	9.4	10.4	13.4	15.4	16.8	17.2	15.1	13.9	11.2	9.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.8	12.5	14.8	17.8	19.7	20.6	21.0	19.0	17.2	14.5	12.7
		MCDB	13.6	13.7	15.9	20.3	23.8	27.6	27.8	29.5	24.5	20.3	15.8	13.9
	2%	WB	10.9	10.7	11.4	13.2	16.2	18.2	19.3	19.6	18.0	16.0	13.3	11.8
		MCDB	12.6	12.6	14.1	17.7	21.8	24.6	25.8	25.5	22.2	18.1	14.9	13.3
	5%	WB	10.0	9.8	10.7	12.0	14.9	17.2	18.5	18.8	17.0	15.2	12.4	10.9
		MCDB	11.7	11.7	13.1	15.9	20.4	22.7	24.3	24.0	20.4	17.2	14.2	12.5
	10%	WB	9.1	8.9	9.9	11.0	13.9	16.2	17.6	18.0	16.1	14.3	11.4	9.7
		MCDB	10.7	10.7	12.3	15.0	18.7	21.3	23.1	22.8	19.3	16.5	13.3	11.4
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.5	5.6	6.9	7.4	7.6	7.7	7.4	6.4	5.3	4.3	3.8
		MCDBR	4.6	5.2	7.4	9.5	10.8	10.7	10.5	10.5	8.5	6.0	4.3	4.2
		MCWBR	4.5	4.0	4.0	4.4	4.9	4.7	3.9	3.7	3.7	3.7	3.7	4.2
	5% WB	MCDBR	4.6	4.9	6.1	8.2	9.9	9.4	9.2	9.1	7.4	5.6	4.4	4.4
		MCWBR	4.7	4.4	4.2	4.4	5.0	4.7	4.2	3.9	4.1	4.3	4.2	4.5
Clear-Sky Solar Irradiance	taub	0.331	0.346	0.383	0.404	0.409	0.410	0.406	0.396	0.378	0.361	0.334	0.320	
	taud	2.372	2.375	2.267	2.228	2.254	2.278	2.296	2.342	2.391	2.421	2.416	2.357	
	Ebn at Noon	674	771	804	832	845	846	843	832	805	744	666	619	
	Edh at Noon	63	81	108	126	129	127	123	111	95	77	60	55	
All-Sky Solar Radiation	RadAvg	0.80	1.46	2.56	4.00	4.81	5.33	5.05	4.20	3.17	1.83	0.96	0.63	
	RadStd	0.07	0.20	0.34	0.43	0.32	0.49	0.48	0.34	0.26	0.17	0.11	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (81 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page