

SHEERNESS, United Kingdom

WMO: 037910

Lat: 51.446N

Lon: 0.746E

Elev: 82

StdP: 14.65

Time Zone: 0.00 (EUW)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.1	32.9	24.3	18.5	37.0	26.3	20.3	37.1	43.7	52.3	39.7	46.7	14.1	300	0.676

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.7	76.6	65.7	73.6	65.0	71.3	63.7	67.9	73.7	66.5	71.8	65.2	70.1	11.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	95.1	71.0	64.4	90.7	69.8	63.0	86.4	68.8	32.3	73.9	31.2	72.1	30.2	70.1	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
33.9	30.2	27.7	DB	28.8	84.1	2.4	2.4	27.1	85.8	25.7	87.2	24.3	88.6	22.6	90.3	(4)
			WB	27.5	70.8	2.0	2.3	26.1	72.4	24.9	73.7	23.8	75.0	22.4	76.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.9	43.3	43.4	45.6	49.3	54.8	60.6	64.5	65.1	60.7	55.2	48.4	43.5
	DBStd	9.28	5.20	5.04	5.04	4.90	4.62	4.47	4.11	3.98	3.85	4.46	4.89	5.47
	HDD50	939	213	188	151	71	12	0	0	0	0	10	85	209
	HDD65	4527	673	604	601	472	319	145	60	48	137	306	497	665
	CDD50	2005	5	4	15	49	159	319	449	467	321	170	38	9
	CDD65	118	0	0	0	0	1	14	44	50	8	1	0	0
	CDH74	247	0	0	0	0	9	41	78	108	11	0	0	0
	CDH80	26	0	0	0	0	2	5	5	13	1	0	0	0
Wind	WSAvg	13.8	16.6	15.7	14.9	13.0	13.5	12.5	12.3	11.9	12.5	13.8	13.5	15.1
Precipitation	PrecAvg	27.8	2.8	2.1	1.6	2.0	1.9	2.0	1.7	2.3	2.3	3.0	3.3	2.7
	PrecMax	39.6	6.5	5.2	4.3	5.0	4.3	5.0	3.3	4.6	5.2	8.3	7.0	5.2
	PrecMin	20.6	0.7	0.5	0.2	0.2	0.4	0.6	0.4	0.4	0.4	0.4	1.3	0.4
	PrecStd	4.4	1.3	1.3	0.9	1.2	1.0	1.3	0.8	1.2	1.3	1.7	1.6	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.9	56.6	59.3	66.6	72.8	78.4	80.5	81.6	74.8	67.8	61.0	56.6
		MCWB	51.3	51.2	52.7	56.9	60.7	65.3	66.9	68.0	64.6	61.1	57.1	53.7
	2%	DB	54.0	53.7	56.3	61.6	66.7	73.3	76.0	76.6	70.4	64.7	58.5	55.2
		MCWB	50.5	50.0	50.7	54.2	59.0	63.1	65.8	66.5	63.1	60.0	55.2	52.4
	5%	DB	52.4	52.0	54.3	58.5	63.5	70.0	73.3	73.3	68.0	62.9	57.1	53.5
		MCWB	49.4	48.7	49.7	52.0	56.6	62.1	65.1	65.6	62.1	59.1	53.8	50.9
	10%	DB	50.6	50.4	52.5	56.2	61.2	67.5	71.0	71.1	66.3	61.3	55.3	51.7
		MCWB	47.8	47.1	48.6	51.0	55.6	60.3	63.7	64.2	61.1	57.9	52.1	48.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	52.2	53.9	58.3	62.8	66.9	69.6	70.5	66.5	62.7	58.2	54.6
		MCDB	54.7	55.0	57.5	64.3	68.3	75.8	75.8	78.3	70.9	66.1	60.2	56.2
	2%	WB	51.0	50.7	51.9	55.4	59.5	64.7	67.6	68.3	64.8	61.1	56.0	52.7
		MCDB	53.4	53.2	55.3	60.4	64.8	71.0	73.3	73.9	68.5	63.7	58.0	54.7
	5%	WB	49.7	49.2	50.5	53.2	57.8	62.9	66.4	66.9	63.5	59.8	54.4	51.3
		MCDB	52.2	51.6	53.5	57.2	62.5	68.3	72.0	71.8	67.1	62.3	56.7	53.4
	10%	WB	48.2	47.7	49.2	51.5	56.5	61.3	65.0	65.5	62.0	58.6	52.5	49.1
		MCDB	50.5	50.1	52.0	55.2	60.6	66.5	70.0	70.1	65.6	61.1	54.8	51.1
Mean Daily Temperature Range	5% DB	MDBR	5.9	6.4	7.0	8.1	7.9	8.9	8.9	8.7	7.8	7.2	6.5	5.8
		MCDBR	7.5	7.7	9.3	11.7	12.3	13.3	12.7	12.2	9.9	8.4	7.4	7.6
		MCWBR	7.2	6.7	6.3	6.7	7.0	7.3	6.6	6.2	5.8	6.3	6.4	7.4
	5% WB	MCDBR	7.5	7.5	8.6	10.8	10.5	12.0	10.5	10.2	8.8	7.8	7.1	7.6
		MCWBR	7.4	7.0	6.6	7.2	7.1	7.4	6.3	5.9	6.2	6.4	6.8	7.6
Clear-Sky Solar Irradiance	taub	0.334	0.350	0.388	0.408	0.414	0.415	0.412	0.403	0.383	0.366	0.339	0.325	
	taud	2.371	2.373	2.261	2.235	2.263	2.286	2.304	2.350	2.397	2.419	2.412	2.362	
	Ebn at Noon	213	244	253	263	266	267	266	262	254	234	209	195	
	Edh at Noon	20	26	35	40	41	40	39	35	30	24	19	17	
All-Sky Solar Radiation	RadAvg	249	462	819	1318	1565	1740	1652	1376	1032	590	299	192	
	RadStd	23	69	102	123	112	135	145	105	81	56	35	26	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page