

CAMBORNE, United Kingdom

WMO: 038080

Lat: 50.2183N

Lon: 5.3275W

Elev: 289

StdP: 14.54

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.0	33.6	22.6	17.2	34.2	25.3	19.5	36.2	35.2	47.3	32.0	47.2	8.9	50	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	70.8	62.5	68.1	61.3	66.1	60.7	64.5	67.9	63.2	66.0	62.1	64.6	11.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.3	88.1	65.5	62.1	84.2	64.2	61.0	81.1	63.3	29.7	68.2	28.8	66.0	28.0	64.8	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.5	26.4	23.7	DB	28.2	75.8	3.3	3.4	25.8	78.3	23.9	80.2	22.0	82.1	19.6	84.6	(4)
(5)			WB	26.0	67.0	3.4	2.2	23.5	68.6	21.5	69.9	19.6	71.1	17.1	72.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	44.7	44.4	45.8	48.3	52.6	56.9	60.3	60.7	58.2	54.3	49.3	46.1	(6)
(7)		DBStd	7.03	4.77	4.39	4.06	3.83	3.67	3.46	3.11	2.72	2.99	3.63	3.95	4.81	(7)
(8)		HDD50	750	169	158	136	74	15	0	0	0	0	7	58	133	(8)
(9)		HDD65	4814	630	576	595	501	386	244	151	136	206	332	471	586	(9)
(10)		CDD50	1425	4	3	6	23	94	209	319	333	245	140	37	12	(10)
(11)		CDD65	11	0	0	0	0	0	2	4	4	1	0	0	0	(11)
(12)		CDH74	23	0	0	0	0	0	7	8	7	1	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	11.8	13.8	13.5	12.8	11.8	11.1	10.3	9.7	9.7	10.6	12.2	12.7	13.5	(14)
(15)	Precipitation	PrecAvg	43.9	5.3	3.9	3.9	2.5	2.6	2.4	2.3	2.9	3.3	4.4	4.8	5.2	(15)
(16)		PrecMax	54.3	9.6	8.4	7.0	6.5	5.2	6.5	6.3	6.0	6.9	10.7	8.3	10.9	(16)
(17)		PrecMin	33.1	0.7	0.4	0.3	0.2	0.4	0.1	0.6	0.2	0.9	0.7	1.9	1.7	(17)
(18)		PrecStd	5.7	2.3	2.2	1.7	1.5	1.2	1.5	1.3	1.7	1.7	2.5	2.0	2.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	53.9	57.2	65.2	68.3	74.1	74.8	74.2	70.0	64.6	58.7	56.1	(19)
(20)			MCWB	52.4	51.2	50.3	54.6	57.8	63.1	64.1	64.9	63.6	59.9	57.0	54.2	(20)
(21)		2%	DB	53.2	52.3	53.8	58.8	63.8	68.5	70.7	69.5	66.6	61.9	57.2	54.8	(21)
(22)			MCWB	51.8	50.4	50.1	52.0	56.3	60.2	62.4	62.8	61.2	58.8	55.5	53.5	(22)
(23)		5%	DB	52.1	51.3	52.2	55.7	60.5	65.1	67.9	67.1	64.6	60.5	56.1	53.9	(23)
(24)			MCWB	50.7	49.5	49.6	50.7	55.0	58.9	61.5	61.7	60.2	58.0	54.4	52.5	(24)
(25)		10%	DB	51.0	50.2	51.1	53.7	58.2	62.7	65.6	65.4	63.1	59.4	55.0	52.7	(25)
(26)			MCWB	49.5	48.5	48.9	49.9	53.9	57.9	60.8	61.0	59.4	57.2	53.2	51.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	52.6	52.8	55.6	60.1	64.5	66.1	66.6	65.0	61.4	57.6	55.0	(27)
(28)			MCD B	53.8	53.1	53.8	60.6	65.5	72.0	71.7	69.9	67.7	63.0	58.0	55.3	(28)
(29)		2%	WB	52.3	51.2	51.5	53.3	57.6	61.6	64.1	64.6	63.0	60.0	56.2	54.0	(29)
(30)			MCD B	52.8	51.9	52.7	57.1	61.4	66.3	67.9	67.2	64.9	61.2	56.8	54.6	(30)
(31)		5%	WB	51.1	50.1	50.6	52.0	56.2	60.0	62.8	63.3	61.8	58.9	55.0	53.0	(31)
(32)			MCD B	51.8	51.0	51.8	54.5	59.2	63.7	65.7	65.7	63.5	59.9	55.8	53.8	(32)
(33)		10%	WB	49.9	49.0	49.5	50.8	54.8	58.8	61.7	62.2	60.6	57.9	53.6	51.6	(33)
(34)			MCD B	50.8	50.1	50.9	53.1	57.3	61.7	64.5	64.4	62.3	59.1	54.8	52.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	7.2	7.7	8.9	9.0	9.2	9.1	8.9	7.7	6.8	6.8	(35)	
(36)			MCDBR	6.9	7.0	8.4	11.7	12.4	13.3	12.6	11.2	10.8	8.0	6.6	6.5	(36)
(37)			MCWBR	7.5	6.7	6.5	7.4	7.6	8.0	6.9	6.4	7.0	6.2	6.6	7.6	(37)
(38)		5% WB	MCDBR	6.9	6.8	7.3	9.6	10.7	11.5	10.5	9.7	8.9	7.2	6.3	6.4	(38)
(39)			MCWBR	7.9	7.2	6.7	7.0	7.2	7.6	6.7	6.7	7.0	6.6	7.0	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.350	0.377	0.383	0.391	0.377	0.382	0.367	0.364	0.358	0.336	0.329	(40)	
(41)		taud	2.353	2.379	2.326	2.343	2.366	2.437	2.429	2.488	2.480	2.449	2.402	2.320	(41)	
(42)		Ebn at Noon	217	247	260	273	275	280	276	276	264	242	217	199	(42)	
(43)		Edh at Noon	21	26	33	36	37	35	34	31	28	24	20	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	261	512	877	1418	1714	1882	1728	1481	1122	638	334	210	(44)	
(45)		RadStd	23	50	96	95	122	173	117	102	76	41	26	23	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page