

CULDROSE, United Kingdom

WMO: 038090

Lat: 50.0844N

Lon: 5.2572W

Elev: 267

StdP: 14.55

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.0	32.6	24.2	18.6	33.3	26.9	21.0	35.7	35.9	47.5	32.7	46.5	10.3	50	0.673

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	70.9	63.3	68.4	61.9	66.4	61.1	65.0	68.7	63.6	66.5	62.5	64.9	11.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.6	88.7	66.1	62.4	85.2	64.7	61.4	82.1	63.8	30.0	69.3	29.0	66.6	28.2	65.0	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
30.3	27.2	24.4	DB	26.1	75.4	2.7	3.2	24.2	77.7	22.6	79.6	21.0	81.4	19.0	83.7
			WB	24.6	67.4	2.7	2.6	22.7	69.3	21.1	70.8	19.6	72.3	17.6	74.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	44.6	44.2	45.5	48.1	52.6	57.1	60.6	60.8	58.0	54.1	49.0	45.9
	DBStd	7.21	5.03	4.57	4.00	3.76	3.66	3.32	3.12	2.78	3.00	3.85	4.42	5.20
	HDD50	791	171	165	142	77	16	0	0	0	0	11	68	141
	HDD65	4846	632	584	603	507	385	237	142	136	212	338	479	591
	CDD50	1432	4	2	4	20	96	214	328	334	239	138	39	14
	CDD65	10	0	0	0	0	0	1	5	4	0	0	0	0
	CDH74	19	0	0	0	0	0	2	11	6	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.4	14.7	13.9	13.4	12.2	11.8	10.9	10.3	10.2	11.4	12.8	13.0	14.6
Precipitation	PrecAvg	39.1	4.5	3.5	2.5	2.6	2.3	2.4	2.7	2.9	2.6	3.9	4.8	4.3
	PrecMax	49.5	7.7	7.5	5.7	6.4	5.5	5.4	8.3	7.8	7.0	6.4	9.8	9.0
	PrecMin	31.1	1.1	0.7	0.8	0.4	0.3	0.3	0.3	0.8	0.2	1.3	1.6	1.3
	PrecStd	5.3	1.9	1.9	1.2	1.5	1.2	1.5	1.7	1.8	1.5	1.4	1.9	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	53.7	56.4	62.7	67.8	72.5	75.3	73.9	69.2	63.9	58.3	55.9
		MCWB	52.2	51.2	51.0	55.3	58.9	63.1	65.5	67.2	63.3	60.2	56.7	54.2
	2%	DB	53.0	52.1	53.3	58.2	63.9	68.7	71.5	69.3	66.2	61.5	57.1	54.8
		MCWB	51.6	50.3	50.0	52.5	57.2	60.5	63.5	63.7	61.4	58.7	55.4	53.5
	5%	DB	52.1	51.1	52.0	55.5	60.7	65.6	68.8	67.2	64.4	60.3	56.2	53.9
		MCWB	50.7	49.4	49.4	51.1	55.5	59.3	62.1	62.3	60.2	58.0	54.6	52.6
	10%	DB	51.2	50.3	51.0	53.6	58.3	63.1	66.3	65.6	63.0	59.3	55.3	52.9
		MCWB	49.7	48.6	48.8	50.0	54.1	58.1	61.1	61.4	59.5	57.3	53.7	51.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.1	52.2	52.7	56.1	61.0	65.0	66.5	67.6	64.5	61.2	57.6	54.9
		MCDB	53.4	52.6	54.4	60.5	65.4	71.1	72.5	71.9	67.0	62.5	57.8	55.2
	2%	WB	52.2	51.1	51.4	53.6	58.3	61.9	64.8	65.3	63.0	60.0	56.2	54.1
		MCDB	52.6	51.6	52.4	56.5	62.2	66.3	69.6	67.9	64.8	60.8	56.6	54.6
	5%	WB	51.2	50.1	50.4	52.1	56.5	60.3	63.3	63.7	61.9	59.0	55.2	53.2
		MCDB	51.8	50.7	51.4	54.3	59.5	63.9	66.9	65.9	63.5	59.7	55.8	53.8
	10%	WB	50.2	49.1	49.6	51.0	55.0	59.0	62.1	62.6	60.8	58.0	54.0	51.9
		MCDB	51.0	50.0	50.6	52.9	57.4	62.1	65.0	64.5	62.2	58.9	55.0	52.7
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.2	8.7	10.0	9.8	9.8	9.5	9.5	9.7	8.3	7.8	7.7
		MCDBR	6.6	7.3	9.0	12.2	13.1	14.0	13.9	11.6	11.0	8.0	6.5	6.3
		MCWBR	7.2	7.1	7.5	8.6	8.4	8.8	8.2	7.5	7.7	6.7	6.7	7.4
	5% WB	MCDBR	6.4	6.8	7.8	10.0	11.3	11.6	11.2	9.8	9.2	7.1	5.8	6.3
		MCWBR	7.4	7.3	7.2	7.8	7.9	8.1	7.5	7.2	7.4	6.7	6.6	7.6
Clear-Sky Solar Irradiance	taub	0.338	0.351	0.379	0.384	0.391	0.377	0.383	0.367	0.364	0.359	0.336	0.330	
	taud	2.356	2.378	2.323	2.341	2.364	2.434	2.427	2.486	2.478	2.449	2.404	2.321	
	Ebn at Noon	218	248	260	273	275	279	276	276	264	242	218	200	
	Edh at Noon	22	27	33	36	37	35	35	31	28	24	20	19	
All-Sky Solar Radiation	RadAvg	265	516	882	1430	1726	1890	1741	1496	1138	650	340	213	
	RadStd	23	51	97	96	127	177	115	105	77	41	26	23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page