

DUNKESWELL, United KingdomWMO: **038400**Lat: **50.8603N**Lon: **3.2403W**Elev: **830**StdP: **14.26**Time Zone: **0.00 (EUW)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.8	28.2	21.1	16.3	29.3	23.8	18.5	31.1	28.3	46.0	26.3	45.1	9.9	50	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	75.0	64.0	71.5	61.9	68.8	60.6	65.2	71.9	63.5	69.1	62.0	66.6	8.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	88.3	67.1	61.4	83.8	65.0	60.1	80.1	63.5	30.5	72.3	29.2	69.4	28.1	66.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.2	21.4	19.1	DB	22.2	79.4	2.8	3.0	20.2	81.5	18.6	83.3	17.0	85.0	15.0	87.2	(4)
(5)			WB	21.3	68.3	2.7	1.6	19.4	69.5	17.8	70.4	16.2	71.4	14.2	72.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	40.1	40.4	42.9	46.4	51.5	56.7	60.2	59.8	56.1	51.1	45.1	41.1	(6)
(7)		DBStd	8.71	5.55	5.26	4.92	4.84	4.85	4.20	4.06	3.75	3.67	4.50	4.97	6.01	(7)
(8)		HDD50	1442	307	271	224	126	37	1	0	0	2	40	157	277	(8)
(9)		HDD65	5735	772	690	686	557	418	251	160	168	266	431	596	740	(9)
(10)		CDD50	1200	0	0	3	19	84	202	315	305	185	74	11	2	(10)
(11)		CDD65	20	0	0	0	0	0	2	10	8	0	0	0	0	(11)
(12)		CDH74	130	0	0	0	0	1	20	67	41	1	0	0	0	(12)
(13)		CDH80	8	0	0	0	0	0	0	4	4	0	0	0	0	(13)
(14)	Wind	WSAvg	9.4	11.1	10.9	10.3	9.6	9.1	8.3	7.7	7.7	8.3	9.8	9.8	10.6	(14)
(15)	Precipitation	PrecAvg	38.7	4.3	3.2	2.7	2.6	2.4	2.6	2.4	2.9	2.7	4.3	4.3	4.2	(15)
(16)		PrecMax	53.9	8.0	7.6	5.7	6.8	5.0	7.1	6.0	7.4	6.5	7.6	8.2	7.7	(16)
(17)		PrecMin	29.4	0.6	0.4	0.6	0.4	0.5	0.6	0.3	0.5	0.6	1.6	1.2	1.3	(17)
(18)		PrecStd	5.7	1.8	1.9	1.2	1.7	1.2	1.5	1.4	1.8	1.6	1.7	1.9	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	53.1	59.6	67.9	72.1	77.2	79.7	79.0	71.5	64.3	57.3	54.1	(19)
(20)			MCWB	51.6	49.3	51.5	56.5	61.1	64.1	65.6	65.8	62.4	58.9	56.5	53.0	(20)
(21)		2%	DB	51.2	50.8	54.8	61.2	67.7	71.8	75.7	73.4	67.9	60.8	55.4	52.8	(21)
(22)			MCWB	50.2	48.9	49.0	53.1	58.5	61.4	64.2	63.9	60.8	57.6	54.3	52.0	(22)
(23)		5%	DB	49.5	49.2	51.9	57.2	64.1	68.5	72.1	69.7	64.9	59.0	54.0	51.4	(23)
(24)			MCWB	48.5	47.8	48.0	50.8	56.8	59.9	62.2	61.6	59.1	56.8	52.8	50.6	(24)
(25)		10%	DB	48.1	47.7	50.0	54.1	60.5	65.1	68.7	66.8	62.6	57.6	52.6	49.8	(25)
(26)			MCWB	47.2	46.3	47.4	48.8	54.5	58.0	60.6	60.2	57.9	55.7	51.4	48.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	51.2	52.7	57.6	62.9	65.8	67.1	68.1	64.6	61.0	56.7	53.5	(27)
(28)			MCDWB	52.4	52.1	56.6	64.0	68.9	73.5	76.4	75.3	68.7	62.6	56.9	53.6	(28)
(29)		2%	WB	50.5	49.5	50.6	53.9	59.5	62.8	65.1	65.0	62.4	58.9	54.7	52.3	(29)
(30)			MCDWB	50.9	50.2	52.8	59.6	65.5	69.3	73.4	70.3	65.9	60.0	55.0	52.7	(30)
(31)		5%	WB	48.9	48.2	49.3	51.7	57.4	60.9	63.3	63.2	60.7	57.5	53.3	50.8	(31)
(32)			MCDWB	49.4	48.9	51.1	55.6	62.8	66.5	69.9	67.5	63.2	58.4	53.8	51.3	(32)
(33)		10%	WB	47.3	46.6	47.9	49.9	55.3	59.0	61.6	61.7	59.2	56.2	51.6	49.1	(33)
(34)			MCDWB	47.9	47.4	49.5	53.0	59.5	64.0	66.7	65.2	61.5	57.2	52.4	49.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.2	8.9	11.0	13.1	13.7	13.9	13.9	12.9	12.4	10.0	8.6	8.1	(35)
(36)			MCDBR	9.1	9.4	13.6	17.7	18.8	19.2	20.0	17.0	15.3	10.3	8.5	8.1	(36)
(37)			MCWBR	9.3	8.1	9.5	11.3	11.6	11.3	10.9	9.3	9.5	7.7	7.9	8.6	(37)
(38)		5% WB	MCDWB	9.1	8.9	11.4	15.4	16.7	16.5	17.1	14.4	12.8	9.0	7.9	8.2	(38)
(39)			MCWBR	9.6	8.6	9.2	10.6	11.0	10.8	10.4	9.1	9.1	8.0	8.0	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.335	0.367	0.381	0.385	0.377	0.374	0.364	0.356	0.345	0.319	0.311	(40)	
(41)		taud	2.373	2.396	2.309	2.288	2.311	2.362	2.375	2.422	2.436	2.442	2.424	2.343	(41)	
(42)		Ebn at Noon	221	252	263	272	276	279	278	275	265	245	221	204	(42)	
(43)		Edh at Noon	20	25	33	38	39	37	36	33	29	24	19	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	256	487	867	1354	1645	1783	1686	1407	1062	595	318	202	(44)	
(45)		RadStd	23	55	110	131	86	180	134	115	70	46	31	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page