

DUNKESWELL, United KingdomWMO: **038400**Lat: **50.8603N**Lon: **3.2403W**Elev: **253**StdP: **98.32**Time Zone: **0.00 (EUW)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.4	-2.1	-6.1	2.3	-1.5	-4.6	2.6	-0.5	12.7	7.8	11.8	7.3	4.4	50	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	23.9	17.8	22.0	16.6	20.5	15.9	18.4	22.2	17.5	20.6	16.7	19.2	3.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.6	19.5	16.3	12.0	18.3	15.6	11.4	17.5	53.0	22.4	50.0	20.8	47.5	19.2	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	9.6	8.5	-5.4	26.3	1.6	1.7	-6.6	27.5	-7.5	28.5	-8.3	29.5	-9.5	30.7
			-5.9	20.2	1.5	0.9	-7.0	20.8	-7.9	21.4	-8.8	21.9	-9.9	22.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	4.5	4.6	6.0	8.0	10.9	13.7	15.7	15.5	13.4	10.6	7.3	5.1
	DBStd	4.84	3.08	2.92	2.73	2.69	2.69	2.33	2.26	2.09	2.04	2.50	2.76	3.34
	HDD10.0	801	171	151	124	70	21	1	0	0	1	22	87	154
	HDD18.3	3186	429	383	381	309	232	139	89	93	148	239	331	411
	CDD10.0	667	0	0	2	11	47	112	175	169	103	41	6	1
	CDD18.3	11	0	0	0	0	0	1	6	4	0	0	0	0
	CDH23.3	72	0	0	0	0	1	11	37	23	1	0	0	0
	CDH26.7	4	0	0	0	0	0	0	2	2	0	0	0	0
Wind	WSAvg	4.2	5.0	4.9	4.6	4.3	4.1	3.7	3.4	3.5	3.7	4.4	4.4	4.7
Precipitation	PrecAvg	983	108	82	69	66	62	65	60	74	69	110	110	107
	PrecMax	1369	204	194	145	172	127	180	152	189	166	194	208	195
	PrecMin	747	14	11	16	9	13	14	8	12	15	40	31	32
	PrecStd	145	45	49	30	42	31	38	36	45	40	42	47	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	11.7	15.3	19.9	22.3	25.1	26.5	26.1	22.0	18.0	14.1	12.3
		MCWB	10.9	9.6	10.8	13.6	16.2	17.8	18.6	18.8	16.9	15.0	13.6	11.7
	2%	DB	10.7	10.5	12.6	16.2	19.8	22.1	24.3	23.0	20.0	16.0	13.0	11.6
		MCWB	10.1	9.4	9.4	11.7	14.7	16.3	17.9	17.7	16.0	14.2	12.4	11.1
	5%	DB	9.7	9.6	11.0	14.0	17.8	20.3	22.3	20.9	18.3	15.0	12.2	10.8
		MCWB	9.2	8.8	8.9	10.4	13.8	15.5	16.8	16.4	15.1	13.8	11.6	10.3
	10%	DB	8.9	8.7	10.0	12.3	15.8	18.4	20.4	19.3	17.0	14.2	11.5	9.9
		MCWB	8.4	7.9	8.6	9.3	12.5	14.5	15.9	15.6	14.4	13.2	10.8	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	10.6	11.5	14.2	17.2	18.8	19.5	20.1	18.1	16.1	13.7	12.0
		MCDB	11.3	11.1	13.6	17.8	20.5	23.1	24.7	24.1	20.4	17.0	13.8	12.0
	2%	WB	10.3	9.7	10.3	12.2	15.3	17.1	18.4	18.3	16.9	15.0	12.6	11.3
		MCDB	10.5	10.1	11.6	15.4	18.6	20.7	23.0	21.3	18.8	15.5	12.8	11.5
	5%	WB	9.4	9.0	9.6	10.9	14.1	16.1	17.4	17.3	15.9	14.2	11.8	10.5
		MCDB	9.6	9.4	10.6	13.1	17.1	19.2	21.1	19.7	17.4	14.7	12.1	10.7
	10%	WB	8.5	8.1	8.8	9.9	12.9	15.0	16.5	16.5	15.1	13.4	10.9	9.5
		MCDB	8.9	8.6	9.7	11.7	15.3	17.8	19.3	18.5	16.4	14.0	11.3	9.8
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.9	6.1	7.3	7.6	7.7	7.7	7.2	6.9	5.6	4.8	4.5
		MCDBR	5.1	5.2	7.5	9.9	10.5	10.7	11.1	9.5	8.5	5.7	4.7	4.5
		MCWBR	5.2	4.5	5.3	6.3	6.4	6.3	6.0	5.2	5.3	4.3	4.4	4.8
	5% WB	MCDBR	5.1	5.0	6.3	8.6	9.3	9.2	9.5	8.0	7.1	5.0	4.4	4.6
		MCWBR	5.3	4.8	5.1	5.9	6.1	6.0	5.8	5.1	5.1	4.5	4.5	4.9
Clear-Sky Solar Irradiance	taub	0.321	0.335	0.367	0.381	0.385	0.377	0.374	0.364	0.356	0.345	0.319	0.311	
	taud	2.373	2.396	2.309	2.288	2.311	2.362	2.375	2.422	2.436	2.442	2.424	2.343	
	Ebn at Noon	698	794	828	858	870	879	875	868	835	771	697	643	
	Edh at Noon	64	80	105	119	122	117	114	103	91	76	60	56	
All-Sky Solar Radiation	RadAvg	0.81	1.53	2.73	4.27	5.19	5.62	5.32	4.43	3.35	1.88	1.00	0.64	
	RadStd	0.07	0.17	0.35	0.41	0.27	0.57	0.42	0.36	0.22	0.15	0.10	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (59 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page