

YEOVILTON, United Kingdom

WMO: 038530

Lat: 51.0064N

Lon: 2.6428W

Elev: 75

StdP: 14.66

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.3	27.2	20.9	15.7	28.3	23.6	17.9	30.7	31.8	50.2	28.9	49.6	2.4	50	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	78.9	65.0	75.1	63.4	72.0	61.9	66.6	75.4	64.8	72.1	63.5	69.6	9.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	88.0	69.4	62.1	83.7	67.3	60.9	80.2	66.1	31.1	75.7	29.8	72.3	28.8	69.7	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.7	22.7	20.0	DB	18.5	84.1	3.6	4.2	15.9	87.0	13.8	89.5	11.8	91.8	9.2	94.8
			WB	17.8	71.0	3.5	3.7	15.3	73.7	13.2	75.8	11.3	77.9	8.7	80.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	41.7	41.9	44.4	48.1	53.5	58.7	62.4	62.0	57.8	52.7	46.3	42.4
	DBStd	9.23	6.33	5.71	5.21	4.92	4.84	4.22	4.11	4.20	4.12	5.44	6.09	7.10
	HDD50	1209	263	231	182	91	19	0	0	0	1	35	139	248
	HDD65	5144	724	647	638	508	357	194	102	112	217	382	561	702
	CDD50	1594	4	3	9	33	128	263	386	373	236	119	28	12
	CDD65	51	0	0	0	0	1	6	22	20	2	0	0	0
	CDH74	442	0	0	0	1	10	70	212	135	13	1	0	0
	CDH80	78	0	0	0	0	0	11	38	29	0	0	0	0
(14) Wind	WSAvg	8.6	9.9	9.8	9.4	8.7	8.5	8.0	7.6	7.5	7.5	8.5	8.3	9.1
(15) Precipitation	PrecAvg	28.6	2.8	2.2	2.1	1.8	2.1	2.2	2.2	2.3	2.6	2.5	2.7	3.1
	PrecMax	35.1	5.2	5.4	4.5	5.2	6.7	5.5	6.1	4.5	6.3	7.4	5.5	6.5
	PrecMin	22.1	0.4	0.1	0.7	0.1	0.2	0.2	0.4	0.7	0.3	0.2	0.8	0.6
	PrecStd	3.6	1.3	1.5	0.9	1.1	1.3	1.3	1.5	1.1	1.6	1.7	1.3	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.9	56.2	62.1	70.6	75.4	81.3	84.4	83.7	76.1	67.8	60.7	57.5
		MCWB	52.9	51.5	53.4	58.8	62.6	66.0	65.5	65.9	63.9	61.4	57.8	54.7
	2%	DB	54.1	53.7	57.4	63.8	70.7	75.3	79.7	77.5	71.4	64.2	58.9	56.0
		MCWB	51.6	50.5	51.2	54.5	59.7	63.2	65.4	65.1	62.2	59.1	56.2	53.6
	5%	DB	52.7	52.2	54.7	59.8	66.8	71.4	75.5	73.1	68.3	62.4	57.2	54.6
		MCWB	50.2	49.3	50.1	52.3	58.3	61.0	63.5	62.9	60.6	58.1	54.5	52.3
	10%	DB	51.1	50.6	52.8	56.8	63.0	67.9	71.9	70.1	65.9	60.9	55.7	53.0
		MCWB	48.7	47.8	48.9	50.6	55.9	59.5	61.9	61.5	59.3	57.2	53.0	50.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	52.9	54.4	59.7	64.5	68.2	69.2	68.8	66.2	62.6	58.5	55.6
		MCDB	55.2	55.0	59.4	68.2	71.8	77.0	79.1	78.4	72.5	66.4	60.0	56.7
	2%	WB	52.3	51.2	52.5	55.6	61.3	64.2	66.4	66.3	63.8	60.6	56.7	54.2
		MCDB	53.9	53.2	56.0	62.0	68.0	72.8	76.9	73.8	68.9	63.2	58.4	55.8
	5%	WB	50.5	49.8	51.1	53.3	59.0	62.2	64.7	64.6	62.2	59.2	55.1	52.7
		MCDB	52.4	51.8	54.0	58.1	65.5	69.4	72.9	70.5	66.4	61.7	57.0	54.5
	10%	WB	49.0	48.3	49.6	51.7	57.0	60.5	63.1	63.2	60.8	57.8	53.3	50.8
		MCDB	50.9	50.4	52.2	55.7	62.3	66.3	69.8	68.2	64.7	60.4	55.4	52.8
(35) Mean Daily Temperature Range	MDBR		10.7	11.6	13.9	15.9	16.4	16.3	16.5	16.0	16.0	13.4	11.9	10.8
	5% DB	MCDBR	10.7	11.8	16.4	20.9	22.6	22.8	24.0	21.0	19.2	13.1	10.8	9.5
		MCWBR	10.0	9.8	11.6	13.2	13.5	12.7	12.0	10.5	11.4	9.3	9.5	9.1
	5% WB	MCDBR	10.7	11.1	14.4	18.1	19.7	19.3	20.2	17.1	16.0	11.6	10.4	9.5
		MCWBR	10.4	9.9	10.9	12.4	12.5	11.7	11.3	9.9	10.6	9.3	9.6	9.3
(40) Clear-Sky Solar Irradiance	taub		0.329	0.343	0.377	0.395	0.399	0.392	0.388	0.377	0.367	0.355	0.328	0.318
	taud		2.349	2.364	2.268	2.237	2.260	2.310	2.328	2.377	2.397	2.409	2.398	2.328
	Ebn at Noon		216	247	258	267	272	274	273	271	260	239	216	199
	Edh at Noon		21	26	35	40	41	39	38	34	30	25	19	18
(44) All-Sky Solar Radiation	RadAvg		254	482	858	1336	1627	1764	1664	1387	1046	588	314	200
	RadStd		23	56	109	134	84	180	138	115	71	47	30	24

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (71 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page