

YEOVILTON, United Kingdom

WMO: 038530

Lat: 51.0064N

Lon: 2.6428W

Elev: 23

StdP: 101.05

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	-2.7	-6.1	2.2	-2.0	-4.7	2.6	-0.7	14.2	10.1	12.9	9.8	1.1	50	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	26.0	18.4	23.9	17.4	22.2	16.6	19.2	24.1	18.2	22.3	17.5	20.9	4.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.5	12.6	20.8	16.7	12.0	19.6	16.1	11.5	19.0	54.6	24.3	51.5	22.4	49.2	20.9	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
11.5	10.1	8.9	DB	-7.5	28.9	2.0	2.3	-8.9	30.6	-10.1	31.9	-11.2	33.2	-12.6	34.9	
			WB	-7.9	21.7	2.0	2.1	-9.3	23.1	-10.4	24.4	-11.5	25.5	-12.9	27.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	5.4	5.5	6.9	8.9	11.9	14.9	16.9	16.7	14.4	11.5	7.9	5.8	(6)
(7)		DBStd	5.13	3.52	3.17	2.89	2.73	2.69	2.34	2.28	2.33	2.29	3.02	3.39	3.95	(7)
(8)		HDD10.0	672	146	128	101	51	11	0	0	0	1	19	77	138	(8)
(9)		HDD18.3	2858	402	359	354	282	198	108	57	62	121	212	312	390	(9)
(10)		CDD10.0	886	2	2	5	18	71	146	214	207	131	66	16	7	(10)
(11)		CDD18.3	28	0	0	0	0	1	3	12	11	1	0	0	0	(11)
(12)		CDH23.3	246	0	0	0	1	6	39	118	75	7	1	0	0	(12)
(13)		CDH26.7	43	0	0	0	0	0	6	21	16	0	0	0	0	(13)
(14)	Wind	WSAvg	3.8	4.4	4.4	4.2	3.9	3.8	3.6	3.4	3.3	3.3	3.8	3.7	4.1	(14)
(15)	Precipitation	PrecAvg	727	72	57	54	46	53	55	57	58	65	64	68	79	(15)
(16)		PrecMax	891	132	138	114	133	171	140	155	115	161	188	140	166	(16)
(17)		PrecMin	562	9	2	19	2	6	5	10	17	8	6	20	14	(17)
(18)		PrecStd	91	34	37	24	28	33	32	37	29	40	42	32	40	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	13.4	16.7	21.4	24.1	27.4	29.1	28.7	24.5	19.9	16.0	14.2	(19)
(20)			MCWB	11.6	10.8	11.9	14.9	17.0	18.9	18.6	18.9	17.7	16.3	14.3	12.6	(20)
(21)		2%	DB	12.3	12.1	14.1	17.7	21.5	24.0	26.5	25.3	21.9	17.9	14.9	13.3	(21)
(22)			MCWB	10.9	10.3	10.6	12.5	15.4	17.3	18.5	18.4	16.8	15.1	13.4	12.0	(22)
(23)		5%	DB	11.5	11.2	12.6	15.4	19.4	21.9	24.2	22.8	20.2	16.9	14.0	12.6	(23)
(24)			MCWB	10.1	9.6	10.0	11.3	14.6	16.1	17.5	17.2	15.9	14.5	12.5	11.3	(24)
(25)		10%	DB	10.6	10.3	11.6	13.8	17.2	20.0	22.2	21.2	18.9	16.0	13.1	11.6	(25)
(26)			MCWB	9.3	8.8	9.4	10.4	13.3	15.3	16.6	16.4	15.2	14.0	11.7	10.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.6	12.4	15.4	18.0	20.1	20.6	20.4	19.0	17.0	14.7	13.1	(27)
(28)			MCDWB	12.9	12.8	15.2	20.1	22.1	25.0	26.2	25.8	22.5	19.1	15.6	13.7	(28)
(29)		2%	WB	11.3	10.7	11.4	13.1	16.3	17.9	19.1	19.1	17.7	15.9	13.7	12.4	(29)
(30)			MCDWB	12.2	11.8	13.4	16.7	20.0	22.7	25.0	23.2	20.5	17.4	14.7	13.2	(30)
(31)		5%	WB	10.3	9.9	10.6	11.9	15.0	16.8	18.2	18.1	16.8	15.1	12.8	11.5	(31)
(32)			MCDWB	11.3	11.0	12.2	14.5	18.6	20.8	22.7	21.4	19.1	16.5	13.9	12.5	(32)
(33)		10%	WB	9.4	9.1	9.8	10.9	13.9	15.8	17.3	17.3	16.0	14.3	11.8	10.5	(33)
(34)			MCDWB	10.5	10.2	11.2	13.2	16.8	19.1	21.0	20.1	18.2	15.8	13.0	11.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	6.4	7.7	8.8	9.1	9.0	9.2	8.9	8.9	7.4	6.6	6.0	(35)
(36)			MCDBR	5.9	6.5	9.1	11.6	12.6	12.6	13.3	11.6	10.7	7.3	6.0	5.3	(36)
(37)			MCWBR	5.6	5.4	6.4	7.4	7.5	7.0	6.7	5.9	6.3	5.2	5.3	5.0	(37)
(38)		5% WB	MCDBR	5.9	6.2	8.0	10.0	10.9	10.7	11.2	9.5	8.9	6.5	5.8	5.3	(38)
(39)			MCWBR	5.8	5.5	6.1	6.9	6.9	6.5	6.3	5.5	5.9	5.2	5.4	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.343	0.377	0.395	0.399	0.392	0.388	0.377	0.367	0.355	0.328	0.318	(40)	
(41)		taud	2.349	2.364	2.268	2.237	2.260	2.310	2.328	2.377	2.397	2.409	2.398	2.328	(41)	
(42)		Ebn at Noon	682	779	813	843	856	864	861	853	820	755	680	628	(42)	
(43)		Edh at Noon	65	83	109	125	128	123	119	108	95	78	61	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.80	1.52	2.70	4.21	5.13	5.56	5.25	4.37	3.30	1.85	0.99	0.63	(44)	
(45)		RadStd	0.07	0.17	0.34	0.42	0.27	0.57	0.43	0.36	0.22	0.15	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page