

BOURNEMOUTH INTL, United KingdomWMO: **038620**Lat: **50.7794N**Lon: **1.8361W**Elev: **12**StdP: **101.19**Time Zone: **0.00 (EUW)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.3	-3.0	-6.3	2.2	-2.4	-4.9	2.5	-1.0	13.5	9.8	12.2	9.8	1.5	350	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	26.1	18.7	24.1	17.7	22.6	17.0	19.6	24.3	18.6	22.6	17.8	21.2	4.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	12.9	20.9	17.1	12.2	19.9	16.4	11.7	19.2	55.6	24.4	52.6	22.7	50.1	21.3	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.0	9.7	8.7	-7.5	29.0	1.6	2.1	-8.7	30.5	-9.6	31.8	-10.4	33.0	-11.6	34.5
			-7.9	21.3	1.6	1.3	-9.0	22.2	-9.9	23.0	-10.8	23.7	-11.9	24.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	5.3	5.4	6.9	9.0	12.0	14.9	17.0	16.7	14.3	11.5	8.0	5.8
(7)		DBStd	5.15	3.46	3.21	2.81	2.85	2.74	2.35	2.24	2.26	2.33	3.03	3.37	3.80
(8)		HDD10.0	678	149	131	102	51	11	0	0	0	1	20	77	137
(9)		HDD18.3	2853	405	363	356	281	197	106	54	60	122	212	309	389
(10)		CDD10.0	896	2	2	4	20	73	147	217	209	130	67	17	7
(11)		CDD18.3	28	0	0	0	0	1	3	13	11	1	0	0	0
(12)		CDH23.3	252	0	0	0	1	7	37	125	76	6	0	0	0
(13)		CDH26.7	38	0	0	0	0	0	4	20	14	0	0	0	0
(14)	Wind	WSAvg	4.1	4.7	4.5	4.3	4.0	4.1	3.9	3.7	3.6	3.6	4.0	4.1	4.3
(15)	Precipitation	PrecAvg	812	91	63	62	53	54	55	45	56	68	87	95	91
(16)		PrecMax	1398	228	184	135	151	135	221	137	137	223	216	235	208
(17)		PrecMin	509	10	6	1	1	11	0	6	5	7	3	19	23
(18)		PrecStd	149	49	42	31	35	32	39	29	34	46	51	52	48
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	13.2	16.6	22.2	24.4	27.0	29.1	28.6	24.1	19.9	16.0	13.9
(20)			MCWB	11.5	10.6	11.2	14.9	17.0	18.9	19.3	20.4	18.4	16.3	14.4	12.6
(21)		2%	DB	12.1	11.8	14.3	18.0	21.8	24.0	26.5	25.3	22.0	18.1	14.9	13.1
(22)			MCWB	11.0	10.2	10.6	12.5	15.8	17.4	18.7	18.8	17.2	15.2	13.6	12.1
(23)		5%	DB	11.3	11.0	12.7	15.7	19.7	22.0	24.4	23.2	20.3	17.1	14.1	12.5
(24)			MCWB	10.2	9.5	9.8	11.5	14.9	16.4	17.9	17.7	16.0	14.9	12.8	11.5
(25)		10%	DB	10.6	10.3	11.5	14.0	17.5	20.3	22.6	21.7	19.1	16.3	13.4	11.7
(26)			MCWB	9.5	8.9	9.3	10.4	13.4	15.5	17.1	16.9	15.5	14.4	12.0	10.6
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.0	11.6	12.3	15.3	18.4	20.0	20.6	21.4	19.2	17.0	14.9	13.1
(28)			MCDWB	12.5	12.2	14.5	20.5	22.5	25.3	26.5	26.4	22.3	18.6	15.4	13.5
(29)		2%	WB	11.2	10.7	11.2	13.3	16.6	18.3	19.4	19.6	18.0	16.2	13.8	12.4
(30)			MCDWB	11.8	11.5	13.0	17.2	20.5	22.6	24.9	23.8	20.6	17.5	14.6	13.0
(31)		5%	WB	10.5	10.0	10.6	12.0	15.2	17.1	18.4	18.6	17.1	15.5	13.1	11.7
(32)			MCDWB	11.2	10.7	12.1	14.7	18.7	21.0	23.1	21.9	19.2	16.7	13.9	12.4
(33)		10%	WB	9.6	9.2	9.9	11.1	14.0	16.0	17.6	17.7	16.4	14.8	12.2	10.7
(34)			MCDWB	10.4	10.1	11.2	13.3	16.8	19.3	21.5	20.4	18.4	16.0	13.2	11.5
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.9	8.2	9.3	9.4	9.3	9.6	9.5	9.6	8.1	7.2	6.4
(36)			MCDBR	5.8	6.6	9.8	12.2	12.9	12.4	13.4	12.1	11.2	7.9	6.2	5.0
(37)			MCWBR	5.6	5.4	6.9	7.6	7.7	7.0	6.9	6.5	7.1	5.7	5.3	5.1
(38)		5% WB	MCDWB	5.8	6.0	8.1	10.3	11.6	10.8	11.6	10.2	9.5	6.8	5.7	5.1
(39)			MCWBR	5.8	5.4	6.2	6.9	7.5	6.6	6.6	6.1	6.7	5.6	5.4	5.3
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.347	0.383	0.400	0.403	0.398	0.391	0.384	0.373	0.361	0.333	0.322	
(41)		taud	2.366	2.377	2.276	2.256	2.289	2.333	2.357	2.397	2.416	2.425	2.417	2.350	
(42)		Ebn at Noon	684	778	809	839	853	860	859	847	816	752	681	632	
(43)		Edh at Noon	65	83	108	123	125	121	116	106	94	78	61	57	
(44)	All-Sky Solar Radiation	RadAvg	0.82	1.54	2.75	4.35	5.25	5.77	5.47	4.58	3.41	1.92	1.01	0.65	
(45)		RadStd	0.07	0.18	0.35	0.41	0.30	0.55	0.43	0.35	0.24	0.15	0.11	0.08	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (69 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page