

LEE-ON-SOLENT, United Kingdom

WMO: 038740

Lat: 50.807N

Lon: 1.209W

Elev: 43

StdP: 14.67

Time Zone: 0.00 (EUW)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	28.4	30.7	21.7	16.3	33.4	24.2	18.4	34.3	44.7	48.8	41.8	48.9	9.6	30	0.690

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	77.4	65.6	74.3	64.4	71.8	63.2	67.8	73.6	66.1	71.7	64.7	69.8	10.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	94.7	70.1	63.9	89.2	68.5	62.6	85.2	67.0	32.1	73.6	30.8	71.9	29.7	70.0	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.4	33.6	29.9	DB	24.7	82.8	2.8	2.9	22.7	84.9	21.0	86.6	19.4	88.2	17.3	90.2	(4)
(5)			WB	23.6	72.0	2.7	4.5	21.6	75.2	20.1	77.8	18.5	80.3	16.6	83.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.9	43.0	43.0	45.8	50.0	55.3	60.3	64.2	64.4	60.5	55.3	48.7	43.4
	DBStd	9.13	5.36	4.78	4.49	4.95	4.62	3.80	3.76	3.43	3.61	4.66	5.20	5.85
	HDD50	926	218	197	139	58	7	0	0	0	0	13	83	211
	HDD65	4504	681	616	594	451	301	148	62	51	140	301	490	669
	CDD50	1984	2	1	10	58	173	310	439	447	315	177	44	8
	CDD65	84	0	0	0	0	2	8	36	33	5	0	0	0
	CDH74	304	0	0	0	1	13	43	141	96	9	1	0	0
	CDH80	34	0	0	0	0	0	4	16	14	0	0	0	0
Wind	WSAvg	13.6	16.0	15.1	13.5	12.5	13.1	12.8	12.7	12.4	12.4	14.3	14.1	15.0
Precipitation	PrecAvg	32.0	3.7	2.6	2.1	2.1	1.9	2.1	1.9	2.2	2.3	3.7	3.9	3.6
	PrecMax	43.2	8.6	6.3	5.5	5.4	4.4	5.5	4.6	5.4	5.5	6.7	7.9	7.2
	PrecMin	24.7	0.7	0.2	0.2	0.0	0.4	0.4	0.4	0.2	0.2	1.2	1.0	1.1
	PrecStd	5.0	1.8	1.7	1.1	1.3	1.1	1.3	1.1	1.3	1.4	1.5	2.0	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.8	54.1	61.2	70.0	75.7	79.2	82.4	81.8	75.2	68.1	60.4	55.5
		MCWB	51.3	50.1	52.1	56.7	61.6	65.9	66.5	67.8	66.0	60.3	57.9	53.4
	2%	DB	52.3	52.0	56.9	63.9	70.1	73.8	77.9	76.2	71.2	64.5	58.3	54.0
		MCWB	50.3	49.1	50.1	54.3	59.9	63.0	65.5	65.6	63.0	59.9	55.5	52.1
	5%	DB	51.3	50.7	54.1	60.2	66.3	70.2	74.4	73.2	68.9	62.9	57.1	52.9
		MCWB	49.4	47.9	48.9	52.2	58.2	61.6	64.6	64.7	61.8	59.3	54.5	51.0
	10%	DB	50.0	49.4	52.0	57.2	63.0	67.5	71.4	70.9	66.7	61.6	55.8	51.6
		MCWB	48.0	46.9	48.0	51.0	56.0	60.1	63.7	63.2	60.6	58.4	53.2	49.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	52.8	53.4	58.6	64.8	70.4	69.6	71.8	67.2	63.2	58.3	54.1
		MCDB	53.0	53.1	58.1	66.6	72.0	73.2	77.0	75.6	71.4	65.4	59.4	54.8
	2%	WB	51.1	50.2	51.4	55.3	61.3	65.1	67.3	67.7	64.8	61.6	56.4	52.7
		MCDB	51.9	51.2	54.8	61.3	67.7	70.9	74.2	73.6	68.9	63.3	57.7	53.7
	5%	WB	49.8	48.6	50.1	53.5	59.0	62.9	65.8	66.1	63.4	60.3	55.1	51.5
		MCDB	51.0	49.8	52.7	58.3	65.0	68.1	72.4	71.2	67.1	62.2	56.7	52.6
	10%	WB	48.5	47.4	49.1	52.0	56.9	61.3	64.3	64.7	62.1	59.1	53.7	49.9
		MCDB	49.8	48.9	51.3	55.8	61.4	65.8	70.1	69.1	65.5	61.2	55.4	51.4
Mean Daily Temperature Range	5% DB	MDBR	7.7	8.6	10.6	12.3	12.5	12.2	12.1	12.1	12.0	10.1	8.9	8.1
		MCDBR	7.0	8.8	13.8	17.3	18.3	17.5	18.1	16.1	15.0	10.3	7.8	6.5
		MCWBR	6.7	6.9	9.1	9.5	10.6	10.0	9.4	8.9	9.0	7.3	6.8	6.8
	5% WB	MCDBR	6.8	7.4	11.2	14.1	16.6	14.6	15.2	13.4	12.7	8.6	6.7	6.5
		MCWBR	7.1	7.0	8.4	8.7	10.7	9.9	9.3	9.0	8.9	7.2	6.8	7.0
Clear-Sky Solar Irradiance	taub	0.333	0.349	0.386	0.404	0.407	0.404	0.397	0.391	0.377	0.363	0.335	0.324	
	taud	2.369	2.377	2.270	2.246	2.285	2.322	2.348	2.385	2.410	2.425	2.415	2.357	
	Ebn at Noon	216	246	256	265	269	271	271	267	257	238	214	200	
	Edh at Noon	21	26	35	40	40	39	37	34	30	25	20	18	
All-Sky Solar Radiation	RadAvg	263	489	871	1382	1665	1843	1749	1464	1084	613	320	206	
	RadStd	20	59	111	131	100	172	139	110	82	50	36	24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page