

BRIGHTON CITY, United Kingdom

WMO: 038760

Lat: 50.8361N

Lon: 0.2936W

Elev: 7

StdP: 14.69

Time Zone: 0.00 (EUW)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	26.8	29.2	22.0	16.5	30.8	24.4	18.5	31.9	32.4	47.8	29.4	46.9	6.7	0	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	75.7	65.6	72.6	64.2	70.1	62.9	67.2	73.4	65.6	70.6	64.3	68.5	10.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.8	91.9	69.6	63.6	88.1	68.1	62.5	84.6	66.8	31.6	73.8	30.4	70.7	29.5	68.6	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	24.8	22.2	22.1	81.4	2.5	3.7	20.3	84.0	18.9	86.2	17.5	88.3	15.7	91.0		
(5)			21.6	70.9	2.5	3.1	19.7	73.1	18.3	74.9	16.8	76.6	15.0	78.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.3	41.6	41.6	44.4	48.3	53.7	58.7	62.3	62.1	58.7	53.6	47.2	42.8		
	DBStd	8.99	5.53	5.12	4.65	4.95	4.74	3.95	3.86	3.33	3.88	5.03	5.74	6.16		
	HDD50	1155	263	236	179	86	17	0	0	0	0	24	118	232		
	HDD65	5036	727	655	639	500	351	193	104	102	191	354	533	687		
	CDD50	1634	1	1	5	36	132	262	381	375	262	136	34	9		
	CDD65	39	0	0	0	0	1	4	20	11	3	0	0	0		
	CDH74	171	0	0	0	0	5	28	95	37	6	0	0	0		
	CDH80	14	0	0	0	0	0	1	10	3	0	0	0	0		
(14) Wind	WSAvg	10.4	11.3	11.1	10.5	9.8	10.4	9.8	9.8	9.7	9.8	10.5	11.0	11.2		
(15) Precipitation	PrecAvg	28.5	2.9	2.1	2.0	2.0	1.6	2.0	1.8	2.2	2.4	2.9	3.3	2.8		
	PrecMax	43.0	7.0	5.7	5.3	5.0	4.1	6.4	4.0	4.9	6.1	8.5	7.7	5.9		
	PrecMin	19.4	0.0	0.0	0.0	0.1	0.3	0.2	0.0	0.0	0.3	0.2	0.6	0.1		
	PrecStd	5.7	1.7	1.6	1.1	1.3	1.1	1.7	1.1	1.3	1.5	1.9	2.1	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	53.6	60.0	69.4	73.7	77.9	81.1	78.3	74.3	66.5	60.7	55.8		
		MCWB	51.3	49.4	51.9	57.4	62.4	65.6	67.1	69.0	66.3	61.8	58.6	53.9		
	2%	DB	52.1	51.5	56.0	62.9	68.5	73.0	76.5	73.6	70.0	64.1	58.7	54.7		
		MCWB	50.3	48.9	50.0	54.4	60.0	63.7	65.4	65.6	63.6	60.6	56.4	53.0		
	5%	DB	51.1	50.3	53.1	58.7	64.9	69.2	73.0	70.8	68.0	62.7	57.4	53.5		
		MCWB	49.4	48.0	48.6	52.0	58.2	61.5	64.7	63.9	62.2	59.6	55.1	51.8		
	10%	DB	49.9	49.2	51.2	56.0	61.7	66.6	70.0	68.6	66.1	61.3	55.9	52.2		
		MCWB	48.3	47.1	47.9	51.0	56.3	60.2	63.1	62.8	61.3	58.4	53.5	50.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	51.3	53.0	59.1	64.3	68.0	69.0	69.8	67.3	63.1	59.3	54.8		
		MCDB	52.8	52.1	58.0	67.2	70.3	75.7	77.4	76.7	71.8	65.3	60.0	55.2		
	2%	WB	51.0	49.9	51.2	55.4	61.0	64.8	67.1	67.0	65.2	61.6	57.1	53.6		
		MCDB	51.8	50.7	54.3	61.9	66.7	71.1	74.3	71.9	68.6	63.4	58.2	54.4		
	5%	WB	49.9	48.8	50.0	53.3	59.0	62.8	65.5	65.4	63.7	60.4	55.6	52.2		
		MCDB	50.8	49.8	52.1	57.2	63.9	67.8	71.4	69.2	66.7	62.1	57.1	53.3		
	10%	WB	48.7	47.6	48.8	51.9	57.1	61.2	64.0	64.1	62.5	59.2	53.9	50.8		
		MCDB	49.8	48.9	50.6	54.8	60.8	65.4	68.7	67.5	65.2	61.0	55.6	52.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	10.0	11.8	13.3	13.4	13.4	13.0	13.1	13.9	12.1	10.7	9.9		
		MCDBR	9.2	10.3	14.4	17.1	17.5	18.2	18.6	15.8	15.7	11.5	9.8	7.6		
		MCWBR	9.0	8.7	10.3	10.9	10.8	11.1	10.4	9.8	10.7	9.1	9.0	7.8		
	5% WB	MCDBR	8.8	8.8	11.8	14.5	15.8	15.8	15.7	13.4	13.7	10.2	9.4	7.8		
		MCWBR	8.9	8.4	9.2	10.2	10.5	10.4	9.8	9.4	10.3	9.0	9.1	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.350	0.387	0.404	0.410	0.409	0.403	0.396	0.381	0.365	0.338	0.324		
	taud		2.370	2.374	2.267	2.247	2.287	2.314	2.338	2.373	2.405	2.424	2.416	2.363		
	Ebn at Noon		216	246	255	265	269	269	269	265	256	237	213	200		
	Edh at Noon		21	26	35	39	40	39	37	35	30	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		262	488	868	1380	1658	1836	1745	1459	1083	613	316	205		
	RadStd		20	61	109	129	103	167	140	108	79	52	35	24		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page