

BRIGHTON CITY, United Kingdom

WMO: 038760

Lat: 50.8361N

Lon: 0.2936W

Elev: 2

StdP: 101.30

Time Zone: 0.00 (EUW)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.9	-1.6	-5.6	2.4	-0.7	-4.2	2.6	-0.1	14.5	8.8	13.1	8.3	3.0	0	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	24.3	18.7	22.6	17.9	21.1	17.2	19.6	23.0	18.7	21.4	18.0	20.3	4.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.1	20.9	17.6	12.6	20.0	16.9	12.1	19.4	55.7	23.2	52.9	21.5	50.6	20.3	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.1	9.9	DB	-5.5	27.4	1.4	2.1	-6.5	28.9	-7.3	30.1	-8.0	31.3	-9.0	32.8	(4)
(5)			WB	-5.8	21.6	1.4	1.7	-6.8	22.8	-7.6	23.8	-8.4	24.8	-9.4	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	5.3	5.3	6.9	9.1	12.1	14.8	16.8	16.7	14.9	12.0	8.5	6.0	(6)	
	DBStd	4.99	3.07	2.85	2.58	2.75	2.63	2.19	2.14	1.85	2.15	2.80	3.19	3.42	(7)	
	HDD10.0	642	146	131	99	48	9	0	0	0	0	13	66	129	(8)	
	HDD18.3	2798	404	364	355	278	195	107	58	57	106	197	296	382	(9)	
	CDD10.0	908	1	1	3	20	73	146	212	208	146	76	19	5	(10)	
	CDD18.3	22	0	0	0	0	1	2	11	6	2	0	0	0	(11)	
	CDH23.3	95	0	0	0	0	3	16	53	21	3	0	0	0	(12)	
	CDH26.7	8	0	0	0	0	0	1	6	2	0	0	0	0	(13)	
(14) Wind	WSAvg	4.7	5.1	5.0	4.7	4.4	4.6	4.4	4.4	4.3	4.4	4.7	4.9	5.0	(14)	
(15) Precipitation	PrecAvg	723	73	53	50	51	41	52	46	55	61	74	84	71	(15)	
	PrecMax	1091	179	144	135	127	105	163	102	124	156	216	196	149	(16)	
	PrecMin	494	0	0	0	2	8	6	1	0	8	5	14	2	(17)	
	PrecStd	146	43	41	29	33	28	43	29	34	39	47	54	43	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	12.0	15.6	20.8	23.1	25.5	27.3	25.7	23.5	19.2	15.9	13.2	(19)	
		MCWB	10.7	9.7	11.1	14.1	16.9	18.7	19.5	20.6	19.0	16.6	14.8	12.2	(20)	
	2%	DB	11.2	10.9	13.3	17.2	20.3	22.8	24.7	23.1	21.1	17.8	14.8	12.6	(21)	
		MCWB	10.2	9.4	10.0	12.4	15.6	17.6	18.6	18.7	17.5	15.9	13.5	11.7	(22)	
	5%	DB	10.6	10.1	11.7	14.8	18.3	20.7	22.8	21.6	20.0	17.1	14.1	11.9	(23)	
		MCWB	9.7	8.9	9.2	11.1	14.5	16.4	18.1	17.7	16.8	15.3	12.8	11.0	(24)	
	10%	DB	10.0	9.6	10.7	13.3	16.5	19.2	21.1	20.3	18.9	16.3	13.3	11.2	(25)	
		MCWB	9.0	8.4	8.8	10.6	13.5	15.7	17.3	17.1	16.3	14.7	11.9	10.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	10.7	11.7	15.1	17.9	20.0	20.5	21.0	19.6	17.3	15.2	12.7	(27)	
		MCDB	11.6	11.1	14.4	19.5	21.3	24.3	25.2	24.8	22.1	18.5	15.6	12.9	(28)	
	2%	WB	10.6	9.9	10.7	13.0	16.1	18.2	19.5	19.4	18.4	16.4	14.0	12.0	(29)	
		MCDB	11.0	10.4	12.4	16.6	19.3	21.7	23.5	22.2	20.3	17.4	14.6	12.5	(30)	
	5%	WB	9.9	9.3	10.0	11.8	15.0	17.1	18.6	18.5	17.6	15.8	13.1	11.2	(31)	
		MCDB	10.4	9.9	11.2	14.0	17.7	19.9	21.9	20.7	19.3	16.7	13.9	11.8	(32)	
	10%	WB	9.3	8.7	9.3	11.0	14.0	16.2	17.8	17.8	16.9	15.1	12.2	10.4	(33)	
		MCDB	9.9	9.4	10.3	12.7	16.0	18.6	20.4	19.7	18.4	16.1	13.1	11.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	5.6	6.6	7.4	7.4	7.5	7.2	7.3	7.7	6.7	6.0	5.5	(35)	
		MCDBR	5.1	5.7	8.0	9.5	9.7	10.1	10.3	8.8	8.7	6.4	5.5	4.2	(36)	
	5% WB	MCWBR	5.0	4.8	5.7	6.1	6.0	6.2	5.8	5.5	6.0	5.0	5.0	4.3	(37)	
		MCWBR	4.9	4.9	6.5	8.1	8.8	8.8	8.7	7.4	7.6	5.7	5.2	4.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.334	0.350	0.387	0.404	0.410	0.409	0.403	0.396	0.381	0.365	0.338	0.324	(40)	
		taud	2.370	2.374	2.267	2.247	2.287	2.314	2.338	2.373	2.405	2.424	2.416	2.363	(41)	
	Ebn at Noon		681	774	804	834	847	849	848	835	807	747	673	629	(42)	
		Edh at Noon	65	83	109	124	125	123	118	109	95	78	62	56	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.83	1.54	2.74	4.35	5.23	5.79	5.50	4.60	3.41	1.93	1.00	0.65	(44)	
	RadStd		0.06	0.19	0.34	0.41	0.32	0.53	0.44	0.34	0.25	0.16	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page