

NEWHAVEN LH, United Kingdom

WMO: 038800

Lat: 50.7818N

Lon: 0.0571E

Elev: 5

StdP: 101.26

Time Zone: 0.00 (EUW)

Period: 90-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.8	-0.3	-4.7	2.5	-0.8	-3.2	2.9	0.7	19.0	9.0	17.0	9.0	4.7	350	0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.9	24.0	18.3	22.1	17.8	20.6	17.0	19.2	22.4	18.4	21.0	17.7	19.9	5.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.0	20.6	17.3	12.4	19.7	16.7	11.9	19.0	54.5	22.7	51.9	21.2	49.7	20.0	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	13.4	11.8	DB	-3.6	26.8	2.2	1.7	-5.2	28.1	-6.5	29.1	-7.7	30.0	-9.4	31.3	(4)
(5)			WB	-4.4	20.6	2.2	1.5	-6.0	21.7	-7.3	22.5	-8.5	23.4	-10.1	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	6.2	5.9	7.5	8.8	12.3	14.4	16.8	17.6	15.2	12.2	8.9	6.5	(6)	
	DBStd	4.81	2.91	2.97	1.95	2.39	2.77	1.88	1.88	2.14	2.01	2.80	3.17	3.06	(7)	
	HDD10.0	555	119	116	79	49	8	1	0	0	0	13	57	113	(8)	
	HDD18.3	2687	377	348	336	286	188	121	56	39	97	190	282	368	(9)	
	CDD10.0	938	1	0	2	13	79	132	211	235	155	81	25	4	(10)	
	CDD18.3	29	0	0	0	0	1	2	9	17	2	0	0	0	(11)	
	CDH23.3	78	0	0	0	0	1	4	24	46	3	0	0	0	(12)	
	CDH26.7	6	0	0	0	0	0	0	1	6	0	0	0	0	(13)	
(14) Wind	WSAvg	5.5	6.6	5.9	5.3	5.4	4.9	5.0	5.0	4.8	5.2	6.0	5.9	6.4	(14)	
(15) Precipitation	PrecAvg	821	93	63	47	52	49	53	53	62	61	95	102	92	(15)	
	PrecMax	1194	188	154	132	110	109	164	122	133	130	281	232	172	(16)	
	PrecMin	612	18	8	3	6	10	10	10	2	4	17	33	12	(17)	
	PrecStd	139	43	39	25	32	28	39	28	34	37	54	54	47	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	11.2	13.3	17.2	23.0	23.8	25.9	27.5	22.7	18.3	15.4	13.1	(19)	
		MCWB	10.2	9.9	10.4	12.7	16.5	17.7	19.3	19.5	17.4	16.4	14.0	11.7	(20)	
	2%	DB	10.8	10.5	11.7	14.8	20.1	20.4	23.3	24.3	20.1	17.4	14.6	12.4	(21)	
		MCWB	9.8	9.3	9.3	11.4	15.2	15.9	18.4	18.7	16.7	15.7	13.4	11.4	(22)	
	5%	DB	10.4	9.9	10.7	13.1	18.2	18.8	21.4	22.5	19.1	16.8	13.9	11.7	(23)	
		MCWB	9.5	8.7	9.0	10.4	14.6	15.2	17.2	18.2	16.2	15.2	12.8	10.8	(24)	
	10%	DB	10.0	9.4	10.1	11.8	16.5	17.4	19.8	21.0	18.3	16.1	13.3	10.9	(25)	
		MCWB	9.2	8.3	8.8	10.0	13.6	14.7	16.5	17.7	15.7	14.5	12.1	9.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.3	11.0	13.3	17.4	18.1	20.7	20.7	18.5	16.9	14.2	12.2	(27)	
		MCDB	10.9	10.9	12.4	16.2	21.3	22.1	24.5	24.8	21.2	17.8	14.9	12.6	(28)	
	2%	WB	10.1	9.6	10.1	11.8	15.9	16.6	19.0	19.5	17.6	16.2	13.8	11.7	(29)	
		MCDB	10.5	10.3	10.9	14.1	19.2	19.3	22.2	22.6	19.6	17.1	14.4	12.3	(30)	
	5%	WB	9.7	9.1	9.6	10.8	14.8	15.7	17.8	18.7	16.8	15.5	13.0	11.0	(31)	
		MCDB	10.2	9.7	10.3	12.3	17.7	17.9	20.2	21.5	18.5	16.6	13.8	11.7	(32)	
	10%	WB	9.3	8.5	9.1	10.3	13.7	15.0	17.0	18.1	16.2	14.8	12.3	10.1	(33)	
		MCDB	9.8	9.2	9.9	11.5	16.2	16.8	18.9	20.4	17.8	16.0	13.1	10.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.4	3.5	3.8	4.5	5.0	4.2	4.3	4.9	4.8	4.4	3.9	3.5	(35)	
		MCDBR	3.0	3.1	4.2	6.5	7.9	7.0	7.5	6.9	5.5	4.0	3.1	3.1	(36)	
	5% WB	MCWBR	3.1	2.9	3.2	4.1	5.0	4.1	4.2	3.7	3.7	3.4	3.0	3.5	(37)	
		MCWBR	3.0	2.9	3.3	5.0	7.4	5.8	5.9	5.6	4.5	3.8	2.7	3.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.335	0.352	0.391	0.408	0.414	0.413	0.407	0.401	0.384	0.368	0.340	0.326	(40)	
		taud	2.363	2.364	2.257	2.237	2.278	2.307	2.330	2.367	2.399	2.415	2.408	2.357	(41)	
	Ebn at Noon		679	771	800	831	843	845	844	830	803	743	670	627	(42)	
		Edh at Noon	65	84	111	126	126	124	119	110	96	79	62	57	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.83	1.54	2.75	4.39	5.25	5.82	5.55	4.64	3.44	1.95	0.98	0.64	(44)	
	RadStd		0.07	0.20	0.34	0.39	0.34	0.51	0.44	0.33	0.23	0.17	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (69 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page