

HERSTMONCEUX WEST END, United Kingdom

WMO: 038820

Lat: 50.8910N

Lon: 0.3165E

Elev: 171

StdP: 14.61

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.0	29.2	21.2	16.0	31.4	23.7	18.1	32.1	25.7	49.4	23.3	49.4	4.8	50	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	79.1	66.7	75.6	64.7	72.5	63.0	68.1	77.0	66.0	73.3	64.3	70.2	6.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	92.2	71.3	63.2	87.2	69.0	61.8	83.0	67.1	32.4	77.2	30.8	73.4	29.5	70.3	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	17.2	15.1	23.2	85.1	3.0	3.7	21.1	87.8	19.3	90.0	17.6	92.1	15.5	94.9
			22.5	71.9	3.1	2.6	20.2	73.8	18.4	75.3	16.7	76.8	14.4	78.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	41.2	41.6	44.6	48.8	54.0	58.9	62.8	62.8	58.6	53.3	46.9	42.4
	DBStd	9.29	5.60	5.31	4.85	5.23	5.17	4.43	4.46	4.14	4.06	4.85	5.50	6.20
	HDD50	1174	274	237	175	82	17	0	0	0	0	24	122	243
	HDD65	5044	738	656	633	487	342	192	98	96	196	362	544	700
	CDD50	1676	1	1	7	45	141	266	398	396	258	127	28	8
	CDD65	71	0	0	0	0	1	8	31	27	4	0	0	0
	CDH74	483	0	0	0	2	15	70	213	165	17	1	0	0
	CDH80	78	0	0	0	0	0	10	39	28	1	0	0	0
Wind	WSAvg	6.5	8.0	7.7	7.2	6.4	6.3	5.9	5.6	5.3	5.5	6.2	6.6	7.5
Precipitation	PrecAvg	31.7	3.6	2.4	1.8	2.0	1.9	2.0	2.0	2.4	2.4	3.6	4.0	3.5
	PrecMax	45.6	7.3	5.9	5.2	4.5	4.2	6.1	4.6	5.3	5.0	10.5	9.2	6.3
	PrecMin	23.7	0.7	0.3	0.2	0.2	0.4	0.4	0.4	0.1	0.2	0.6	1.4	0.4
	PrecStd	5.2	1.7	1.5	0.9	1.2	1.1	1.5	1.0	1.4	1.4	2.0	2.1	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	55.8	61.8	72.2	76.1	80.8	84.9	83.5	76.3	68.2	60.4	56.0
		MCWB	51.4	50.1	52.3	58.5	62.9	67.5	70.6	68.5	65.3	62.0	57.7	53.7
	2%	DB	52.2	52.1	57.5	64.6	71.8	75.4	79.2	78.7	71.7	64.6	58.0	54.5
		MCWB	50.2	48.8	50.5	55.1	61.1	64.1	66.7	66.9	63.1	59.9	55.5	52.7
	5%	DB	50.9	50.5	54.3	60.5	67.7	71.3	75.6	74.2	68.5	62.2	56.7	53.2
		MCWB	49.1	47.8	48.6	52.7	58.6	61.7	65.2	64.4	60.8	58.4	54.4	51.4
	10%	DB	49.5	49.1	51.8	57.3	63.2	68.0	71.9	70.7	65.8	60.7	55.1	51.8
		MCWB	47.6	46.7	47.7	50.9	56.1	59.9	63.1	62.7	59.6	57.6	52.8	50.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.3	51.4	53.5	59.5	65.2	68.7	72.3	70.5	67.0	63.1	58.5	54.7
		MCDB	53.0	53.2	58.7	69.5	73.0	79.1	80.5	79.9	73.9	66.7	59.6	55.3
	2%	WB	51.0	50.0	51.5	55.9	62.0	65.4	68.3	67.8	64.4	61.0	56.3	53.1
		MCDB	51.9	51.4	55.4	63.4	70.0	73.4	77.3	76.4	69.5	63.1	57.4	54.1
	5%	WB	49.4	48.5	50.1	53.6	59.2	62.8	66.0	65.7	62.6	59.6	54.8	51.9
		MCDB	50.5	49.8	52.9	59.0	65.9	69.3	73.5	72.1	66.2	61.5	56.3	53.0
	10%	WB	48.0	47.2	48.7	51.7	57.0	60.9	64.0	63.9	61.1	58.3	53.0	50.1
		MCDB	49.3	48.9	51.1	56.1	62.3	66.4	70.3	68.9	64.4	60.2	54.8	51.6
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.8	12.0	14.3	14.6	14.7	14.6	14.6	14.0	12.1	10.3	9.0
		MCDBR	9.0	10.6	15.8	18.9	20.7	20.9	20.6	19.9	17.0	12.8	9.8	7.6
		MCWBR	8.7	8.3	10.2	11.1	11.9	11.7	10.7	9.8	9.5	8.9	8.5	7.9
	5% WB	MCDBR	9.0	9.6	13.1	17.1	18.6	18.6	18.8	17.1	14.6	11.4	9.2	7.7
		MCWBR	9.2	8.4	9.3	10.7	11.4	11.4	10.5	9.5	9.0	8.6	8.3	8.3
Clear-Sky Solar Irradiance	taub	0.333	0.350	0.388	0.406	0.412	0.411	0.406	0.399	0.382	0.365	0.337	0.323	
	taud	2.367	2.367	2.261	2.237	2.273	2.301	2.321	2.360	2.397	2.416	2.409	2.359	
	Ebn at Noon	216	245	255	264	268	269	268	264	255	236	213	199	
	Edh at Noon	21	26	35	40	40	39	38	35	30	25	20	18	
All-Sky Solar Radiation	RadAvg	261	484	862	1382	1646	1825	1744	1456	1083	613	306	201	
	RadStd	22	67	105	121	112	153	141	103	73	56	34	24	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page