

HERSTMONCEUX WEST END, United Kingdom

WMO: 038820

Lat: 50.8910N

Lon: 0.3165E

Elev: 52

StdP: 100.70

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.8	(c) -1.6	(d) -6.0	(e) 2.3	(f) -0.3	(g) -4.6	(h) 2.6	(i) 0.1	(j) 11.5	(k) 9.7	(l) 10.4	(m) 9.7	(n) 2.1	(o) 50	(p) 0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	26.2	19.3	24.2	18.2	22.5	17.2	20.0	25.0	18.9	22.9	17.9	21.2	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	21.8	17.3	12.5	20.6	16.6	11.9	19.5	57.4	25.1	53.7	23.0	50.7	21.3	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.9	(b) 7.7	(c) 6.7	(e) -4.9	(f) 29.5	(g) 1.7	(h) 2.1	(i) -6.1	(j) 31.0	(k) -7.0	(l) 32.2	(m) -8.0	(n) 33.4	(o) -9.2	(p) 34.9		
(a) 8.9	(b) 7.7	(c) 6.7	(e) -5.3	(f) 22.2	(g) 1.7	(h) 1.4	(i) -6.5	(j) 23.2	(k) -7.5	(l) 24.1	(m) -8.5	(n) 24.9	(o) -9.8	(p) 25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	5.1	5.3	7.0	9.3	12.2	14.9	17.1	17.1	14.8	11.8	8.3	5.8
	DBStd	5.16	3.11	2.95	2.70	2.91	2.87	2.46	2.48	2.30	2.25	2.69	3.06	3.45
	HDD10.0	652	152	132	97	46	9	0	0	0	0	13	68	135
	HDD18.3	2802	410	364	352	271	190	107	54	53	109	201	302	389
	CDD10.0	931	1	1	4	25	78	148	221	220	143	71	16	4
	CDD18.3	39	0	0	0	0	1	4	17	15	2	0	0	0
	CDH23.3	268	0	0	0	1	8	39	118	92	9	1	0	0
	CDH26.7	43	0	0	0	0	0	6	22	16	1	0	0	0
Wind	WSAvg	2.9	3.6	3.5	3.2	2.9	2.8	2.6	2.5	2.4	2.5	2.8	2.9	3.3
Precipitation	PrecAvg	804	91	62	46	52	49	51	51	61	61	91	101	88
	PrecMax	1158	185	150	133	114	106	156	116	134	127	267	234	160
	PrecMin	601	19	7	5	5	10	11	9	3	6	16	36	10
	PrecStd	132	42	38	24	31	27	37	26	35	36	52	53	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	13.2	16.6	22.4	24.5	27.1	29.4	28.6	24.6	20.1	15.8	13.3
		MCWB	10.8	10.1	11.3	14.7	17.1	19.7	21.4	20.3	18.5	16.6	14.3	12.1
	2%	DB	11.2	11.1	14.2	18.1	22.1	24.1	26.2	25.9	22.1	18.1	14.4	12.5
		MCWB	10.1	9.3	10.3	12.9	16.2	17.8	19.3	19.4	17.3	15.5	13.0	11.5
	5%	DB	10.5	10.3	12.4	15.8	19.8	21.8	24.2	23.5	20.3	16.8	13.7	11.8
		MCWB	9.5	8.8	9.2	11.5	14.8	16.5	18.4	18.0	16.0	14.7	12.4	10.8
	10%	DB	9.7	9.5	11.0	14.1	17.4	20.0	22.2	21.5	18.8	16.0	12.9	11.0
		MCWB	8.7	8.2	8.7	10.5	13.4	15.5	17.3	17.0	15.3	14.2	11.6	10.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	10.8	12.0	15.3	18.4	20.4	22.4	21.4	19.4	17.3	14.7	12.6
		MCDB	11.6	11.8	14.8	20.8	22.8	26.2	26.9	26.6	23.3	19.3	15.4	12.9
	2%	WB	10.5	10.0	10.8	13.3	16.7	18.6	20.2	19.9	18.0	16.1	13.5	11.7
		MCDB	11.0	10.8	13.0	17.4	21.1	23.0	25.2	24.7	20.8	17.3	14.1	12.3
	5%	WB	9.7	9.2	10.1	12.0	15.1	17.1	18.9	18.7	17.0	15.3	12.7	11.0
		MCDB	10.3	9.9	11.6	15.0	18.8	20.7	23.1	22.3	19.0	16.4	13.5	11.7
	10%	WB	8.9	8.5	9.3	11.0	13.9	16.1	17.8	17.7	16.2	14.6	11.7	10.1
		MCDB	9.6	9.4	10.6	13.4	16.9	19.1	21.3	20.5	18.0	15.7	12.7	10.9
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.5	6.7	8.0	8.1	8.1	8.1	8.1	7.8	6.7	5.7	5.0
		MCDBR	5.0	5.9	8.8	10.5	11.5	11.6	11.4	11.0	9.4	7.1	5.5	4.2
		MCWBR	4.8	4.6	5.7	6.2	6.6	6.5	5.9	5.5	5.3	4.9	4.7	4.4
	5% WB	MCDBR	5.0	5.3	7.3	9.5	10.3	10.4	10.5	9.5	8.1	6.3	5.1	4.3
		MCWBR	5.1	4.7	5.2	5.9	6.3	6.4	5.8	5.3	5.3	5.0	4.8	4.6
Clear-Sky Solar Irradiance	taub	0.333	0.350	0.388	0.406	0.412	0.411	0.406	0.399	0.382	0.365	0.337	0.323	
	taud	2.367	2.367	2.261	2.237	2.273	2.301	2.321	2.360	2.397	2.416	2.409	2.359	
	Ebn at Noon	681	773	803	833	844	847	844	832	805	745	671	628	
	Edh at Noon	65	83	110	126	127	124	120	110	96	79	62	56	
All-Sky Solar Radiation	RadAvg	0.82	1.52	2.72	4.36	5.19	5.75	5.50	4.59	3.41	1.93	0.96	0.63	
	RadStd	0.07	0.21	0.33	0.38	0.35	0.48	0.45	0.32	0.23	0.18	0.11	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (73 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page