

HERSTMONCEUX OBS, United Kingdom

WMO: 038840

Lat: 50.8700N

Lon: 0.3466E

Elev: 56

StdP: 14.67

Time Zone: 0.00 (EUW)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.1	27.2	17.1	13.1	26.2	20.7	15.6	31.0	39.7	50.3	34.1	47.5	7.6	60	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	76.6	65.1	73.8	63.3	71.1	62.0	66.4	74.9	64.7	71.3	63.4	68.9	9.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.4	87.6	69.2	62.1	83.5	67.3	61.0	80.4	66.2	31.1	75.0	29.8	71.5	28.8	69.1	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.6	26.9	23.2	DB	19.5	83.1	7.1	4.3	14.4	86.2	10.2	88.7	6.2	91.2	1.0	94.3	(4)
(5)			WB	18.5	70.9	7.1	2.8	13.4	72.9	9.2	74.5	5.2	76.0	0.0	78.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.2	40.2	39.1	43.1	46.4	52.6	57.1	62.0	61.6	57.6	53.0	45.6	43.1
	DBStd	9.41	6.36	6.53	4.64	4.78	5.37	4.78	4.03	4.27	4.25	4.73	6.16	5.63
	HDD50	1394	304	305	217	129	29	2	0	0	2	25	159	222
	HDD65	5450	769	724	679	559	384	241	113	121	225	374	581	680
	CDD50	1462	0	1	3	20	111	216	372	359	228	117	28	7
	CDD65	43	0	0	0	0	1	5	19	16	2	0	0	0
	CDH74	255	0	0	0	0	7	32	112	98	6	0	0	0
	CDH80	39	0	0	0	0	0	2	11	26	0	0	0	0
Wind	WSAvg	9.6	11.8	11.0	10.6	9.8	8.6	8.4	8.1	8.3	8.1	9.6	9.4	10.9
Precipitation	PrecAvg	31.7	3.6	2.4	1.8	2.0	1.9	2.0	2.0	2.4	2.4	3.6	4.0	3.5
	PrecMax	45.6	7.3	5.9	5.2	4.5	4.2	6.1	4.6	5.3	5.0	10.5	9.2	6.3
	PrecMin	23.7	0.7	0.3	0.2	0.2	0.4	0.4	0.4	0.1	0.2	0.6	1.4	0.4
	PrecStd	5.2	1.7	1.5	0.9	1.2	1.1	1.5	1.0	1.4	1.4	2.0	2.1	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	55.0	58.0	67.0	74.8	77.8	81.8	83.3	74.5	67.2	59.4	55.9
		MCWB	50.4	52.1	51.4	54.7	61.8	65.5	68.5	66.6	63.6	60.5	56.1	52.6
	2%	DB	51.7	51.9	54.1	61.4	70.7	73.3	77.0	75.7	70.1	63.9	57.5	54.3
		MCWB	49.9	49.1	49.2	52.8	60.4	63.4	65.7	64.1	62.0	59.1	55.2	51.6
	5%	DB	50.5	50.0	51.9	57.9	66.5	70.0	73.9	72.5	67.5	61.9	56.4	52.9
		MCWB	48.7	47.6	47.8	50.6	58.1	61.6	63.8	62.7	60.4	57.8	54.2	50.7
	10%	DB	49.4	48.3	50.1	54.6	62.2	66.2	70.9	69.8	65.2	60.2	54.9	51.6
		MCWB	47.5	45.9	47.1	49.2	55.3	59.2	62.0	61.9	59.5	56.9	52.8	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	52.0	52.7	57.0	64.1	67.6	69.5	68.0	65.6	62.1	56.8	53.8
		MCDB	52.2	54.0	56.9	63.3	73.1	75.1	79.1	77.8	71.7	65.9	58.2	55.0
	2%	WB	50.4	49.8	50.4	53.8	61.1	64.7	66.8	65.7	63.7	59.9	55.6	52.2
		MCDB	51.1	51.3	52.7	59.9	68.5	71.8	75.0	74.4	67.9	62.6	57.1	53.5
	5%	WB	49.1	48.0	49.1	51.7	58.5	62.2	65.0	64.1	62.4	58.7	54.6	51.1
		MCDB	50.3	49.4	51.0	56.2	65.0	68.9	71.8	69.8	65.7	61.0	56.1	52.6
	10%	WB	47.8	46.4	47.8	49.9	56.1	59.8	63.2	62.9	61.0	57.5	53.2	49.8
		MCDB	49.3	48.0	49.6	53.8	62.0	65.0	68.8	67.9	64.4	59.8	54.8	51.5
Mean Daily Temperature Range	5% DB	MDBR	9.3	9.3	11.6	13.5	14.4	14.0	15.0	15.2	14.5	11.7	10.3	8.9
		MCDBR	9.4	9.7	13.0	18.0	20.2	20.1	20.5	19.2	17.3	12.4	7.9	8.3
		MCWBR	9.0	8.5	9.3	11.1	12.2	12.1	10.9	9.6	10.2	8.6	7.1	7.6
	5% WB	MCDBR	9.5	9.1	10.9	15.3	18.5	18.2	17.7	16.1	14.5	10.6	8.0	8.2
		MCWBR	9.6	8.5	8.7	10.2	11.8	11.7	10.3	9.1	9.9	8.6	7.6	7.9
Clear-Sky Solar Irradiance	taub	0.335	0.352	0.390	0.408	0.415	0.414	0.409	0.402	0.384	0.367	0.340	0.325	
	taud	2.364	2.363	2.256	2.232	2.269	2.298	2.319	2.358	2.394	2.412	2.406	2.356	
	Ebn at Noon	215	245	254	263	267	268	267	263	255	236	212	199	
	Edh at Noon	21	27	35	40	40	40	38	35	30	25	20	18	
All-Sky Solar Radiation	RadAvg	261	484	863	1385	1649	1829	1749	1460	1085	614	306	201	
	RadStd	22	67	105	121	112	152	141	102	72	56	34	24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page