

JERSEY, Jersey

WMO: 038950

Lat: 49.210N

Lon: 2.194W

Elev: 277

StdP: 14.55

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.3	33.5	23.5	17.9	34.5	26.1	20.3	36.3	36.7	46.3	33.1	46.0	12.6	90	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.1	77.0	65.0	73.3	63.3	70.4	62.2	66.4	73.8	64.8	70.5	63.6	68.2	10.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.9	89.9	68.3	62.8	86.3	66.6	61.7	83.1	65.5	31.2	74.0	30.0	70.7	29.0	68.4	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.1	27.5	24.8	DB	27.7	84.7	3.2	4.4	25.4	87.9	23.5	90.4	21.7	92.9	19.4	96.1	(4)
(5)			WB	26.0	70.1	3.2	1.9	23.6	71.5	21.7	72.6	19.9	73.7	17.6	75.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.1	44.1	43.9	46.4	49.7	54.6	59.4	62.8	63.3	60.6	56.0	50.0	45.7
	DBStd	8.22	5.06	4.51	4.24	4.34	4.39	4.05	3.77	3.39	3.44	4.09	4.30	5.22
	HDD50	749	187	172	125	54	7	0	0	0	0	6	50	148
	HDD65	4410	649	590	578	460	324	177	89	75	140	280	449	599
	CDD50	1875	3	2	12	44	149	281	398	413	317	192	51	13
	CDD65	64	0	0	0	0	1	9	22	23	8	1	0	0
	CDH74	275	0	0	0	0	8	59	100	90	17	1	0	0
	CDH80	48	0	0	0	0	0	11	19	18	0	0	0	0
Wind	WSAvg	13.1	15.6	14.6	13.6	12.5	12.0	11.3	11.1	10.9	12.2	13.7	14.8	15.5
Precipitation	PrecAvg	33.5	3.8	2.8	2.7	2.1	2.1	1.8	1.6	1.9	2.7	3.5	4.3	4.2
	PrecMax	42.8	7.2	6.1	5.0	4.6	5.0	3.6	4.1	5.3	6.5	8.1	7.7	7.8
	PrecMin	22.8	0.6	0.2	0.1	0.1	0.1	0.0	0.2	0.0	0.6	0.1	1.0	1.3
	PrecStd	5.2	1.8	1.6	1.3	1.0	1.3	0.9	0.8	1.3	1.5	2.0	1.7	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	54.7	61.5	69.5	74.3	81.1	82.2	81.8	76.6	68.2	60.5	56.1
		MCWB	52.1	50.1	53.4	57.1	61.9	66.4	66.8	67.3	64.7	62.0	58.3	54.2
	2%	DB	52.7	52.3	56.6	63.0	69.1	74.0	76.3	75.8	71.3	64.7	58.4	54.8
		MCWB	51.1	49.7	50.7	54.4	59.4	62.9	64.5	65.3	62.7	60.3	56.2	53.4
	5%	DB	51.4	50.9	53.8	58.9	65.0	69.7	72.6	71.7	68.2	62.8	57.1	53.7
		MCWB	49.9	48.9	49.9	52.4	57.4	61.1	62.9	63.6	61.5	59.3	54.9	52.1
	10%	DB	50.4	49.7	51.9	55.9	61.6	66.4	69.5	68.6	65.7	61.3	55.8	52.5
		MCWB	48.8	47.9	49.0	50.8	55.7	59.5	62.1	62.3	60.2	58.3	53.5	50.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.0	51.9	54.0	58.6	64.1	67.9	68.4	69.0	66.3	63.3	59.1	55.2
		MCDB	53.4	52.9	58.7	66.0	71.8	78.4	78.0	78.2	72.9	66.5	59.7	55.5
	2%	WB	51.7	50.5	52.2	55.3	60.4	64.5	65.8	66.6	64.3	61.5	56.9	53.8
		MCDB	52.4	51.4	55.0	61.4	67.1	72.2	73.5	72.8	68.9	63.7	57.8	54.4
	5%	WB	50.4	49.4	50.9	53.2	58.3	62.0	64.3	64.8	62.9	60.1	55.5	52.6
		MCDB	51.2	50.5	52.9	57.3	63.6	68.0	70.0	69.4	66.3	62.1	56.8	53.5
	10%	WB	49.2	48.4	49.6	51.5	56.4	60.3	63.0	63.5	61.7	59.0	54.0	51.4
		MCDB	50.2	49.5	51.4	54.9	60.5	65.0	67.7	67.2	64.7	60.9	55.5	52.4
Mean Daily Temperature Range	5% DB	MDBR	6.3	7.0	8.4	10.1	10.5	11.0	10.7	10.1	9.6	7.7	6.4	6.4
		MCDBR	6.0	7.5	11.6	15.1	16.3	17.5	16.8	15.7	13.2	8.8	6.3	5.7
		MCWBR	6.4	6.5	7.7	8.9	9.3	9.4	8.2	7.7	6.9	6.2	6.4	6.5
	5% WB	MCDBR	5.9	6.8	9.6	12.9	14.6	15.6	14.2	12.8	11.1	7.8	6.2	5.9
		MCWBR	6.7	6.8	7.2	8.3	8.9	9.2	7.9	7.2	7.0	6.5	6.7	6.9
Clear-Sky Solar Irradiance	taub	0.334	0.350	0.381	0.393	0.398	0.392	0.388	0.381	0.370	0.361	0.337	0.327	
	taud	2.414	2.399	2.322	2.315	2.352	2.398	2.409	2.453	2.461	2.464	2.446	2.380	
	Ebn at Noon	226	251	261	271	274	276	275	272	263	245	224	210	
	Edh at Noon	21	27	34	37	37	36	35	32	29	25	20	19	
All-Sky Solar Radiation	RadAvg	285	527	903	1433	1713	1879	1811	1518	1169	663	353	235	
	RadStd	23	63	96	126	130	189	105	115	81	50	35	28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page