

PORTGLENONE, United Kingdom

WMO: 039150

Lat: 54.8653N

Lon: 6.4583W

Elev: 213

StdP: 14.58

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	30.1	23.2	17.6	32.2	25.6	19.7	33.9	40.1	41.1	30.4	44.0	2.9	130	0.624

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	72.4	63.2	69.1	61.7	66.4	60.2	64.7	70.0	62.9	67.2	61.4	65.2	8.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.6	85.6	66.7	61.0	80.8	65.1	59.5	76.6	63.5	29.8	70.2	28.5	67.2	27.5	65.5	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.3	21.6	18.8	DB	22.4	76.6	4.0	3.0	19.5	78.7	17.2	80.5	14.9	82.1	12.0	84.3
			WB	22.0	67.7	3.8	2.2	19.3	69.3	17.1	70.6	15.0	71.8	12.2	73.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	40.4	40.9	43.1	46.6	51.1	55.5	58.5	58.3	55.0	50.2	44.6	41.0	(6)
	DBStd	8.03	4.94	4.66	4.65	4.65	4.81	4.32	4.07	3.59	3.75	4.39	4.88	5.72	(7)
	HDD50	1450	298	255	220	122	43	5	0	0	4	52	171	280	(8)
	HDD65	5921	762	674	680	553	432	286	207	211	300	460	613	743	(9)
	CDD50	1013	1	1	4	19	76	170	263	257	154	58	8	2	(10)
	CDD65	9	0	0	0	0	0	1	5	3	0	0	0	0	(11)
	CDH74	47	0	0	0	0	0	14	22	11	0	0	0	0	(12)
	CDH80	2	0	0	0	0	0	2	0	0	0	0	0	0	(13)
	Wind	WSAvg	8.5	10.0	9.4	9.1	8.8	8.1	7.6	7.2	7.3	7.8	8.9	9.3	(14)
	Precipitation	PrecAvg	42.2	4.1	3.1	3.0	2.9	3.0	3.3	3.5	3.1	4.6	4.4	4.3	(15)
(16) Precipitation	PrecMax	52.1	6.9	5.8	6.2	5.0	6.7	6.5	5.4	8.8	7.3	8.6	7.2	8.8	(16)
	PrecMin	33.3	1.1	1.1	0.8	1.2	0.5	1.2	1.5	0.6	0.0	1.8	2.4	2.1	(17)
	PrecStd	4.5	1.4	1.2	1.3	1.1	1.5	1.3	1.0	1.8	1.6	2.0	1.4	1.5	(18)
	PrecStd	4.5	1.4	1.2	1.3	1.1	1.5	1.3	1.0	1.8	1.6	2.0	1.4	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.8	54.9	58.1	64.7	72.0	75.4	77.0	75.4	68.7	62.0	57.6	55.3	(19)
		MCWB	51.5	51.6	51.2	55.0	61.4	62.9	66.9	65.3	63.1	58.3	55.7	53.5	(20)
	2%	DB	51.6	52.3	54.4	60.0	66.7	70.1	72.8	70.2	65.8	59.9	55.4	53.2	(21)
		MCWB	49.8	49.9	49.8	52.5	58.3	61.4	63.9	62.9	60.7	57.2	53.6	51.6	(22)
	5%	DB	49.9	50.3	52.4	56.7	62.7	66.5	69.1	67.0	63.3	58.4	53.6	51.5	(23)
		MCWB	48.3	48.2	48.5	50.8	55.9	59.3	62.2	61.1	58.9	55.8	51.9	49.9	(24)
	10%	DB	48.1	48.4	50.5	54.3	59.6	63.4	66.0	64.7	61.4	57.0	51.9	49.4	(25)
		MCWB	46.6	46.4	47.2	49.3	53.8	57.4	60.6	59.8	57.4	54.5	50.2	47.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.3	52.3	52.8	56.4	62.5	64.9	68.0	66.7	64.8	60.1	56.2	54.1	(27)
		MCDB	53.2	53.8	56.3	61.5	69.8	72.7	75.0	72.6	67.3	61.0	57.1	55.0	(28)
	2%	WB	50.2	50.4	50.8	53.9	59.1	62.3	65.2	63.8	61.8	57.9	54.1	52.0	(29)
		MCDB	51.2	51.9	53.4	58.6	65.1	68.4	70.9	68.0	64.5	59.3	55.0	53.0	(30)
	5%	WB	48.6	48.5	49.2	51.7	56.8	60.2	63.0	62.3	59.9	56.4	52.2	50.1	(31)
		MCDB	49.6	50.0	51.7	55.6	61.9	65.1	67.5	65.7	62.5	57.9	53.3	51.3	(32)
	10%	WB	46.7	46.7	47.6	49.9	54.6	58.3	61.2	60.8	58.2	54.9	50.4	48.0	(33)
		MCDB	48.0	48.3	50.1	53.7	58.8	62.6	65.2	63.8	60.6	56.5	51.7	49.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.6	11.1	12.5	13.8	13.1	12.5	12.3	11.5	10.1	8.7	8.4	(35)
		MCDBR	9.4	10.1	12.3	15.4	18.1	18.1	16.9	15.2	13.1	10.2	8.9	10.1	(36)
		MCWBR	9.0	9.1	8.8	9.8	11.6	11.0	10.2	9.4	8.8	8.4	8.5	9.8	(37)
	5% WB	MCDBR	9.6	9.9	11.5	13.6	16.8	16.4	15.3	13.3	11.7	9.7	8.8	10.3	(38)
		MCWBR	9.4	9.3	9.2	9.6	11.3	10.8	10.3	9.3	9.0	8.6	8.7	10.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.337	0.347	0.370	0.383	0.388	0.379	0.381	0.365	0.360	0.345	0.330	0.325	(40)
	taud		2.215	2.296	2.277	2.281	2.313	2.371	2.369	2.428	2.439	2.407	2.280	2.183	(41)
	Ebn at Noon		181	229	252	266	272	275	272	270	255	229	184	154	(42)
	Edh at Noon		20	25	32	37	38	36	36	31	27	23	18	16	(43)
(44) All-Sky Solar Radiation	RadAvg		176	392	725	1184	1509	1536	1414	1150	816	462	218	129	(44)
	RadStd		19	35	67	105	135	153	113	94	43	42	23	13	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page