

GLENANNE NO2, United Kingdom

WMO: 039230

Lat: 54.2369N

Lon: 6.5039W

Elev: 160

StdP: 99.42

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.2	-1.0	-4.5	2.6	-0.1	-3.3	2.9	0.7	13.7	7.8	12.7	7.6	2.9	300	0.644

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	21.8	17.1	20.2	16.3	18.8	15.5	18.0	20.5	17.0	19.2	16.2	18.1	3.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	12.3	19.1	16.1	11.6	18.0	15.3	11.0	17.2	51.2	20.6	48.3	19.2	45.9	18.2	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.4	10.0	8.9	DB	-4.7	24.6	2.7	1.9	-6.6	26.0	-8.2	27.1	-9.7	28.1	-11.7	29.5	(4)
			WB	-4.9	19.7	2.8	1.0	-6.9	20.5	-8.5	21.1	-10.0	21.6	-12.1	22.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	4.5	4.7	5.9	7.8	10.3	13.1	14.6	14.4	12.6	9.9	6.8	4.9
	DBStd	4.45	2.65	2.56	2.59	2.47	2.62	2.36	2.08	1.89	2.00	2.32	2.65	3.02
	HDD10.0	846	171	148	130	74	27	2	0	0	3	31	100	159
	HDD18.3	3357	429	381	387	317	248	159	117	122	172	263	346	416
	CDD10.0	536	0	1	2	8	38	94	144	138	81	27	4	1
	CDD18.3	4	0	0	0	0	0	1	2	1	0	0	0	0
	CDH23.3	21	0	0	0	0	0	6	9	5	0	0	0	0
	CDH26.7	1	0	0	0	0	0	1	0	0	0	0	0	0
Wind	WSAvg	4.3	5.1	5.1	4.7	4.3	3.8	3.6	3.4	3.5	3.8	4.3	4.6	4.9
Precipitation	PrecAvg	819	80	57	66	58	60	60	54	77	71	85	73	79
	PrecMax	1059	130	154	108	132	130	121	107	146	166	157	139	166
	PrecMin	586	31	4	28	9	7	15	15	14	4	37	25	17
	PrecStd	98	26	34	24	27	31	24	25	30	35	37	30	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	12.2	14.2	17.3	21.3	23.5	24.8	23.5	20.2	16.4	14.1	12.8
		MCWB	10.7	10.7	10.5	12.6	16.1	17.1	19.2	18.6	17.2	14.6	13.3	12.0
	2%	DB	10.6	10.9	12.2	14.9	18.8	20.9	22.1	20.6	18.3	15.2	12.8	11.4
		MCWB	9.7	9.8	10.0	11.3	14.6	16.2	17.4	17.0	15.9	13.9	12.1	10.6
	5%	DB	9.6	9.9	11.0	13.2	16.6	19.0	20.2	19.1	17.1	14.3	11.7	10.5
		MCWB	8.9	8.8	9.1	10.3	13.1	15.0	16.3	16.1	14.8	13.1	11.0	9.8
	10%	DB	8.7	8.8	10.0	11.8	14.9	17.4	18.6	17.9	16.0	13.5	10.9	9.4
		MCWB	7.9	7.7	8.4	9.4	12.0	14.0	15.4	15.3	13.9	12.4	10.2	8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.8	11.1	11.6	13.5	17.0	18.3	19.5	19.2	17.8	15.2	13.4	12.1
		MCDB	11.1	11.8	13.0	15.8	20.2	22.2	23.6	21.7	19.3	15.7	13.8	12.4
	2%	WB	9.9	10.1	10.5	12.1	15.0	16.7	18.1	17.7	16.5	14.3	12.3	10.8
		MCDB	10.4	10.8	11.7	14.2	18.0	19.8	20.9	19.8	17.8	14.9	12.7	11.3
	5%	WB	9.0	9.0	9.6	10.8	13.6	15.6	16.9	16.8	15.4	13.5	11.2	9.9
		MCDB	9.5	9.8	10.7	12.6	16.1	18.3	19.3	18.5	16.6	14.1	11.7	10.5
	10%	WB	8.0	7.9	8.6	9.8	12.4	14.6	16.0	15.9	14.5	12.6	10.3	8.8
		MCDB	8.6	8.8	9.8	11.6	14.4	16.9	18.0	17.4	15.6	13.4	10.9	9.4
Mean Daily Temperature Range	5% DB	MDBR	4.4	5.0	5.9	6.7	7.5	7.3	6.9	6.6	6.1	5.3	4.6	4.3
		MCDBR	5.5	5.6	6.8	8.3	9.7	9.5	9.2	7.9	7.1	5.7	4.9	5.4
		MCWBR	5.4	5.1	5.1	5.5	6.3	5.7	5.5	5.1	5.0	4.7	4.8	5.3
	5% WB	MCDBR	5.5	5.6	6.3	7.7	9.0	8.7	8.3	7.3	6.6	5.4	4.8	5.4
		MCWBR	5.4	5.3	5.2	5.6	6.2	5.8	5.7	5.3	5.2	4.9	4.9	5.4
Clear-Sky Solar Irradiance	taub	0.329	0.339	0.363	0.376	0.381	0.373	0.375	0.359	0.352	0.339	0.322	0.317	
	taud	2.245	2.325	2.291	2.290	2.313	2.366	2.366	2.424	2.441	2.423	2.308	2.211	
	Ebn at Noon	600	744	807	849	864	874	865	860	817	739	609	524	
	Edh at Noon	62	79	101	115	119	114	112	100	87	71	57	52	
All-Sky Solar Radiation	RadAvg	0.62	1.30	2.33	3.70	4.67	4.78	4.35	3.58	2.65	1.54	0.77	0.47	
	RadStd	0.06	0.12	0.24	0.39	0.41	0.50	0.39	0.31	0.13	0.14	0.08	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page