

SHERKIN ISLAND, Ireland

WMO: 039510

Lat: 51.4767N

Lon: 9.4289W

Elev: 69

StdP: 14.66

Time Zone: 1.00 (IRL)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.6	34.3	25.7	19.7	34.5	28.3	22.3	36.7	42.9	47.5	39.0	48.0	11.9	50	0.737

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	67.3	61.9	65.0	60.5	63.7	59.7	63.0	65.5	62.0	64.0	61.0	62.8	11.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.1	83.5	63.6	61.1	80.6	62.8	60.2	78.0	62.0	28.5	65.5	27.8	64.1	27.1	62.8	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
36.4	32.1	28.7	DB	30.1	69.7	4.5	3.5	26.9	72.2	24.2	74.3	21.7	76.3	18.5	78.8
			WB	29.0	64.3	4.2	2.0	26.0	65.7	23.5	66.9	21.2	68.0	18.1	69.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	45.8	45.5	45.9	48.9	52.7	56.8	59.4	58.9	57.4	54.0	48.8	47.0	(6)
(7)		DBStd	6.29	4.35	4.21	3.92	2.99	3.21	2.98	2.90	1.78	2.54	3.40	4.54	4.87	(7)
(8)		HDD50	649	135	132	132	53	9	0	0	0	0	8	72	108	(8)
(9)		HDD65	4824	595	547	593	484	382	247	175	189	228	342	485	557	(9)
(10)		CDD50	1302	5	4	5	19	92	203	292	276	222	131	37	16	(10)
(11)		CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0	(11)
(12)		CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	14.2	16.2	16.0	14.5	13.6	12.3	12.0	11.2	12.2	13.3	14.5	16.8	17.7	(14)
(15)	Precipitation	PrecAvg	50.4	5.9	4.4	3.4	3.1	3.1	3.3	3.7	3.5	3.7	5.2	5.4	5.7	(15)
(16)		PrecMax	64.0	9.4	9.8	5.7	5.1	5.9	7.5	7.0	7.3	8.4	8.9	12.6	14.9	(16)
(17)		PrecMin	40.1	2.3	1.1	0.9	0.9	0.2	0.6	1.6	0.9	1.1	1.2	1.5	1.3	(17)
(18)		PrecStd	6.5	2.0	2.5	1.5	1.3	1.4	1.4	1.4	1.9	1.7	2.2	2.2	2.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.8	53.4	56.1	58.6	66.5	70.4	71.7	65.7	65.2	62.1	58.1	55.1	(19)
(20)			MCWB	52.2	51.0	50.6	53.2	61.0	61.6	64.0	60.9	61.1	60.1	56.7	53.4	(20)
(21)		2%	DB	52.6	52.4	52.7	56.2	61.8	65.7	68.4	64.3	63.4	60.9	57.0	54.5	(21)
(22)			MCWB	51.0	50.5	49.9	52.2	56.9	59.8	62.9	60.2	60.1	59.1	55.7	52.9	(22)
(23)		5%	DB	51.8	51.7	51.8	54.3	59.1	63.7	66.1	63.2	62.2	59.6	55.8	53.7	(23)
(24)			MCWB	50.3	50.1	49.5	50.8	55.3	58.5	61.8	59.6	59.3	57.7	54.1	52.4	(24)
(25)		10%	DB	51.2	50.9	51.0	53.0	57.3	61.8	64.2	62.2	61.2	58.5	55.0	52.7	(25)
(26)			MCWB	49.6	49.4	48.8	49.9	54.1	57.5	60.5	59.1	58.7	56.4	53.1	51.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.9	52.2	52.2	55.2	60.2	62.6	65.5	63.4	62.7	61.8	57.5	54.5	(27)
(28)			MCDWB	53.3	52.5	53.1	57.7	64.8	68.5	69.2	64.1	63.6	62.0	57.7	54.9	(28)
(29)		2%	WB	52.0	51.4	51.2	53.1	57.5	60.7	63.8	62.1	61.3	60.1	56.1	53.7	(29)
(30)			MCDWB	52.3	51.9	52.0	54.7	60.6	64.5	66.9	63.2	62.3	60.4	56.6	54.2	(30)
(31)		5%	WB	51.1	50.8	50.5	52.1	56.1	59.5	62.5	61.2	60.6	58.5	54.9	52.8	(31)
(32)			MCDWB	51.7	51.5	51.6	53.5	58.4	62.6	65.3	62.3	61.6	59.1	55.7	53.4	(32)
(33)		10%	WB	50.2	50.1	49.6	51.2	54.9	58.4	61.3	60.3	59.7	57.3	53.8	51.8	(33)
(34)			MCDWB	51.1	51.0	50.9	52.6	56.8	61.1	63.8	61.5	60.9	58.3	55.0	52.5	(34)
(35)	Mean Daily Temperature Range		MDBR	6.4	6.3	7.5	7.9	7.8	7.8	7.6	7.0	6.7	6.5	6.5	6.3	(35)
(36)		5% DB	MCDBR	5.2	5.1	7.1	8.7	10.2	10.7	10.1	8.0	7.5	6.4	5.7	5.6	(36)
(37)			MCWBR	6.1	5.4	6.4	6.3	6.7	6.6	6.5	5.6	5.9	5.7	6.4	6.5	(37)
(38)		5% WB	MCDWB	5.1	4.7	6.4	7.5	8.7	9.2	9.1	6.7	6.4	5.3	5.7	5.8	(38)
(39)			MCWBR	6.3	5.2	6.6	6.2	6.2	6.3	6.6	5.7	5.8	5.6	6.5	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.353	0.359	0.382	0.384	0.395	0.376	0.382	0.366	0.364	0.358	0.344	0.346	(40)	
(41)		taud	2.246	2.311	2.283	2.327	2.335	2.427	2.416	2.474	2.465	2.416	2.316	2.218	(41)	
(42)		Ebn at Noon	199	238	256	271	272	279	275	274	261	237	203	178	(42)	
(43)		Edh at Noon	23	28	34	36	38	35	35	31	28	24	21	20	(43)	
(44)	All-Sky Solar Radiation	RadAvg	252	473	836	1353	1641	1797	1635	1393	1005	577	319	192	(44)	
(45)		RadStd	24	36	84	92	98	142	132	78	78	55	23	24	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page